

Parameters	Units	Time			MCL
		2:00 PM	4:00 PM	6:00 PM	
Anion Analysis					
Chloride	mg/L	*95	*106	204	250 mg/L
Fluoride	mg/L	0.896	0.928	0.976	2 mg/L
Nitrate	mg/L	*ND < 0.1	*ND < 0.1	ND < 0.05	10 mg/L
Nitrite	mg/L	*ND < 0.002	*ND < 0.002	ND < 0.05	1 mg/L
Sulfate	mg/L	213	215	214	250 mg/L
Metals Analysis					
Barium	mg/L	3	1	0.0228	2 mg/L
Boron	mg/L	0.484	0.498	0.506	NA
Calcium	mg/L	74.2	72.9	72.4	NA
Chromium	mg/L	0.0117	0.0117	0.0113	0.1 mg/L
Iron	mg/L	0.897	0.974	1.04	0.3 mg/L
Magnesium	mg/L	23.4	23.1	23.4	NA
Manganese	mg/L	0.0106	0.0112	0.0116	0.05 mg/L
Mercury	mg/L	0.0005	0.0003	0.0004	0.002 mg/L
Nickel	mg/L	0.0041	0.0042	0.0041	NA
pH		*7.8	*7.8	7.93	6.5-8.5
Potassium	mg/L	21.4	20.4	21.0	NA
Selenium	mg/L	ND <0.005	0.0581	ND <0.005	0.05 mg/L
Sodium	mg/L	152	150	142	NA
Zinc	mg/L	*0.08	*0.01	0.0311	5 mg/L
Hardness Analysis					
Hardness as Calcium	mg/L	214	210	209	NA
Hardness as Magnesium	mg/L	112	110	112	NA
Total Hardness	mg/L	326	320	321	NA
*Total Hardness	mg/L	*376	*342	*359	NA
Volatiles Analysis					
Methylene Chloride	ug/L	ND < 0.5	13.40	ND < 0.5	NA
Trichloroethene	ug/L	ND <0.5	1.57	ND <0.5	NA
Xylenes (total)	ug/L	1.05	ND < 1.0	1.13	10 mg/L
Turbidity Analysis					
Turbidity	NTU	0.30	0.25	0.32	0.5 NTU
Subcontracted Analysis					
Methane	ug/L	No Data	No Data	215	NA
Alkalinity Analysis					
Alkalinity, Total (as CaCO ₃)	mg/L	254	253	251	NA
Total Dissolved Solids Analysis					
Total Dissolved Solids	mg/L	800	784	820	500 mg/L
Ammonia Analysis					
Ammonia (as N)	mg/L	1.36	1.27	1.71	NA

* Denotes Field Data