

Existant

Existing 10KV Switchgear

INCOMER 1 (TR-01)	INCOMER 2									BUS- COUPLER	REMONTE E BARRES								INCOMER 3 (TR-02)
2000A	2000A	1250A	1250A	1250A	1250A	1250A	1250A	1250A	1250A	2000A		1250A	1250A	1250A	1250A	1250A	1250A	1250A	2000A
1	2	3	4	5	6	7	8	9	10	11		12	13	14	15	16	17	18	19

Step 1

INCOMER 1 (TR-01)	INCOMER 2								
2000A	2000A	1250A	1250A	1250A	1250A	1250A	1250A	1250A	1250A
1	2	3	4	5	6	7	8	9	

									INCOMER 3 (TR-02)
FDR	FDR	FDR	FDR	FDR	FDR	FDR	FDR	FDR	2000A
1250A	1250A	1250A	1250A	1250A	1250A	1250A	1250A	1250A	2000A
12	13	14	15	16	17	18	19		

2 cabinets to be removed

BUS- COUPLER	REMONTE E BARRES
2000A	

Etape 2

INCOMER 1 (TR-01)	INCOMER 2																	INCOMER 3 (TR-02)
2000A	2000A	1250A	1250A	1250A	1250A	1250A	1250A	1250A	1250A	FDR	BUS-COUPLER							2000A
1	2	3	4	5	6	7	8	9										19

Busbar TR N°1

Busbar N°2

New feeder to be added