

TT # 2952

SER. NO. 201B05T  
 CUSTOMER: JO TRINIPAD INC.  
 P.O. NO. TTI-3461B-1541  
 SERVICE DEAERATED BOILER FEEDWATER

DATE 12-10-79

REV. DATE 1-22-82 ISSUE # 1

MIN. FLOW = 330 wpm

**GOULDS PUMPS, INC.**  
 SENECA FALLS NEW YORK 13085

**CENTRIFUGAL PUMP CHARACTERISTICS**  
BASED ON GOULDS STANDARD CONDITIONS

**RPM 3550 GDS 2679-1**

**MODEL 3300** *9 7/8"*

**SIZE** 4 x 6-10

**IMP. DWG. D01158A, 1157A & 1159A**

**PATTERN 57447, 57458, 57597**

**EYE AREA 30 in<sup>2</sup>** (U<sub>1</sub> = 85 ft/sec)

**MAX. IMP. DIA. = 10 3/8** NS = 1436

