



Truss Detail

- Timber Post and Roof Truss Spaced 8.0' O.C. Typ.
- View is Looking at Front of Truss. Back of Truss (2X10) is attached to Posts.
- 2X6 Cross Members Overlap Chords and are Nailed to Chords (5 Nails Each).
- No Metal Plates, Front or Back of Truss.
- 2X10 Top Chord is Labeled 460 KABOB W WP S-Dry 2.
- 2X6 Cross Members are Labeled 118 S-P-F S-Dry No.1 Keystone Kiln Dried.
- 2X4 Stringers are Labeled Millar AFPA 23 SPF S-Dry Stand & Btr.
- 6X6 Posts are Labeled 68 CCA C 99 TP Ground Contact LP-22-.40 Free State Lumber Co Haleyville Al.

