

Interpretation Detail

Standard Designation:	BPV Section I
Edition/Addenda:	
Para./Fig./Table No:	
Subject Description:	Section I, Upgrading Marking on Material
Date Issued:	09/17/1991
Record Number:	BC91-418
Historical Interpretation numbers:	I-92-06
Question(s) and Reply(ies):	Question: May a boiler or part manufacturer re-identify pipe which is marked with SA-106, Grade B, and upgrade it to SA-106, Grade C, if it is shown by means of a Mill Test Report that the pipe meets all the physical, chemical, and testing requirements of Grade C pipe and provided the rules of PG-10 are met? Reply: Yes.