



1. THE CONTRACTOR SHALL LOCATE ALL UTILITIES, EMBEDDED PIPES, AND CONDUITS IN THE VICINITY OF THE AREAS TO BE REPAIRED.

2. SEE SPECIFICATIONS FOR WATERPROOFING, CONCRETE CRACK REPAIR, AND PARTIAL DEPTH DEFECT OR DELAMINATION REPAIR REQUIREMENTS.

3. ALL REPAIRS SHALL BE PERFORMED IN A MANNER SO AS TO PRODUCE A UNIFORM, FINISHED SURFACE, PREVIOUSLY PAINTED CONCRETE SURFACES SHALL BE RE-PAINTED USING SHERWIN WILLIAMS MILLENNIUMS BLENK-GLOSS COATING ON APPROVED EPOXY SURFACE PREPARATION, FILLING, AND COATING SHALL BE PERFORMED IN ACCORDANCE WITH MANUFACTURERS' RECOMMENDATIONS, COLORS, CURE TO MATCH EXISTING.

4. REPAIR AREAS SHOULD BE APPROXIMATE. THE CONTRACTOR SHALL SET THE REPAIR LIMITS AND TURNISH THE REPAIR LIMITS TO THE ENGINEER FOR REVIEW AND REPAIR AREAS SHOWN TO BE WORK. THE CONTRACTOR SHALL COORDINATE ALL REPAIR WORK WITH THE SITE OWNER.

5. IF THE TIME LIMIT SHALL BE THAT THE JOB OR SURFACE TO WHICH SOUND CONCRETE IS DISCOVERED AFTER SURFACE PREPARATION IS COMPLETE, TO ELIMINATE FURNISHED SOUNDING EFFECTS, THE REM LINE MAY NEED TO EXTEND DEEPER INTO SOUND CONCRETE.

6. UNLESS SPECIFICALLY DIRECTED BY THE ENGINEER, DEPTH OF REMOVAL SHALL NOT EXCEED 4 INCHES.

7. STEEL FABRIC SHALL BE WETTED WIRE FABRIC .404 MAXIMUM DIA.

8. ANY OVERLAP AREA WHERE STEEL FABRIC IS REQUIRED SHALL HAVE A MINIMUM OF 14" TYP DIAMETER THREADED ADHESIVE ANCHORS, LENGTH TO SUIT WITH MINIMUM 6" EMBEDMENT INTO SOUND CONCRETE.

9. IF GREATER THAN 30% OF THE DEPTH OF EXISTING REINFORCEMENT IS EXPOSED AT THE LIMITS OF SOUND CONCRETE, REMOVE CONCRETE TO ACHIEVE 3/4" MINIMUM CLEARANCE TO EXISTING CONCRETE. CLEAN & SHOW REINFORCING AGENT.

10. IF EXPOSED EXISTING REINFORCEMENT BARS HAVE GREATER THAN 20% SECTION LOSS, CLAMP DOWN EXPOSED REINFORCEMENT TO CHAIN, TURNISH NEW