



RULE: IF EITHER 'X' IS GREATER THAN TWO INCHES (2") THEN ANGLES SHALL BE ADDED AS INDICATED ABOVE TO TRANSFER CONCENTRATED LOAD TO A PANEL POINT. ALL CONDITIONS SHOULD BE VERIFIED WITH STRUCTURAL ENGINEER.

FIELD MODIFICATIONS TO JOISTS FOR CONCENTRATED LOADS

TYPICAL MECHANICAL EQUIPMENT ROOF FRAMES

7
S8.0

DETAIL

SCALE: 3/4" = 1'-0"

8
S8.0

SECTION

SCALE: 3/4" = 1'-0"

DWG NAME: 0. 2.000 Yrns...
 LOT DATE: Jan 20, 2005 - 3:07pm