



Direct Shear Test Report

Sample Identification		Sample Description	Sample Test State
B1 @ 10'		CL-ML	Saturated-Consolidated
Peak:	Phi (Degrees)	31.0	(Avg.Dry Dens. = 104.9 pcf) (Avg.Moist. = 22.03 %)
	Cohesion (PSF)	948.0	
Ultimate:	Phi (Degrees)	28.1	
	Cohesion (PSF)	-18.0	

☒ Relatively Undisturbed
☐ Remolded



Project Name: