



NOTES:

- 1.
2. CROSS TIES ARE REQUIRED WHERE AREA OF SCHEDULED VERTICAL REINFORCEMENT EXCEEDS 0.01 TIMES THE GROSS CONCRETE AREA OF THE WALL. IF CENTER TO CENTER SPACING OF VERTICAL BARS IS 6" OR SMALLER, CROSS TIES SHALL BE PLACED AT EVERY OTHER PAIR OF VERTICAL BARS; OTHERWISE, ALL VERTICAL BARS SHALL BE CONFINED WITH CROSS TIES. CROSS TIES SHALL BE #3 BARS FOR #10 VERTICAL BARS & SMALLER AND #4 BARS FOR #11 VERTICAL BARS & LARGER.