

Contents

- 1. Introduction 2**
 - 1.1 Features..... 2
 - 1.2 Application..... 2
 - 1.3 Input description..... 4
 - 1.4 Output description 4
- 2. Description of Operation..... 5**
 - 2.1 Configuring the inputs and the outputs 5
 - 2.2 Configuration error checking 5
 - 2.3 Setting the rated values of the protected unit 6
 - 2.4 Operation criteria..... 6
 - 2.4.1 Stabilized stage $3\Delta I >$ 6
 - 2.4.2 Saturation detection 8
 - 2.4.3 Instantaneous stage $3\Delta I >>$ 8
 - 2.5 Recommendations for current transformers 8
 - 2.6 Connection of current transformers 10
 - 2.7 Setting groups..... 12
 - 2.8 Test mode 12
 - 2.9 TRIP and CBFP outputs..... 12
 - 2.10 Resetting..... 13
- 3. Parameters and Events 14**
 - 3.1 General 14
 - 3.2 Setting values..... 15
 - 3.2.1 Actual settings..... 15
 - 3.2.2 Setting group 1 16
 - 3.2.3 Setting group 2..... 16
 - 3.2.4 Control settings 17
 - 3.3 Measurement values..... 18
 - 3.3.1 Input data 18
 - 3.3.2 Output data 19
 - 3.3.3 Recorded data..... 19
 - 3.3.4 Events 24
- 4. Technical Data 25**

1. Introduction

1.1 Features

- Three-phase current differential protection with stabilized and instantaneous stages providing winding short-circuit protection for generators
- The stabilized stage is provided with saturation detection that blocks the stage internally in case of current transformer saturation at external faults
- The differential and stabilizing currents are calculated for every phase on the basis of the fundamental frequency components of currents
- A separately adjustable instantaneous differential current stage for severe internal faults. Instantaneous stage is not affected by saturation detection.
- The MMI monitoring of the phase current and phase difference values facilitates the commissioning of differential protection and the checking of connections and CT polarities
- Delayed trip output for the circuit-breaker failure protection (CBFP) function
- High stability at external faults, also with partially saturated current transformers
- Short operate times at faults occurring in the zone to be protected (internal faults), also with partially saturated current transformers

1.2 Application

This document specifies the function of the three-phase differential protection function block Diff6G used in products based on the RED 500 Platform.

$3\Delta I >$

$3\Delta I >>$

Figure 1. Protection diagram symbol of Diff6G (For IEC symbols used in single line diagrams, refer to the manual "Technical Descriptions of Functions, Introduction", 1MRS750528-MUM)




Figure 2. Function block symbol of Diff6G

1.3

Input description

Name	Type	Description
IL1	Analogue signal (SINT)	Input for measuring phase current I_{L1}
IL2	Analogue signal (SINT)	Input for measuring phase current I_{L2}
IL3	Analogue signal (SINT)	Input for measuring phase current I_{L3}
IL1b	Analogue signal (SINT)	Input for measuring phase current I_{L1b}
IL2b	Analogue signal (SINT)	Input for measuring phase current I_{L2b}
IL3b	Analogue signal (SINT)	Input for measuring phase current I_{L3b}
BS1	Digital signal (BOOL, active high)	Blocking signal of the stabilized stage
BS2	Digital signal (BOOL, active high)	Blocking signal of the instantaneous stage
TRIGG	Digital signal (BOOL, active high)	Control signal for triggering the registers
GROUP	Digital signal (BOOL, active high)	Control input for switching between the setting groups 1 and 2. When GROUP is FALSE, group 1 is active. When GROUP is TRUE, group 2 is active.
RESET	Reset signal (BOOL, pos. edge)	Input signal for resetting the trip signal and registers of Diff6G

1.4

Output description

Name	Type	Description
TRIP	Digital signal (BOOL, active high)	Trip signal
CBFP	Digital signal (BOOL, active high)	Delayed trip signal for circuit-breaker failure protection (CBFP)
ERR	Digital signal (BOOL, active high)	Signal for indicating a configuration error

2. Description of Operation

2.1 Configuring the inputs and the outputs

Phase currents can be measured either via conventional current transformers or via Rogowski coils but no combination of these two is possible. The measuring devices and signal types for analogue channels are selected and configured in a special dialogue box of the Relay Configuration Tool included in the CAP 505 Tool Box. Digital inputs are configured in the same programming environment (the number of selectable analogue inputs, digital inputs and digital outputs depends on the hardware used).

When the analogue channels and digital inputs have been selected and configured in the dialogue box, the inputs and outputs of the function block can be configured on a graphic worksheet of the configuration tool. The phase currents I_{L1} , I_{L2} , I_{L3} , I_{L1b} , I_{L2b} and I_{L3b} are connected to the corresponding IL1, IL2, IL3, IL1b, IL2b and IL3b inputs of the function block. The currents I_{L1} - I_{L3} are assumed to be measured at the neutral end and the currents I_{L1b} - I_{L3b} at the line end of the generator (see Figure 3 below). Digital inputs are connected to the boolean inputs of the function block and in the same way, the outputs of the function block are connected to the output signals.




Figure 3. Currents at the neutral end and at the line end of the generator

2.2 Configuration error checking

When the relay is started, the function block checks the signal types and the measuring device types of the connected analogue inputs. If the signal types are not phase currents (I_{L1} , I_{L2} , I_{L3} , I_{L1b} , I_{L2b} or I_{L3b}) or if all the measuring device types are not current transformers or Rogowski coils, the ERR output is activated. Also an event E13 is sent.

The program that the function block is instantiated within should be associated with a task the interval of which is not greater than one fourth of the fundamental cycle. The ERR output of the function block will be activated if an association with a slower task is made. Also an event E13 is sent.

2.3 Setting the rated values of the protected unit

A separate scaling factor can be set for each analogue channel. The factors enable differences between the ratings of the protected unit and those of the measuring device (CTs, VTs, etc.). A setting of 1.00 means that the rated value of the protected unit is exactly the same as that of the measuring device. For more information refer to Technical Reference Manual for REM 54_.

2.4 Operation criteria

The differential protection function block includes two stages for generator differential protection.

2.4.1 Stabilized stage 3ΔI>

The operating characteristic of the stabilized stage 3ΔI> is determined by the parameters “Basic setting” and “Starting ratio” as well as by the parameters “Turn-point 1” and “Turn-point 2” for the turning points of the characteristic. The settings are the same for each phase. When the differential current exceeds the operating characteristic, the function block trips unless it internally blocks the trip function or is blocked by the external blocking signal BS1.

The phasors \bar{I}_1 and \bar{I}_2 denote the fundamental frequency components of the CT secondary currents on the input side and output side of the protected object. The amplitude of the differential current I_d is obtained as follows:

$$I_d = |\bar{I}_1 - \bar{I}_2| \quad (1)$$

In a normal situation there is no fault in the area protected by the function block. Then the currents \bar{I}_1 and \bar{I}_2 are equal and the differential current $I_d = 0$. In practise, however, the differential current slightly deviates from zero in normal situations. In generator protection the deviation is caused by CT inaccuracies.

In a stabilized differential relay the differential current required for tripping is the higher the higher the load current is. The stabilizing current I_b of the relay is obtained as follows:

$$I_b = \frac{|\bar{I}_1 + \bar{I}_2|}{2} \quad (2)$$

The operation of the relay is affected by stabilization as shown by the operating characteristic illustrated in Figure 4 below.




Figure 4. Operating characteristic for the stabilized stage of the generator differential protection function block Diff6G

The basic setting for the stabilized stage of the function block is determined according to Figure 4:

$$\text{Basic setting} = I_{d1}/I_n$$

The starting ratio is determined correspondingly:

$$\text{Starting ratio} = I_{d2}/I_{b2}$$

The first turning point “Turn-point 1” can be set at a desired point within the range 0.0...1.0. Accordingly, the second turning point “Turn-point 2” can be set within the range 1.0...3.0.

The slope of the operating characteristic for the function block varies in different parts of the range. In part 1 ($0.0 \leq I_b/I_n < \text{Turn-point 1}$), the differential current required for tripping is constant. The value of the differential current is the same as the basic setting selected for the function block. The basic setting basically allows for small inaccuracies of current transformers but it can also be used to influence the overall level of the operating characteristic.

The part 2, i.e. when $\text{Turn-point 1} \leq I_b/I_n < \text{Turn-point 2}$, is called the influence area of the setting “Starting ratio”. In this part, variations in the starting ratio affect the slope of the characteristic i.e. how big the change in the differential current required for tripping is in comparison with the change in the load current. The starting ratio allows for CT errors.

At high stabilizing currents, i.e. when $I_b/I_n \geq \text{Turn-point 2}$, the slope of the characteristic is constant (part 3). The slope is 100%, which means that the increase in the differential current is equal to the corresponding increase in the stabilizing current.

The required differential current for tripping at a certain stabilizing current level can be calculated using the following formulas:

If the stabilizing current is lower than Turn-point 1,

$$I_{d,operate} = \text{Basic Setting.}$$

If the stabilizing current is greater than Turn-point 1 but lower than Turn-point 2,

$$I_{d,operate} = \text{Basic Setting} + (I_b - \text{Turn-point 1}) \times \text{Starting ratio.}$$

For greater stabilizing current values, that is beyond Turn-point 2,

$$I_{d,operate} = \text{Basic Setting} + (\text{Turn-point 2} - \text{Turn-point 1}) \times \text{Starting ratio} + (I_b - \text{Turn-point 2}).$$

2.4.2 Saturation detection

The stabilized stage is provided with a current transformer saturation detection based on the waveforms of the currents. The saturation detection blocks Diff6G internally in case of current transformer saturation during an external fault.

2.4.3 Instantaneous stage $3\Delta I >>$

In addition to the stabilized stage, the differential function block includes an instantaneous stage which does not allow for stabilization. This stage trips when the amplitude of the fundamental frequency component of the differential current exceeds the set operate value “Inst. setting” or when the instantaneous value of the differential current exceeds $2.5 \times \text{Inst. setting}$. The factor 2.5 ($1.8 \times \sqrt{2}$) is due to the maximum asymmetric short-circuit current. The internal blocking signals of the function block do not prevent the operate signal of the instantaneous stage. When required, the operate signal of the stage can be blocked by the external control signal BS2.

2.5 Recommendations for current transformers

The more important the object to be protected, the more attention should be paid to the current transformers. Normally, it is not possible to dimension the current transformers so that they repeat currents with high DC components without saturating when the residual flux of the current transformer is high. The differential protection function block Diff6G operates reliably even though the current transformers are partially saturated. The purpose of the following current transformer recommendations is to secure the stability of the relay at high through currents and the quick and sensitive operation of the relay at faults occurring in the protected area, where the fault currents may be high.

The accuracy class recommended for current transformers to be used with the differential function block Diff6G is 5P, in which the limit of the current error at the rated primary current is 1% and the limit of the phase displacement is 60 minutes. The limit of the composite error at the rated accuracy limit primary current is 5%.

The approximate value of the accuracy limit factor F_a corresponding to the actual CT burden can be calculated on the basis of the rated accuracy limit factor F_n (ALF) at the rated burden, the rated burden S_n , the internal burden S_{in} and the actual burden S_a of the current transformer as follows:

$$F_a = F_n \times \frac{S_{in} + S_n}{S_{in} + S_a} \quad (3)$$

EXAMPLE 1

In the example the rated burden S_n of the line end CTs 5P20 is 10 VA, the secondary rated current 5A, the internal resistance $R_{in} = 0.07 \Omega$ and the accuracy limit factor F_n (ALF) corresponding to the rated burden is 20 (5P20). Thus the internal burden of the current transformer is $S_{in} = (5A)^2 \times 0.07 \Omega = 1.75 \text{ VA}$. The input impedance of the relay at a rated current of 5A is $< 20 \text{ m}\Omega$. If the measurement conductors have a resistance of 0.113Ω , the actual burden of the current transformer is $S_a = (5A)^2 \times (0.113 + 0.020) \Omega = 3.33 \text{ VA}$. Thus the accuracy limit factor F_a corresponding to the actual burden will be about 46.

The CT burden may grow considerably at the rated current of 5A. At the rated current of 1A the actual burden of the current transformer decreases, while the repeatability simultaneously improves.

At faults occurring in the protected area, the fault currents from the line end may be very high compared to the rated currents of the current transformers. Thanks to the instantaneous stage of the differential function block, it is enough that the current transformers are capable of repeating, during the first cycle, the current required for instantaneous tripping.

Thus the current transformers should be able to reproduce the asymmetric fault current without saturating within the next 10 ms after the occurrence of the fault, to secure that the operate times of the relay comply with the times stated in section "Technical Data".

The accuracy limit factors corresponding to the actual burden of the phase current transformer to be used in differential protection shall fulfill the following requirement:

$$F_a > (I_{kmax} / I_{In}) \times 3/(1-r) \quad (4)$$

where I_{kmax} is the maximum through-going fault current at which the protection is not allowed to operate and I_{In} is the nominal primary current of the CT.

The parameter r gives the maximum remanence flux density in the CT core. The value of the parameter r depends on the magnetic material used and on the construction of the CT. For example the value $r = 0.4$ means that the remanence flux density may be 40 % of the saturation flux density. The manufacturer of the CT should be contacted when an accurate value of the parameter r is needed. The value $r = 0.4$ is recommended to be used in practice. The requirement can then be rewritten as follows:

$$F_a > (I_{kmax} / I_{1n}) \times 5 \quad (5)$$

If the actual burden of the current transformer (S_a) in equation (3) cannot be reduced low enough to provide a sufficient value for F_a , there are two alternatives to deal with the situation.

- 1 A current transformer with a higher rated burden S_n can be chosen (which also means a higher rated accuracy limit F_n) or
- 2 a current transformer with a higher nominal primary current I_{1n} (but the same rated burden) can be chosen

The alternative 2. is more cost effective and therefore often better although the sensitivity of the scheme is slightly reduced.

EXAMPLE 2

If we assume the maximum through-going fault current I_{kmax} to be 6000 A and the nominal primary current of the CT is 1500 A, we get for F_a :

$$F_a = (6000 / 1500) \times 5 = 20$$

In generator protection it is important that the accuracy limit factors (F_a) of the phase current transformers at the neutral end and at the line end of the generator correspond to each other, i.e. the burdens of the current transformers on both sides are as equal as possible. Should high inrush or start currents with high DC components pass through the protected generator when it is connected to the network, special attention should be paid to the performance and the burdens of the current transformers and to the settings of the function block.

2.6

Connection of current transformers

The connections of the main current transformers are designated as Type I and Type II. In case the earthings of the current transformers are either inside or outside the area to be protected, the setting parameter "CT connection" is of Type I (Figure 5). In case the earthings of the current transformers are both inside and outside the area to be protected, the setting parameter "CT connection" is of Type II (Figure 6). The default setting is Type I.




Figure 5. Connection of current transformers of Type I




Figure 6. Connection of current transformers of Type II

2.7 Setting groups

Two different groups of setting values, group 1 and group 2, are available for the function block. Switching between the two groups can be done in the following three ways:

- 1 Locally via the control parameter “Group selection”¹⁾ of the MMI
- 2 Over the communication bus by writing the parameter V2¹⁾
- 3 By means of the input signal GROUP when allowed via the parameter “Group selection” (i.e. when V2 = 2¹⁾)

¹⁾ Group selection (V2): 0 = Group 1; 1 = Group 2; 2 = GROUP input

The control parameter “Active group” indicates the setting group valid at a given time.

2.8 Test mode

The TRIP and CBFP digital outputs of the function block can be activated with separate control parameters for each output either locally via the MMI or externally via the serial communication. When an output is activated with the test parameter, an event indicating the test is generated.

The protection functions operate normally while the outputs are tested.

2.9 TRIP and CBFP outputs

The output signal TRIP may have a non-latching or latching feature. When the latching mode has been selected, the TRIP signal remains active until the output is reset even if the operation criteria have reset. When the non-latching mode has been selected, the TRIP signal remains active until the operation criteria have reset and the time determined by the the control parameter “Trip pulse” has elapsed.

The function block provides a delayed trip signal CBFP after the TRIP signal unless the fault has disappeared during the set CBFP time delay. In circuit-breaker failure protection the CBFP output can be used to operate a circuit breaker in front of the circuit breaker of the machine. The control parameter “Trip pulse” also sets the width of the CBFP output signal.

2.10

Resetting

The TRIP output signal and the registers can be reset via the RESET input, or over the serial bus or the local MMI.

The operation indicators, latched trip signal and recorded data can be reset as follows:

	Operation indicators	Latched trip signal	Recorded data
RESET input of the function block ¹⁾		X	X
Parameter F099V013 ¹⁾		X	X
General parameter F001V011 ²⁾	X		
General parameter F001V012 ²⁾	X	X	
General parameter F001V013 ²⁾	X	X	X
Push-button C ²⁾	X		
Push-buttons C + E (2 s) ²⁾	X	X	
Push-buttons C + E (5 s) ²⁾	X	X	X

1) Resets the latched trip signal and recorded data of this particular function block.

2) Affects all function blocks.

3. Parameters and Events

3.1 General

- Each function block has a specific channel number for serial communication parameters and events. The channel for Diff6G is 99.
- The data direction of the parameters defines the use of each parameter as follows:

Data direction	Description
R, R/M	Read only
W	Write only
R/W	Read and write

- The different event mask parameters (see section “Control settings”) affect the visibility of events on the MMI or on serial communication (LON or SPA) as follows:

Event mask 1 (FxxxV101/102)	SPA / MMI (LON)
Event mask 2 (FxxxV103/104)	LON
Event mask 3 (FxxxV105/106)	LON
Event mask 4 (FxxxV107/108)	LON

For example, if only the events E3, E4 and E5 are to be seen on the MMI of the relay terminal, the event mask value 56 (8 + 16 + 32) is written to the “Event mask 1” parameter (FxxxV101).

In case a function block includes more than 32 events, there are two parameters instead of e.g. the “Event mask 1” parameter: the parameter “Event mask 1A” (FxxxV101) covers the events 0...31 and “Event mask 1B”(FxxxV102) the events 32...63.

3.2 Setting values

3.2.1 Actual settings

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Basic setting	S1	5...50	%	5	R	The lowest ratio of differential and nominal current to cause a trip
Starting ratio	S2	10...50	%	10	R	Slope of the second line of the operating characteristics
Turn-point 1	S3	0.0...1.0	x In	0.5	R	Turn-point between the first and the second line of the operating characteristics
Turn-point 2	S4	1.0...3.0	x In	1.5	R	Turn-point between the second and the third line of the operating characteristics
Inst. setting	S5	5...30	x In	5	R	Tripping value of the instantaneous stage

3.2.2

Setting group 1

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Basic setting	S41	5...50	%	5	R/W	The lowest ratio of differential and nominal current to cause a trip
Starting ratio	S42	10...50	%	10	R/W	Slope of the second line of the operating characteristics
Turn-point 1	S43	0.0...1.0	x In	0.5	R/W	Turn-point between the first and the second line of the operating characteristics
Turn-point 2	S44	1.0...3.0	x In	1.5	R/W	Turn-point between the second and the third line of the operating characteristics
Inst. setting	S45	5...30	x In	5	R/W	Tripping value of the instantaneous stage

3.2.3

Setting group 2

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Basic setting	S71	5...50	%	5	R/W	The lowest ratio of differential and nominal current to cause a trip
Starting ratio	S72	10...50	%	10	R/W	Slope of the second line of the operating characteristics
Turn-point 1	S73	0.0...1.0	x In	0.5	R/W	Turn-point between the first and the second line of the operating characteristics
Turn-point 2	S74	1.0...3.0	x In	1.5	R/W	Turn-point between the second and the third line of the operating characteristics
Inst. setting	S75	5...30	x In	5	R/W	Tripping value of the instantaneous stage

3.2.4

Control settings

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Diff6G	V1	0 or 1 ¹⁾	-	1	R/W	Protection block in use or not in use
Group selection	V2	0...2 ²⁾	-	0	R/W	Selection of the active setting group
Active group	V3	0 or 1 ³⁾	-	0	R/M	Active setting group
Trip signal	V4	0 or 1 ⁴⁾	-	0	R/W	Selection of latching feature for TRIP output
Trip pulse	V5	40...1000	ms	40	R/W	Minimum pulse width of TRIP and CBFP
CBFP time	V6	100...1000	ms	100	R/W	Operate time of the delayed trip CBFP
CT connection	V7	0 or 1 ⁵⁾	-	0	R/W	Determined by the directions of the connected currents transformers
Reset registers	V13	1=Reset	-	0	W	Resetting of latched trip signal and registers
Test TRIP	V32	0 or 1 ⁶⁾	-	-	R/W	Testing of TRIP
Test CBFP	V33	0 or 1 ⁶⁾	-	-	R/W	Testing of CBFP
Event mask 1	V101	0...16383	-	8255	R/W	Event mask 1 for event transmission (E0 ... E13)
Event mask 2	V103	0...16383	-	8255	R/W	Event mask 2 for event transmission (E0 ... E13)
Event mask 3	V105	0...16383	-	8255	R/W	Event mask 3 for event transmission (E0 ... E13)
Event mask 4	V107	0...16383	-	8255	R/W	Event mask 4 for event transmission (E0 ... E13)

- ¹⁾ Status
²⁾ Group selection
³⁾ Active group
⁴⁾ Trip signal
⁵⁾ CT connection
⁶⁾ Test
- 0 = Not in use; 1 = In use
0 = Group 1; 1 = Group 2; 2 = GROUP input
0 = Group 1; 1 = Group 2
0 = Non-latching; 1 = Latching
0 = Type I; 1 = Type II
0 = Do not activate; 1 = Activate

3.3

Measurement values

3.3.1

Input data

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Current IL1	I1	0.00...60.00	x In	0.00	R/M	Phase current IL1
Current IL2	I2	0.00...60.00	x In	0.00	R/M	Phase current IL2
Current IL3	I3	0.00...60.00	x In	0.00	R/M	Phase current IL3
Current IL1b	I4	0.00...60.00	x In	0.00	R/M	Phase current IL1b
Current IL2b	I5	0.00...60.00	x In	0.00	R/M	Phase current IL2b
Current IL3b	I6	0.00...60.00	x In	0.00	R/M	Phase current IL3b
Current Id1	I7	0.00...60.00	x In	0.00	R/M	Differential current of phase 1
Current Id2	I8	0.00...60.00	x In	0.00	R/M	Differential current of phase 2
Current Id3	I9	0.00...60.00	x In	0.00	R/M	Differential current of phase 3
Current Ib1	I10	0.00...60.00	x In	0.00	R/M	Bias current of phase 1
Current Ib2	I11	0.00...60.00	x In	0.00	R/M	Bias current of phase 2
Current Ib3	I12	0.00...60.00	x In	0.00	R/M	Bias current of phase 3
Angle IL1-IL2	I13	-180...180	°	0	R/M	Phase difference of the currents L1 and L2
Angle IL2-IL3	I14	-180...180	°	0	R/M	Phase diff. of the currents L2 & L3
Angle IL3-IL1	I15	-180...180	°	0	R/M	Phase diff. of the currents L3 & L1
Angle IL1b-IL2b	I16	-180...180	°	0	R/M	Phase diff. of the currents L1b & L2b
Angle IL2b-IL3b	I17	-180...180	°	0	R/M	Phase diff. of the currents L2b & L3b
Angle IL3b-IL1b	I18	-180...180	°	0	R/M	Phase diff. of the currents L3b & L1b
Angle IL1-IL1b	I19	-180...180	°	0	R/M	Phase diff. of the currents L1 & L1b
Angle IL2-IL2b	I20	-180...180	°	0	R/M	Phase diff. of the currents L2 & L2b
Angle IL3-IL3b	I21	-180...180	°	0	R/M	Phase diff. of the currents L3 & L3b
Input BS1	I22	0 or 1 ¹⁾		0	R/M	Status of BS1 signal
Input BS2	I23	0 or 1 ¹⁾	-	0	R/M	Status of BS2 signal
Input GROUP	I24	0 or 1 ¹⁾	-	0	R/M	Status of signal for switching between the groups 1 and 2
Input RESET	I25	0 or 1 ¹⁾	-	0	R/M	Status of signal for resetting the output signals of Diff6G

¹⁾ Input 0 = Not active; 1 = Active

3.3.2 Output data

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Output TRIP	O1	0 or 1 ¹⁾	-	0	R/M	Status of trip signal
Output ERR	O2	0 or 1 ¹⁾	-	0	R/M	Status of configuration error signal

¹⁾ Output 0 = Not active; 1 = Active

3.3.3 Recorded data

3.3.3.1 General

The information required for later fault analysis is recorded when the function block trips or when the recording function is triggered via an external triggering input.

The data of three last operations (operation 1...3) are recorded, and the values of the most recent operation always replace the data of the oldest operation. The registers are updated in the following order: Operation 1, Operation 2, Operation 3, Operation 1, Operation 2,...

3.3.3.2 Date and time

The time stamp indicates the rising edge of the TRIGG signal or the moment of the highest fault current during the period of 50 ms after the rising edge of the TRIP signal.

3.3.3.3 Currents and phase differences

If the function block trips, all the recorded current and phase difference values will originate from the same moment determined by the highest differential current. For external triggering, the current values are recorded at the moment of triggering i.e. on the rising edge of the input signal TRIGG. Consequently, the values of the phase currents I_{L1} , I_{L2} , I_{L3} , I_{L1b} , I_{L2b} , I_{L3b} , the values of the differential currents I_{d1} , I_{d2} , I_{d3} , the values of the stabilizing currents I_{b1} , I_{b2} , I_{b3} and the phase difference values always originate from the same moment. The current values are recorded as multiples of the rated current I_n and the phase difference values are recorded in degrees.

3.3.3.4 Status data

The status data of the input signals BS1 and BS2 (Active or Not active) as well as the parameters “Active group” and “Reg. reason” are recorded at the moment of tripping and triggering. The “Active group” parameter indicates the setting group valid for the recorded data and the “Reg. Reason” parameter the reason for the particular registration (i.e. trip of the stabilized stage, trip of the instantaneous stage or activation of the TRIGG input).

3.3.3.5

Recorded data 1

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Date	V201	YYYY-MM-DD	-	-	R/M	Recording date
Time	V202	hh:mm:ss.mss	-	-	R/M	Recording time
Current IL1	V203	0.00...60.00	x In	0.00	R/M	Phase current IL1
Current IL2	V204	0.00...60.00	x In	0.00	R/M	Phase current IL2
Current IL3	V205	0.00...60.00	x In	0.00	R/M	Phase current IL3
Current IL1b	V206	0.00...60.00	x In	0.00	R/M	Phase current IL1b
Current IL2b	V207	0.00...60.00	x In	0.00	R/M	Phase current IL2b
Current IL3b	V208	0.00...60.00	x In	0.00	R/M	Phase current IL3b
Current Id1	V209	0.00...60.00	x In	0.00	R/M	Differential current of phase 1
Current Id2	V210	0.00...60.00	x In	0.00	R/M	Differential current of phase 2
Current Id3	V211	0.00...60.00	x In	0.00	R/M	Differential current of phase 3
Current Ib1	V212	0.00...60.00	x In	0.00	R/M	Bias current of phase 1
Current Ib2	V213	0.00...60.00	x In	0.00	R/M	Bias current of phase 2
Current Ib3	V214	0.00...60.00	x In	0.00	R/M	Bias current of phase 3
Angle IL1-IL2	V215	-180...180	°	0	R/M	Phase difference of the currents L1 and L2
Angle IL2-IL3	V216	-180...180	°	0	R/M	Phase difference of the currents L2 and L3
Angle IL3-IL1	V217	-180...180	°	0	R/M	Phase difference of the currents L3 and L1
Angle IL1b-IL2b	V218	-180...180	°	0	R/M	Phase difference of the currents L1b and L2b
Angle IL2b-IL3b	V219	-180...180	°	0	R/M	Phase difference of the currents L2b and L3b
Angle IL3b-IL1b	V220	-180...180	°	0	R/M	Phase difference of the currents L3b and L1b
Angle IL1-IL1b	V221	-180...180	°	0	R/M	Phase difference of the currents L1 and L1b
Angle IL2-IL2b	V222	-180...180	°	0	R/M	Phase difference of the currents L2 and L2b
Angle IL3-IL3b	V223	-180...180	°	0	R/M	Phase difference of the currents L3 and L3b
BS1	V224	0 or 1 ¹⁾	-	0	R/M	Status of BS1 input
BS2	V225	0 or 1 ¹⁾	-	0	R/M	Status of BS2 input
Active group	V226	0 or 1 ²⁾	-	0	R/M	Active setting group
Reg. reason	V227	0...2 ³⁾	-	0	R/M	Reason for registration

¹⁾ Status 0 = Not active; 1 = Active

²⁾ Active group 0 = Group 1; 1 = Group 2

³⁾ Reg reason 0 = TRIP >; 1 = TRIP >>; 2 = TRIGG

3.3.3.6

Recorded data 2

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Date	V301	YYYY-MM-DD	-	-	R/M	Recording date
Time	V302	hh:mm:ss.mss	-	-	R/M	Recording time
Current IL1	V303	0.00...60.00	x In	0.00	R/M	Phase current IL1
Current IL2	V304	0.00...60.00	x In	0.00	R/M	Phase current IL2
Current IL3	V305	0.00...60.00	x In	0.00	R/M	Phase current IL3
Current IL1b	V306	0.00...60.00	x In	0.00	R/M	Phase current IL1b
Current IL2b	V307	0.00...60.00	x In	0.00	R/M	Phase current IL2b
Current IL3b	V308	0.00...60.00	x In	0.00	R/M	Phase current IL3b
Current Id1	V309	0.00...60.00	x In	0.00	R/M	Differential current of phase 1
Current Id2	V310	0.00...60.00	x In	0.00	R/M	Differential current of phase 2
Current Id3	V311	0.00...60.00	x In	0.00	R/M	Differential current of phase 3
Current Ib1	V312	0.00...60.00	x In	0.00	R/M	Bias current of phase 1
Current Ib2	V313	0.00...60.00	x In	0.00	R/M	Bias current of phase 2
Current Ib3	V314	0.00...60.00	x In	0.00	R/M	Bias current of phase 3
Angle IL1-IL2	V315	-180...180	°	0	R/M	Phase difference of the currents L1 and L2
Angle IL2-IL3	V316	-180...180	°	0	R/M	Phase difference of the currents L2 and L3
Angle IL3-IL1	V317	-180...180	°	0	R/M	Phase difference of the currents L3 and L1
Angle IL1b-IL2b	V318	-180...180	°	0	R/M	Phase difference of the currents L1b and L2b
Angle IL2b-IL3b	V319	-180...180	°	0	R/M	Phase difference of the currents L2b and L3b
Angle IL3b-IL1b	V320	-180...180	°	0	R/M	Phase difference of the currents L3b and L1b
Angle IL1-IL1b	V321	-180...180	°	0	R/M	Phase difference of the currents L1 and L1b
Angle IL2-IL2b	V322	-180...180	°	0	R/M	Phase difference of the currents L2 and L2b
Angle IL3-IL3b	V323	-180...180	°	0	R/M	Phase difference of the currents L3 and L3b
BS1	V324	0 or 1 ¹⁾	-	0	R/M	Status of BS1 input
BS2	V325	0 or 1 ¹⁾	-	0	R/M	Status of BS2 input
Active group	V326	0 or 1 ²⁾	-	0	R/M	Active setting group
Reg. reason	V327	0...2 ³⁾	-	0	R/M	Reason for registration

¹⁾ Status 0 = Not active; 1 = Active

²⁾ Active group 0 = Group 1; 1 = Group 2

³⁾ Reg. reason 0 = TRIP >; 1 = TRIP >>; 2 = TRIGG

3.3.4

Events

Code	Weighting coefficient	Default mask	Event reason	Event state
E0	1	1	TRIP signal of 3d l> stage	Reset
E1	2	1	TRIP signal of 3d l> stage	Activated
E2	4	1	TRIP signal of 3d l>> stage	Reset
E3	8	1	TRIP signal of 3d l>> stage	Activated
E4	16	1	CBFB signal 3d l> or 3d l>>	Reset
E5	32	1	CBFB signal 3d l> or 3d l>>	Activated
E6	64	0	BLOCK signal of 3d l> stage	Reset
E7	128	0	BLOCK signal of 3d l> stage	Activated
E8	256	0	BLOCK signal of 3d l>> stage	Reset
E9	512	0	BLOCK signal of 3d l>> stage	Activated
E10	1024	0	Test mode of 3d l> and 3d l>>	Off
E11	2048	0	Test mode of 3d l> and 3d l>>	On
E12	0	0	-	-
E13	8192	1	ERR: task / measuring device / signal type	Activated

