

**Contents**

<b>1. Introduction .....</b>	<b>2</b>
1.1 Features.....	2
1.2 Application .....	2
1.3 Input description .....	3
1.4 Output description.....	3
<b>2. Description of Operation .....</b>	<b>4</b>
2.1 Configuration .....	4
2.2 Configuration error checking.....	5
2.3 Measuring mode .....	5
2.4 Operation criteria .....	6
2.4.1 Definite-time operation .....	6
2.4.2 Inverse-time operation.....	8
2.5 Setting groups.....	10
2.6 Test mode.....	10
2.7 START, TRIP and CBFP outputs.....	10
2.8 Resetting.....	11
<b>3. Parameters and Events.....</b>	<b>12</b>
3.1 General .....	12
3.2 Setting values .....	13
3.2.1 Actual settings .....	13
3.2.2 Setting group 1 .....	13
3.2.3 Setting group 2 .....	14
3.2.4 Control settings.....	15
3.3 Measurement values.....	16
3.3.1 Input data.....	16
3.3.2 Output data.....	16
3.3.3 Recorded data .....	17
3.3.4 Events.....	19
<b>4. Technical Data .....</b>	<b>20</b>

# 1. Introduction

## 1.1 Features

- Negative-phase-sequence protection
- Definite-time (DT) or inverse-time (IDMT) operation
- Definite minimum time for high-level negative-sequence currents in inverse-time operation
- Limited maximum operate time for long-time low-level negative-sequence currents in inverse-time operation
- Adjustable start delay in inverse-time operation
- Backwards counting when overload disappears in inverse-time mode
- Current measurement with conventional current transformers or Rogowski coils
- Two- or three-phase negative-sequence current measurement
- Input signal for selecting the direction of rotation
- Delayed trip output for the circuit-breaker failure protection (CBFP) function
- Output for blocking the reconnection of an overheated machine
- Wide setting ranges

## 1.2 Application

This document specifies the functions of the negative-phase-sequence function blocks NPS3Low and NPS3High used in products based on the RED 500 Platform. The low-set stage and the high-set stage are identical in operation.

The function blocks NPS3Low and NPS3High are designed for negative-phase-sequence protection whenever the operating characteristic is appropriate. They are applied for the protection of power generators or synchronous motors against thermal stress and damage.

(See Figure 5).

I2>

I2>>

*Figure 1. Protection diagram symbols of NPS3Low and NPS3High (For IEC symbols used in single line diagrams, refer to the manual “Technical Descriptions of Functions, Introduction”, IMRS750528-MUM)*




Figure 2. Function block symbols of NPS3Low and NPS3High

### 1.3 Input description

Name	Type	Description
IL1	Analogue signal (SINT)	Input for measuring phase current $I_{L1}$
IL2	Analogue signal (SINT)	Input for measuring phase current $I_{L2}$
IL3	Analogue signal (SINT)	Input for measuring phase current $I_{L3}$
ROT_DIR	Digital signal (BOOL, active high)	Input signal for selecting rotation direction of the machine
GROUP	Digital signal (BOOL, active high)	Control input for switching between the setting groups 1 and 2
BLOCK	Digital signal (BOOL, active high)	Input for blocking the function
RESET	Reset signal (BOOL, pos. edge)	Input signal for resetting the trip signal and registers of NPS3Low or NPS3High

### 1.4 Output description

Name	Type	Description
START	Digital signal (BOOL, active high)	Start signal
TRIP	Digital signal (BOOL, active high)	Trip signal
CBFP	Digital signal (BOOL, active high)	Delayed trip signal for circuit-breaker failure protection (CBFP)
BLOCK_OUT	Digital signal (BOOL, active high)	Signal for blocking the reconnection of an overheated machine
ERR	Digital signal (BOOL, active high)	Signal for indicating a configuration error

## 2. Description of Operation

### 2.1 Configuration

Phase currents can be measured via conventional current transformers or Rogowski coils. The measuring devices and signal types for the analogue channels are selected and configured in a special dialogue box of the Relay Configuration Tool included in the CAP 505 Tool Box. Digital inputs are configured in the same programming environment (the number of selectable analogue inputs, digital inputs and digital outputs depends on the hardware used).

When the analogue channels and digital inputs have been selected and configured in the dialogue box, the inputs and outputs of the function block can be configured on a graphic worksheet of the configuration tool.

In case of three phase currents (Figure 3), the phase currents  $I_{L1}$ ,  $I_{L2}$  and  $I_{L3}$  are connected to the corresponding IL1, IL2 and IL3 inputs of the function block, whereas in case of two phase currents (Figure 4), the phase currents are connected to the first two phase current inputs and the third analogue input is left unconnected.

Digital inputs are connected to the boolean inputs of the function block and in the same way, the outputs of the function block are connected to the output signals.




Figure 3. Configuration example in case of three phase currents




Figure 4. Analogue channel connections in case of two phase currents

In the input data and recorded data fields, the monitored phase currents are those actually connected to the corresponding inputs. For example, if the analogue channel IL3 is connected to the input IL1, the value of the “Current IL1” parameter is actually the value of phase current IL3.

The ROT\_DIR input is used for motor protection. If status information about the motor rotation direction is available, it can be connected to the ROT\_DIR input of the function block. In this case the control setting parameter “Dir. selection” must be set to value “Input rot.dir.”, which means the measured negative-sequence current and the operation of the function block are independent of the motor rotation direction.

## 2.2 Configuration error checking

When the relay is started, the function block checks that at least two phase currents are connected to the first two analogue inputs. If two currents are not connected, the ERR output is activated and the error event E13 is sent.

If the phase currents are connected in a different order compared to the configuration examples, the error event is not sent and the ERR output is not activated. In these cases, however, the control setting parameter “Dir. selection” must be set to “Reverse” value to achieve correct operation.

## 2.3 Measuring mode

Negative phase-sequence current can be calculated from two- or three-phase currents. The number of phase currents is set via the control setting parameter “Num. of phases”. If only two phase currents are connected, the value of “Num. of phases” parameter is always two and cannot be changed. The negative-sequence current calculation is based on fundamental-frequency phase currents.

When three-phase currents are used, the negative-sequence current is calculated as follows:

$$I_2 = \frac{1}{3} |I_R + I_S \angle 240^\circ + I_T \angle 120^\circ|$$

where  $I_R$ ,  $I_S$  and  $I_T$  are phase currents.

In case of two-phase currents, the value of the neutral current is assumed to be 0, that is,  $I_R + I_S + I_T = 0$ . Thus, the negative-sequence current is calculated as follows:

$$I_2 = \frac{\sqrt{3}}{3} |I_R + I_T \angle 60^\circ|$$

where  $I_R$  and  $I_T$  are phase currents.

## 2.4 Operation criteria

The function block has the two operation modes “Definite time” and “Inverse time”. The type of operation is selected via the setting parameter “Operation mode”.

In both operation modes the function block starts if the calculated negative phase-sequence exceeds the set start current, which is set via the “Start value” parameter. The parameter is common to the two operation modes.

Note! The default value of the “Start value” parameter is 20% of nominal, which is usual for motor protection. Generators are more sensitive to current unbalance and the negative sequence current value that a generator can stand continuously is usually between 5% and 10%. Therefore in case of generator protection a safer value for the “Start value” parameter is 5%.

### 2.4.1 Definite-time operation

The function block trips when the measured negative phase-sequence has remained over the set limit for the time set via the “Operate time” parameter. The “Operate time” parameter is used only in the definite-time operation.

When the function block trips, the BLOCK\_OUT output is activated and will remain active for the set time. The cooling time is set via the “Cooling time” parameter. The same parameter is also used in the inverse-time operation. The BLOCK\_OUT signal is used to prevent the auto-reclosing of an overheated generator.




Figure 5. Use of the “Cooling time” parameter

For intermittent faults, the definite-time operation includes the delayed reset function. Without the delayed reset function the DT timer would reset once the negative-sequence current drops off.

When the DT timer has started, it goes on running normally even if the current drops off, provided the drop-off period is shorter than the set drop-off time. If the drop-off period is longer than the set drop-off time, the DT timer will reset when the drop-off time elapses (Figure 6).

In Figures 6 and 7 the input signal IN of the DT timer is TRUE when the current is above the set start value and FALSE when the current is below the set start value.




Figure 6. The drop-off period is longer than the set drop-off time

If the drop-off period is shorter than the set drop-off time and the DT timer time has elapsed during the drop-off period, the function block will trip once the current exceeds the set value again (Figure 7).




Figure 7. The drop-off period is shorter than the set drop-off time

## 2.4.2 Inverse-time operation

The operate time of the function block in the inverse-time mode is expressed mathematically as follows :

$$t = \frac{K}{\left(\frac{I_2}{I_N}\right)^2 - StartValue^2}$$

where

t	relay operate time in seconds
$I_2$	negative-sequence current
$I_N$	rated current of the machine
Start value	Setting parameter that corresponds to the continuous negative-sequence current withstand of the machine, the $I_2$ current expressed in $xI_N$ (rated current of the machine)
K	Setting parameter that corresponds to the machine constant, equal to the $I_2^2 t$ constant of the machine, as stated by the machine manufacturer




Figure 8. The time/negative sequence current characteristics of NPS3Low and NPS3High

When the measured negative-sequence current exceeds the set start current  $I_2$ , the function block starts accumulating a sum, the accumulate rate being proportional to the subtraction of the squared value of the actual negative-sequence current and the

squared value of the “Start value” parameter. When the sum exceeds the level corresponding to the setting parameter K, the function block operates. The higher the degree of current unbalance, the faster the sum increases, and as the operate level of the sum is defined only by the constant K, the negative-sequence relay will have an inverse-time operating characteristic which conforms to the thermal load characteristic of a rotating machine. When the overload disappears, the subtraction ( $I_2^2 - \text{StartValue}^2$ ) becomes negative and the sum decreases. Thus, decrease of the sum indicates cooling of the machine, and the cooling speed depends on the value of the  $I_2$  current. When the sum reaches 0, the accumulation is stopped.

The accumulation is also stopped and the sum is set to 0 if the negative-sequence current remains below the set limit for the set cooling time. Another purpose of the “Cooling time” parameter is to keep the BLOCK\_OUT signal active after tripping for the set time. The BLOCK\_OUT signal is used to prevent the auto-reclosing of the overheated generator.

In inverse-time operation, the delay of the START output can be set via the parameter “Start delay”. The start delay can be used for definite-time alarming when the START output is used as an alarm output. The set start delay does not affect the operate time of the function block.

The maximum operate time is limited for long-time low-level negative-sequence currents. The maximum operate time can be set via the “Maximum time” parameter and the minimum operate time via the “Minimum time” parameter. The meaning of the minimum and maximum time settings is illustrated in the figure below.




Figure 9. Operating characteristic

The setting parameters “K”, “Start delay”, “Minimum time” and “Maximum time” do not affect the definite-time mode.

## 2.5 Setting groups

Two different groups of setting values, group 1 and group 2, are available for each function block. Switching between the two groups can be done in the following three ways:

- 1 Locally via the control parameter “Group selection”<sup>1)</sup> of the MMI
- 2 Over the communication bus by writing the parameter V2<sup>1)</sup>
- 3 By means of the input signal GROUP when allowed via the parameter “Group selection” (i.e. when V2 = 2<sup>1)</sup>)

<sup>1)</sup> Group selection (V2): 0 = Group 1; 1 = Group 2; 2 = GROUP input

The control parameter “Active group” indicates the setting group valid at a given time.

## 2.6 Test mode

The digital outputs of the function block can be activated with separate control parameters for each output either locally via the MMI or externally via the serial communication. When an output is activated with the test parameter, an event indicating the test is generated.

The protection functions operate normally while the outputs are tested.

## 2.7 START, TRIP and CBFP outputs

The output signal START is always pulse-shaped. The minimum pulse width of the corresponding output signal is set via a separate parameter on the MMI or on serial communication. If the start situation is longer than the set pulse width, the START signal remains active until the start situation is over.

The output signal TRIP may have a non-latching or latching feature. When the latching mode has been selected, the TRIP signal remains active until the output is reset even if the operation criteria have reset.

Each function block provides a delayed trip signal CBFP after the TRIP signal unless the fault has disappeared during the set CBFP time delay. In circuit-breaker failure protection, the CBFP output can be used to operate a circuit breaker in front of the circuit breaker of the machine. The control parameter “Trip pulse” also sets the width of the CBFP output signal.

## 2.8

**Resetting**

The TRIP output signal and the registers can be reset either via the RESET input, or over the serial bus or the local MMI.

The operation indicators, latched trip signal and recorded data can be reset as follows:

	<b>Operation indicators</b>	<b>Latched trip signal</b>	<b>Recorded data</b>
RESET input of the function block <sup>1)</sup>		X	X
Parameter F077V013 for NPS3Low <sup>1)</sup>		X	X
Parameter F078V013 for NPS3High <sup>1)</sup>		X	X
General parameter F001V011 <sup>2)</sup>	X		
General parameter F001V012 <sup>2)</sup>	X	X	
General parameter F001V013 <sup>2)</sup>	X	X	X
Push-button C <sup>2)</sup>	X		
Push-buttons C + E (2 s) <sup>2)</sup>	X	X	
Push-buttons C + E (5 s) <sup>2)</sup>	X	X	X

<sup>1)</sup> Resets the latched trip signal and recorded data of this particular function block.

<sup>2)</sup> Affects all function blocks.

## 3. Parameters and Events

### 3.1 General

- Each function block has a specific channel number for serial communication parameters and events. The channel for NPS3Low is 77 and that for NPS3High 78.
- The data direction of the parameters defines the use of each parameter as follows:

Data direction	Description
R, R/M	Read only
W	Write only
R/W	Read and write

- The different event mask parameters (see section “Control settings”) affect the visibility of events on the MMI or on serial communication (LON or SPA) as follows:

Event mask 1 (FxxxV101/102)	SPA / MMI (LON)
Event mask 2 (FxxxV103/104)	LON
Event mask 3 (FxxxV105/106)	LON
Event mask 4 (FxxxV107/108)	LON

For example, if only the events E3, E4 and E5 are to be seen on the MMI of the relay terminal, the event mask value 56 (8 + 16 + 32) is written to the “Event mask 1” parameter (FxxxV101).

In case a function block includes more than 32 events, there are two parameters instead of e.g. the “Event mask 1” parameter: the parameter “Event mask 1A” (FxxxV101) covers the events 0...31 and “Event mask 1B”(FxxxV102) the events 32...63.

## 3.2 Setting values

### 3.2.1 Actual settings

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Operation mode	S1	0...2 <sup>1)</sup>	-	1	R/M	Selection of operation mode (definite- or inverse-time mode)
Start value	S2	0.01...0.50	x I <sub>n</sub>	0.20	R/M	Start value of negative-sequence current I <sub>2</sub>
Operate time	S3	0.1...120.0	s	1.0	R/M	Operate time in definite-time mode
K	S4	5.0...100.0	-	5.0	R/M	Operating characteristic constant
Start delay	S5	0.1...60.0	s	1.0	R/M	Definite start time in inverse-time mode
Minimum time	S6	0.1...120.0	s	0.1	R/M	Definite minimum operate time
Maximum time	S7	500...10000	s	1000	R/M	Maximum operate time regardless of the inverse characteristic
Cooling time	S8	5...10000	s	50	R/M	Time required to cool the machine

<sup>1)</sup>Operation mode 0 = Not in use; 1 = Definite time; 2 = Inverse time

### 3.2.2 Setting group 1

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Operation mode	S41	0...2 <sup>1)</sup>	-	1	R/W	Selection of operation mode (definite- or inverse-time mode)
Start value	S42	0.01...0.50	x I <sub>n</sub>	0.20	R/W	Start value of negative-sequence current I <sub>2</sub>
Operate time	S43	0.1...120.0	s	1.0	R/W	Operate time in definite-time mode
K	S44	5.0...100.0	-	5.0	R/W	Operating characteristic constant
Start delay	S45	0.1...60.0	s	1.0	R/W	Definite start time in inverse-time mode
Minimum time	S46	0.1...120.0	s	0.1	R/W	Definite minimum operate time
Maximum time	S47	500...10000	s	1000	R/W	Maximum operate time regardless of the inverse characteristic
Cooling time	S48	5...10000	s	50	R/W	Time required to cool the machine

<sup>1)</sup>Operation mode 0 = Not in use; 1 = Definite time; 2 = Inverse time

## 3.2.3

## Setting group 2

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Operation mode	S71	0...2 <sup>1)</sup>	-	1	R/W	Selection of operation mode (definite- or inverse-time mode)
Start value	S72	0.01...0.50	$x I_n$	0.20	R/W	Start value of negative-sequence current $I_2$
Operate time	S73	0.1...120.0	s	1.0	R/W	Operate time in definite-time mode
K	S74	5.0...100.0	-	5.0	R/W	Operating characteristic constant
Start delay	S75	0.1...60.0	s	1.0	R/W	Definite start time in inverse-time mode
Minimum time	S76	0.1...120.0	s	0.1	R/W	Definite minimum operate time
Maximum time	S77	500...10000	s	1000	R/W	Maximum operate time regardless of the inverse characteristic
Cooling time	S78	5...10000	s	50	R/W	Time required to cool the machine

<sup>1)</sup> Operation mode      0 = Not in use; 1 = Definite time; 2 = Inverse time

## 3.2.4

## Control settings

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Num. of phases	V1	2...3	-	3	R/W	Selection of two-phase or three-phase measurement
Group selection	V2	0...2 <sup>1)</sup>	-	0	R/W	Selection of the active setting group
Active group	V3	0 or 1 <sup>2)</sup>	-	0	R/M	Active setting group
Dir. selection	V4	0...2 <sup>3)</sup>	-	0	R/W	Selection of rotation direction
Rotation dir.	V5	0 or 1 <sup>4)</sup>	-	0	R/M	Rotation direction
Drop-off time	V6	0...1000	ms	0	R/W	Resetting time of the operate time counter in DT mode
Start pulse	V7	0...1000	ms	0	R/W	Minimum pulse width of START signal
Trip signal	V8	0 or 1 <sup>5)</sup>	-	0	R/W	Selection of latching feature for TRIP output
Trip pulse	V9	40...1000	ms	40	R/W	Minimum pulse width of TRIP and CBFP
CBFP time	V10	100...1000	ms	100	R/W	Operate time of the delayed trip CBFP
Reset registers	V13	1=Reset	-	0	W	Resetting of latched trip signal and registers
Test START	V31	0 or 1 <sup>6)</sup>	-	0	R/W	Testing of START
Test TRIP	V32	0 or 1 <sup>6)</sup>	-	0	R/W	Testing of TRIP
Test CBFP	V33	0 or 1 <sup>6)</sup>	-	0	R/W	Testing of CBFP
Event mask 1	V101	0...4095	-	63	R/W	Event mask 1 for event transmission (E0... E11)
Event mask 2	V103	0... 4095	-	63	R/W	Event mask 2 for event transmission (E0... E11)
Event mask 3	V105	0... 4095	-	63	R/W	Event mask 3 for event transmission (E0... E11)
Event mask 4	V107	0... 4095	-	63	R/W	Event mask 4 for event transmission (E0... E11)

<sup>1)</sup> Group selection      0 = Group 1; 1 = Group 2; 2 = GROUP input

<sup>2)</sup> Active group        0 = Group 1; 1 = Group 2

<sup>3)</sup> Dir. selection      0 = Forward; 1 = Reverse; 2 = Input rot.dir.

<sup>4)</sup> Rotation dir.        0 = Forward; 1 = Reverse

<sup>5)</sup> Trip signal          0 = Non-latching; 1 = Latching

<sup>6)</sup> Test                    0 = Do not activate; 1 = Activate

### 3.3 Measurement values

#### 3.3.1 Input data

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Neg. seq. cur.	I1	0.00...60.00	x In	0.00	R/M	Negative-sequence current I2
Current IL1	I2	0.00...60.00	x In	0.00	R/M	Phase current IL1
Current IL2	I3	0.00...60.00	x In	0.00	R/M	Phase current IL2
Current IL3	I4	0.00...60.00	x In	0.00	R/M	Phase current IL3
Input Rot. dir.	I5	0 or 1 <sup>1)</sup>	-	0	R/M	Input signal for selecting rotation direction for the generator
Input BLOCK	I6	0 or 1 <sup>2)</sup>	-	0	R/M	Input signal for blocking the function block
Input GROUP	I7	0 or 1 <sup>2)</sup>	-	0	R/M	Signal for switching between groups 1 and 2
Input RESET	I8	0 or 1 <sup>2)</sup>	-	0	R/M	Signal for resetting the output signals and registers of NPS3Low or NPS3High

<sup>1)</sup> Rot. dir. 0 = forward; 1 = reverse

<sup>2)</sup> Input 0 = Not active; 1 = Active

#### 3.3.2 Output data

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Output START	O1	0 or 1 <sup>1)</sup>	-	0	R/M	Status of start signal
Output TRIP	O2	0 or 1 <sup>1)</sup>	-	0	R/M	Status of trip signal
Output BLOCK	O3	0 or 1 <sup>1)</sup>	-	0	R/M	Status of BLOCK_OUT signal (signal for keeping the machine separated from the power system)
Output CBFP	O4	0 or 1 <sup>1)</sup>	-	0	R/M	Status of CBFP signal

<sup>1)</sup> Output 0 = Not active; 1 = Active

### **3.3.3 Recorded data**

#### **3.3.3.1 General**

The information required for later fault analysis is recorded when the function block starts or trips.

The data of three last operations (operation 1...3) are recorded and the values of the most recent operation always replace the data of the oldest operation. The registers are updated in the following order: Operation 1, Operation 2, Operation 3, Operation 1, Operation 2,...

#### **3.3.3.2 Date and time**

The time stamp indicates the rising edge of the START or TRIP signal.

#### **3.3.3.3 Duration**

The duration of the start situation is recorded as a percentage of the calculated operate time.

#### **3.3.3.4 Currents**

If the function block trips or starts, the negative-sequence current is updated at the moment of tripping or starting i.e. on the rising edge of the TRIP or START signal. The negative-sequence current is recorded as a multiple of the rated current  $I_n$ .

#### **3.3.3.5 Status data**

The status data of the input signal BLOCK (Active or Not active) and the parameters "Rotation dir." and "Active group" are recorded at the moment of triggering. The "Rotation dir." parameter indicates the rotation direction of the machine and the "Active group" parameter the setting group valid for the recorded data.

### 3.3.3.6 Priority

The priority of the recording function is the following:

- 1 Tripping
- 2 Starting

### 3.3.3.7 Recorded data 1

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Date	V201	YYYY-MM-DD	-	-	R/M	Recording date
Time	V202	hh:mm:ss.mss	-	-	R/M	Recording time
Duration	V203	0.0...100.0	%	0.0	R/M	Duration of start situation
Neg. seq. cur.	V204	0.00...60.00	x In	0.00	R/M	Negative-sequence current
Current IL1	V205	0.00...60.00	x In	0.00	R/M	Filtered value of IL1
Current IL2	V206	0.00...60.00	x In	0.00	R/M	Filtered value of IL2
Current IL3	V207	0.00...60.00	x In	0.00	R/M	Filtered value of IL3
Rotation dir.	V208	0 or 1 <sup>1)</sup>	-	0	R/M	Status of rotation direction
BLOCK	V209	0 or 1 <sup>2)</sup>	-	0	R/M	Status of BLOCK input
Active group	V210	0 or 1 <sup>3)</sup>	-	0	R/M	Active setting group

<sup>1)</sup> Rotation dir. 0 = Forward; 1 = Reverse

<sup>2)</sup> BLOCK 0 = Not active; 1 = Active

<sup>3)</sup> Active group 0 = Group 1; 1 = Group 2

### 3.3.3.8 Recorded data 2

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Date	V301	YYYY-MM-DD	-	-	R/M	Recording date
Time	V302	hh:mm:ss.mss	-	-	R/M	Recording time
Duration	V303	0.0...100.0	%	0.0	R/M	Duration of start situation
Neg. seq. cur.	V304	0.00...60.00	x In	0.00	R/M	Negative-sequence current
Current IL1	V305	0.00...60.00	x In	0.00	R/M	Filtered value of IL1
Current IL2	V306	0.00...60.00	x In	0.00	R/M	Filtered value of IL2
Current IL3	V307	0.00...60.00	x In	0.00	R/M	Filtered value of IL3
Rotation dir.	V308	0 or 1 <sup>1)</sup>	-	0	R/M	Status of rotation direction
BLOCK	V309	0 or 1 <sup>2)</sup>	-	0	R/M	Status of BLOCK input
Active group	V310	0 or 1 <sup>3)</sup>	-	0	R/M	Active setting group

<sup>1)</sup> Rotation dir. 0 = Forward; 1 = Reverse

<sup>2)</sup> BLOCK 0 = Not active; 1 = Active

<sup>3)</sup> Active group 0 = Group 1; 1 = Group 2

## 3.3.3.9

## Recorded data 3

Parameter	Code	Values	Unit	Default	Data direction	Explanation
Date	V401	YYYY-MM-DD	-	-	R/M	Recording date
Time	V402	hh:mm:ss.mss	-	-	R/M	Recording time
Duration	V403	0.0...100.0	%	0.0	R/M	Duration of start situation
Neg. seq. cur.	V404	0.00...60.00	x In	0.00	R/M	Negative-sequence current
Current IL1	V405	0.00...60.00	x In	0.00	R/M	Filtered value of IL1
Current IL2	V406	0.00...60.00	x In	0.00	R/M	Filtered value of IL2
Current IL3	V407	0.00...60.00	x In	0.00	R/M	Filtered value of IL3
Rotation dir.	V408	0 or 1 <sup>1)</sup>	-	0	R/M	Status of rotation direction
BLOCK	V409	0 or 1 <sup>2)</sup>	-	0	R/M	Status of BLOCK input
Active group	V410	0 or 1 <sup>3)</sup>	-	0	R/M	Active setting group

<sup>1)</sup> Rotation dir. 0 = Forward; 1 = Reverse

<sup>2)</sup> BLOCK 0 = Not active; 1 = Active

<sup>3)</sup> Active group 0 = Group 1; 1 = Group 2

## 3.3.4

## Events

Code	Weighting coefficient	Default mask	Event reason	Event state
E0	1	1	START signal from I2> or I2>> stage	Reset
E1	2	1	START signal from I2> or I2>> stage	Activated
E2	4	1	TRIP signal from I2> or I2>> stage	Reset
E3	8	1	TRIP signal from I2> or I2>> stage	Activated
E4	16	1	CBFP signal from I2> or I2>> stage	Reset
E5	32	1	CBFP signal from I2> or I2>> stage	Activated
E6	64	0	BLOCK_OUT signal from I2> or I2>> stage	Reset
E7	128	0	BLOCK_OUT signal from I2> or I2>> stage	Activated
E8	256	0	BLOCK signal of I2> or I2>> stage	Reset
E9	512	0	BLOCK signal of I2> or I2>> stage	Activated
E10	1024	0	Test mode of I2> or I2>> stage	Off
E11	2048	0	Test mode of I2> or I2>> stage	On

