

2 -- ALL REINFORCING BARS SHALL BE  
DEFORMED BARS (CONFORMING TO  
A.S.T.M. A-305) WITH A MINIMUM  
ALLOWABLE TENSILE STRENGTH  
F<sub>s</sub> = 24,000 PSI (A-432)