

Table 4.1.5.3.
Specified Uniformly Distributed Live Loads on an Area of Floor or Roof
 Forming Part of Sentence 4.1.5.3.(1)

Use of Area of Floor or Roof	Minimum Specified Load, kPa
Assembly Areas a) Except for the areas listed under b) and c), assembly areas with or without fixed seats including <ul style="list-style-type: none"> Arenas Auditoria Churches Dance floors Dining areas⁽¹⁾ Foyers and entrance halls Grandstands, reviewing stands and bleachers Gymnasias Museums Promenades Rinks Stadia Theatres Other areas with similar uses 	4.8
b) Assembly areas with fixed seats that have backs over at least 80% of the assembly area for the following uses: <ul style="list-style-type: none"> Churches Courtrooms Lecture Halls Theatres 	2.4
c) Classrooms with or without fixed seats	2.4
Attics <ul style="list-style-type: none"> Accessible by a stairway in <i>residential occupancies</i> only Having limited accessibility so that there is no storage of equipment or material⁽²⁾ 	1.4 0.5
Balconies <ul style="list-style-type: none"> Exterior Interior and <i>mezzanines</i> that could be used by an assembly of people as a viewing area⁽²⁾ Interior and <i>mezzanines</i> other than above 	4.8 4.8 (3)
Corridors, lobbies and aisles <ul style="list-style-type: none"> Other than those listed below Not more than 1 200 mm in width and all upper floor corridors of residential areas only of apartments, hotels and motels (that cannot be used by an assembly of people as a viewing area)⁽²⁾ 	4.8 (3)