



A. Operation Fan:

1. Operate when switch in booth is activated

B. Operation Burner:

1. Allow operation when OAT is below 50°F (ajds. In MAU)
2. Modulate Burner to Maintain space Temperature (40%-100% Modulation possible)

C. Operation Dampers:

1. When Dial is on 100% OA open Discharge damper 100% and close Return damper to 0%
2. When OA dial is between 50% and 99% modulate dampers on linear scale:
 - a) close Discharge damper down to 50% (determined at time of balancing)
 - b) open Return damper up to 100%