



SIEMENS

SER. NO. **24-34520-01**
NEMA CLASS AA DRY TYPE TRANSFORMER

VA...2500
HV...13200
kV BIL.60HV/10LV
LV...480Y/277
LV AMP.3007

CLASS...AA
TYPE...VENT
PHASE...3
IMP.....5.87
HZ.....60

TEMP. RISE...115°C
CONDUCTOR...A/A
SPECS.#



VOLTS
13860
13530
13200
12870
12540

AMPERES	
AA	FA
104	
107	
109	
112	
115	

CONN. TAP ON EACH COIL	
E-F	A
D-F	B
E-G	C
D-G	D
C-G	E

DE-ENERGIZE TRANSFORMER BEFORE
CHANGING TAPS

DATE - 9/93

APPROX. WT. (LBS)

C&C 11100

TOTAL 12500

INST. BOOK IBXFI-00