



2	a	OUTGOING FEED 415V 3 PH
4	b	BUSBAR / RISER SYSTEM
6	c	500 AMP M-PACT 5 ACB
8	d	CDG 14 EARTH FAULT RELAY (5IN)
10		
12	f	110V DC TRIP SUPPLY
14	g	EARTH FAULT ALARM SIGNAL
16		
18		
20		
22		
24		
26	p	KLIPPON LINK TERMINAL SAK R MOUNTED INSIDE COMPT ALONG WITH SAK TI
28		FIT STANDARD WARNING LABEL ON COMPT DOOR
30	u	SI-a ACB AUX OPEN WHEN ACB OPEN SI-b CLOSED WHEN ACB OPEN
32		
34		
36	s	KLIPPON SHORTING TEST TERMINAL TYPE SAK TI FIT INTERBLOCK LINK & REQUISITE CROSS CONNECTOR BAR
38		
40	v	TERMINALS TO BE SHROUDED
42		
44		
46		
48		SULLOM VOE TERMINAL
50	FW REQ FW ORDER TAG NO	1854 - 1722 - ZA
		5041/1850
		SA-1DO1
	DRAWING NUMBER	650-02D-8346 S
	SHEET NUMBER	6-051