




ALT II W/4"
2'-0" (TYP.)


L




1/2" Ø S.S. KWIK BOLT II W/ 4"
EMBEDMENT OR EQUAL.
SPACING @2'-0" ON CTRS.
(TYPICAL)
9'-2 1/2"

PLAN




NOTE: ALL PARTS THAT ARE NOT STAINLESS
STEEL SHALL BE GALVANIZED. NUTS TO BE
COATED IN ACCORDANCE W/ ASTM A 536.



SECTION D-D



SECTION E-E



ANTI-STAGNATION WALL DETAIL

SCALE: 1/2" = 1'-0"

9