



- GENERAL NOTES:**
- 1-ALL MATERIAL TO BE A-36 WITH MIN. YIELD STRENGTH OF 36000 P.S.I. AS PER AISC CODE OR EQUIVALENT.
 - 2- ALL FABRICATION AND ERECTION TO BE AS PER AISC SPECIFICATION OR EQUIVALENT. USE E 70 XX ELECTRODES.
 - 3-ALL FILLET WELDS SHALL BE 5/16" THICK EXCEPT WHERE WRITTEN OTHERWISE ALL BUTT WELDS SHALL BE FULL STRENGTH.
 - 4-ALL NEW GUSSET PLATE TO BE 3/8" THICK.

Do you have enough headroom to place these members as shown in black? It would be much better if you can place the braces at the panel points.

