



Posts/Studs Analysis and Design

ASD Method

Version: 3.1

www.pa.org



How to Enter Data

Designed on: September 21, 2016



Print



Order Pro Version



Developed by: **Forum Engineers**

Member # **Typical Wall Stud**

Location : **North Wall**

Sits on Sill Plate ?

**** Dimension Lumber ****

Nominal Size : **(1) 2** x **6**

Species = **Douglas Fir-Larch**

Grade = **No.2**

**** Dimension Lumber ****


Sill Plate Nominal Size : **2** x **6**

Species or Symbol = **Douglas Fir-Larch**

Grade = **No.2**

Bearing at < 3" of Sill End? **No**

Height (H) = 10 ft - 0 in
Unbraced Length (I₁) = 10 ft - 0 in
Unbraced Length (I₂) = 1 ft - 0 in



P = **2400** lb = DL + SL
w = **40.0** plf = Wind
lu = 10 ft - 0 in

Setup (pressed-down buttons are selected)

| | | | |
|-----------------------------|---|--|--|
| Repetitive Use ? | <input type="button" value="No"/> | <input type="button" value="Yes"/> | |
| Incised for PT ? | <input type="button" value="No"/> | <input type="button" value="Yes"/> | |
| Flat Use : | <input type="button" value="No"/> | <input type="button" value="Yes"/> | |
| Moisture Content : | <input type="button" value="<19%"/> | <input type="button" value=">19%"/> | |
| Temperature (° F) : | <input type="button" value="<100"/> | <input type="button" value="100~125"/> | <input type="button" value="125~150"/> |
| Set Duration Factors | C _D = 1.15 (P) & 1.60 (P+w) | | |
| Set Effective-Length Factor | K = 1.00 | | |
| Set Deflection Limit | Δ / H = 240 | | |

for P only, f_c (psi) = 291 < 781 = F_c -|
 for P + w, f_c (psi) = 291 < 781 = F_c -|
 (1.3/2) f_b (psi) = 516 < 871 = F_b
 $(f_c / F'_c)^2 + f_b / [F'_b (1 - f_c / F_{ce})] = 0.94$ < 1.00 **OK**
 Mid-H Deflection due to w, Δ (inch) = 0.19 < H / 240 **OK**

Why is this 0.65 f_b? to check interaction against 1 instead of 1.33 allowable increase?

Section Properties

| | Post/Stud | Sill PL |
|--------------------------|----------------------|---------|
| breadth (b) = | 1.5 in | 1.5 |
| depth (d) = | 5.5 in | 5.5 |
| Area (A) = | 8.3 in ² | 8.3 |
| Section Modulus (S) = | 7.6 in ³ | |
| Moment of Inertial (I) = | 20.8 in ⁴ | |

I can not reproduce this value

Adjustment Factors

| | Bending | Comp // | E | Sill PL |
|------------------------|------------------------|---------|------|---------|
| | | | | Comp - |
| Wet Service | C _M = 1.00 | 1.00 | 1.00 | 1.00 |
| Temperature | C _t = 1.00 | 1.00 | 1.00 | 1.00 |
| Beam Stability | C _L = 0.56 | N/A | N/A | N/A |
| Size | C _F = 1.30 | 1.10 | N/A | N/A |
| Flat Use | C _{Fu} = 1.00 | N/A | N/A | N/A |
| Incising | C _i = 1.00 | 1.00 | 1.00 | 1.00 |
| Repetitive Member | C _r = 1.15 | N/A | N/A | N/A |
| Column Stability (P) | C _P = N/A | 0.49 | N/A | N/A |
| Column Stability (P+w) | C _{Pw} = N/A | 0.38 | N/A | N/A |
| Bearing Area | C _b = N/A | N/A | N/A | 1.25 |

Design Values (psi)

| | F _b | F _c - | E | F _c - | E _{min} |
|----------------|----------------|------------------|---------|------------------|------------------|
| Reference | 900 | 1350 | 1600000 | 625 | 580000 |
| Adjusted (P) | | 839 | 1600000 | 781 | 580000 |
| Adjusted (P+w) | 871 | 894 | 1600000 | 781 | 580000 |

Product of factors *F_b is 866 psi

These verify by my calcs

BEARING WALL STUDS WITH AXIAL & BENDING

Section Properties: $n := 3$ number of plates

$b := 1.5 \text{ in}$ $d := 5.50 \text{ in}$ $l := 10 \text{ ft} + 4.50 \text{ in}$ $t_{pl} := 1.5 \text{ in}$

$l_y := 1 \text{ ft} + 0 \text{ in}$ $l_x := l - n \cdot t_{pl} = 120 \text{ in}$ $l_b := 10 \text{ ft} + 0 \text{ in}$

$K_{ey} := 1.0$ $K_{ex} := 1.0$ $l_u := l_y$

$A := b \cdot d = 8.25 \text{ in}^2$ $S_x := b \cdot \frac{d^2}{6} = 7.5625 \text{ in}^3$ $I_x := b \cdot \frac{d^3}{12} = 20.7969 \text{ in}^4$

Wall Stud Spacing $s := 24 \text{ in}$

Axial Force $DL := 600 \frac{\text{lbf}}{\text{ft}}$ $LL := 600 \frac{\text{lbf}}{\text{ft}}$

$P := s \cdot (DL + LL) = 2400 \text{ lbf}$

Lateral Forces: $w_{wall} := 20 \frac{\text{lbf}}{\text{ft}^2}$ $w := w_{wall} \cdot s = 40 \frac{\text{lbf}}{\text{ft}}$

Wood Species and Properties, 2012 NDS:

Doug-Fir No 2

$F_b := 900 \text{ psi}$ $F_{Cperp} := 625 \text{ psi}$ $F_{c11} := 1350 \text{ psi}$ $E_{min} := 580000 \text{ psi}$ $E := 1.6 \cdot 10^6 \text{ psi}$

Applicable Adjustment Factors:

$C_{DPsnow} := 1.15$ $C_M := 1.0$ $C_t := 1.0$ $C_L := 1.0$ $C_{Fc} := 1.10$ $C_i := 1.0$

$C_{fu} := 1.0$ $C_T := 1.0$ $C_p := 1.0$ (C.p recalced below)

Determine capacity due to column equation:

$$LED := \max \left(\left[\frac{K_{ey} \cdot l_y}{b} \right], \left[\frac{K_{ex} \cdot l_x}{d} \right] \right) = 21.8$$

$$\frac{K_{ey} \cdot l_y}{b} = 8$$

$$\frac{K_{ex} \cdot l_x}{d} = 21.8182$$

$$E'_{min} := E_{min} \cdot C_M \cdot C_t \cdot C_T \cdot C_i = 580000 \text{ psi}$$

$$E' := E \cdot C_M \cdot C_t \cdot C_T = 1.6 \cdot 10^6 \text{ psi} \qquad E = 1.6 \cdot 10^6 \text{ psi}$$

$c := 0.8$ for visually graded sawn lumber

$$F_{cE} := \frac{0.822 \cdot E'_{min}}{LED^2} = 1001.5 \text{ psi} \qquad F_{cE} = 1002 \text{ psi}$$

$$F_{cSTAR} := F_{c11} \cdot C_{DPSnow} \cdot C_M \cdot C_t \cdot C_{Fc} \cdot C_i = 1707.75 \text{ psi}$$

$$F_{cSTAR} = 1707.75 \text{ psi}$$

Calculate C_p (column stability factor):

$$C_p := \frac{1 + \frac{F_{cE}}{F_{cSTAR}}}{2 \cdot c} - \sqrt{\left(\frac{1 + \frac{F_{cE}}{F_{cSTAR}}}{2 \cdot c} \right)^2 - \frac{F_{cE}}{F_{cSTAR} \cdot c}} = 0.4915$$

These check
against WWSA ok

$$C_p = 0.4915$$

$$F'_c := F_{c11} \cdot C_{DPSnow} \cdot C_M \cdot C_t \cdot C_{Fc} \cdot C_p \cdot C_i = 839 \text{ psi}$$

$$F'_c = 839 \text{ psi}$$

$$f_c := \frac{P}{A} = 291 \text{ psi}$$

```

if  $f_c \leq F'_c$  = "AXIAL CHECK OK"
  "AXIAL CHECK OK"
else
  "AXIAL CHECK NG"

```

$$P_a := F'_c \cdot A = 6924 \text{ lbf}$$

$$P_a = 6924 \text{ lbf}$$

Maximum Wall Loading

$$w_{max} := \frac{P_a}{s} = 3462 \frac{\text{lbf}}{\text{ft}}$$

$$w_{max} = 3462 \frac{\text{lbf}}{\text{ft}}$$

Bearing Capacity Check of bottom plate

$$F_{Cpl} := 625 \text{ psi} \quad \text{Compression Capacity of Wall Plate}$$

$$C_b := \frac{b + 0.375 \text{ in}}{b} = 1.25$$

$$C_b = 1.25$$

$$F'_{Cpl} := F_{Cpl} \cdot C_M \cdot C_t \cdot C_b = 781 \text{ psi}$$

$$F'_{Cpl} = 781 \text{ psi}$$

```

if  $F'_{Cpl} \geq f_c$  = "BEARING CHECK OK"
  "BEARING CHECK OK"
else
  "BEARING NO GOOD"

```

Capacity with Bending

$$C_{DWind} := 1.6 \quad C_{Fc} = 1.1 \quad C_{Fb} := 1.3 \quad C_D := \min \left(\begin{array}{l} C_{DPSnow} \\ C_{DWind} \end{array} \right) = 1.15 \quad C_r := 1.150$$

$$M_{col} := \frac{w \cdot l_b^2}{8} = 6000 \text{ lbf in} \quad f_{bx} := \frac{M_{col}}{S_x} = 793 \text{ psi} \quad f_{bx} = 793 \text{ psi}$$

$$F_{cE} = 1002 \text{ psi} \quad C_D = 1.15 \quad C_M = 1 \quad C_t = 1 \quad C_{Fc} = 1.1 \quad C_i = 1$$

$$F_{cSTAR} := F_{c11} \cdot C_{DWind} \cdot C_M \cdot C_t \cdot C_{Fc} \cdot C_i = 2376 \text{ psi} \quad F_{cSTAR} = 2376 \text{ psi}$$

$$\frac{F_{cE}}{F_{cSTAR}} = 0.4215 \quad \frac{1 + \frac{F_{cE}}{F_{cSTAR}}}{2 \cdot c} = 0.8884$$

$$C_{pw} := \frac{1 + \frac{F_{cE}}{F_{cSTAR}}}{2 \cdot c} - \sqrt{\left(\frac{1 + \frac{F_{cE}}{F_{cSTAR}}}{2 \cdot c} \right)^2 - \frac{F_{cE}}{F_{cSTAR} \cdot c}} = 0.3762 \quad C_{pw} = 0.3762$$

$$F_{c11} = 1350 \text{ psi}$$

$$F'_c := F_{c11} \cdot C_{DWind} \cdot C_M \cdot C_t \cdot C_{Fc} \cdot C_{pw} \cdot C_i = 894 \text{ psi}$$

$$l_u := 120 \text{ in}$$

$$\text{if } \frac{l_u}{d} < 7 \quad l_e = 212.1 \text{ in} \quad F_b = 900 \text{ psi}$$

$$l_e := 2.06 \cdot l_u$$

else

$$l_e := 1.63 \cdot l_u + 3 \cdot d$$

$$R_B := \sqrt{\frac{l_e \cdot d}{b^2}} = 22.7699$$

$$F_{bE} := \frac{1.2 \cdot E' \cdot \min}{R_B^2} = 1342 \text{ psi}$$

$$C_L = 1 \quad F_b = 900 \text{ psi} \quad C_D = 1.15 \quad C_r = 1.15 \quad C_{Fb} = 1.3$$

$$F'_{bx} := C_L \cdot F_b \cdot C_D \cdot C_M \cdot C_t \cdot C_{Fb} \cdot C_r \cdot C_L = 1547.325 \text{ psi}$$

$$C_L := \frac{1 + \frac{F_{bE}}{F'_{bx}}}{1.9} - \sqrt{\left(\frac{1 + \frac{F_{bE}}{F'_{bx}}}{1.9} \right)^2 - \frac{F_{bE}}{F'_{bx} \cdot 0.95}} = 0.7529$$

This value in the WWPA spreadsheet is 0.49

$$F'_{bx} := C_L \cdot F_b \cdot C_D \cdot C_M \cdot C_t \cdot C_{Fb} \cdot C_r \cdot C_L = 877 \text{ psi}$$

This value is expressed as 0.65fb in the WHPA spreadsheet

CHECK INTERACTION OF BENDING AND AXIAL

$$f_c = 291 \text{ psi}$$

$$f_{bx} = 793 \text{ psi}$$

$$F'_c = 894 \text{ psi}$$

$$F'_{bx} = 877 \text{ psi}$$

This value is 871 in the WHPA spreadsheet.

$$F_{cE} = 1002 \text{ psi}$$

These check

$$\left(\frac{f_c}{F'_c} \right) = 0.3255$$

$$\frac{1}{1 - \frac{f_c}{F_{cE}}} = 1.4094$$

$$\frac{f_{bx}}{F'_{bx}} = 0.9046$$

$$IE := \left(\frac{f_c}{F'_c} \right)^2 + \frac{f_{bx}}{F'_{bx} \cdot \left(1 - \frac{f_c}{F_{cE}} \right)} = 1.3808$$

if $1.0 \geq IE$ = "INTERACTION NOT GOOD"
 "INTERACTION CHECK OK"
 else
 "INTERACTION NOT GOOD"

I am OVER by this check!