


1	 <div> <div>LEGENDS</div> <div>Calgary, Alberta</div> <div>CANADA</div> </div>				Case Name: C:\Documents and Settings\Owner\Desktop\PIPESYS\uk_2.hsc				
2					Unit Set: SI				
3					Date/Time: Mon Oct 16 15:56:27 2017				
4									
5									
6	NeotecPIPESYS v2.01:				uk_2.hsc				
7									
8									
9									
10	op-100								
11									
12	Cooldown								
13									
14									
15	Thermal Conductivity of Fluid								
16									
17	n/a								
18									
19	Heat Transfer Parameters				Transient Cooldown Parameters				
20									
21	Overall Heat Transfer Coefficient: ---				Maximum Time Since Shutdown: ---				
22	Inside Film Coefficient: ---				First Intermediate Time: ---				
23	Thermal Conductivity of Fluid: ---				Second Intermediate Time: ---				
24	Heat Capacity of Pipe Material: ---				Third Intermediate Time: ---				
25	Density of Pipe Material: ---				Minimum Cooldown Temperature: ---				
26					Calculation Time Step: ---				
27									
28	Results								
29	Cumulative	Overall Heat	Inside	Fluid	First	Second	Third	Temperature for	Time to Reach
30	Length	Transfer	Film	Thermal	Intermediate	Intermediate	Intermediate	Max Time Since	Min Cooldown
31		Coefficient	Coefficient	Conductivity	Temperature	Temperature	Temperature	Shutdown	Temperature
32	(m)	(kJ/h-m2-C)	(kJ/h-m2-C)	(W/m-K)	(C)	(C)	(C)	(C)	(hours)
33									
34									
35	Inlet Properties : inlet								
36									
37		Overall	Vapour Phase						
38	Vapour/Phase Fraction	1.0000	1.0000						
39	Temperature: (C)	45.00 *	45.00						
40	Pressure: (kPa)	8000.00 *	8000.00						
41	Molar Flow (kgmole/h)	300.00 *	300.00						
42	Mass Flow (kg/h)	5512.61	5512.61						
43	Liquid Volume Flow (m3/h)	16.82	16.82						
44	Std Gas Flow (STD_m3/h)	7093.33	7093.33						
45	Molar Enthalpy (kJ/kgmole)	-8.188e+004	-8.188e+004						
46	Mass Enthalpy (kJ/kg)	-4456	-4456						
47	Heat Flow (kJ/h)	-2.457e+007	-2.457e+007						
48	Molar Density (kgmole/m3)	3.4253	3.4253						
49	Mass Density (kg/m3)	62.942	62.942						
50	Std Liquid Mass Density (kg/m3)	---	---						
51	Molar Heat Capacity (kJ/kgmole-C)	49.646	49.646						
52	Mass Heat Capacity (kJ/kg-C)	2.702	2.702						
53	Molar Entropy (kJ/kgmole-C)	149.938	149.938						
54	Mass Entropy (kJ/kg-C)	8.160	8.160						
55	ThermalConductivity (W/m-K)	0.042	0.042						
56	Viscosity (cP)	0.014	0.014						
57	Surface Tension (dyne/cm)	---	---						
58	Molecular Weight	18.375	18.375						
59	Z Factor	0.883	0.883						
60									
61									
62									
63	Hyprotech Ltd.		HYSYS v3.2 (Build 5029)				Page 8 of 10		

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59


60

61

62

63


<

1	 <div> <div>LEGENDS</div> <div>Calgary, Alberta</div> <div>CANADA</div> </div>	Case Name: C:\Documents and Settings\Owner\Desktop\PIPESYS\uk_2.hsc
2		Unit Set: SI
3		Date/Time: Mon Oct 16 15:56:27 2017
4		
5		
6	NeotecPIPESYS v2.01:	
7	uk_2.hsc	
8		
9		
10	op-100	
11		
12	Summary	
13		
14		
15		
16	Upstream Pressure: 8000.00 kPa	
17	Upstream Temperature: 45.00 C	
18		
19	Downstream Pressure: 7271.64 kPa	
20	Downstream Temperature: 26.46 C	
21		
22	Predicted Pressure Loss: 728.37 kPa	
23		
24	Friction Loss: 555.71 kPa	
25	Hydrostatic Loss: 172.50 kPa	
26	Kinetic Loss: 0.156 kPa	
27	Inline Facilities Loss: 0.00 kPa	
28		
29	Average Pressure Gradient: -0.2418 kPa/m	
30		
31	Total Liquid Holdup: 0.0 m3	
32	Total Line Pack @STD: 1167.7 m3	
33		
34	Pipe Volume: 14.4 m3	
35		
36	Net Heat Loss to the Surroundings: 2.195e+005 kJ/h	
37		
38		
39		
40		
41		
42		
43		
44		
45		
46		
47		
48		
49		
50		
51		
52		
53		
54		
55		
56		
57		
58		
59		
60		
61		
62		
63	Hyprotech Ltd.	<div> <div>HYSYS v3.2 (Build 5029)</div> <div>Page 10 of 10</div> </div>


Pipeline Elevation: op-100



Flowing Pressure: op-100



Flowing Temperature: op-100



Actual Gas Velocity: op-100

