


169 W 83RD

TO APARTMENTS

CITY WATER IN @ 32 PSI


DOMESTIC COLD SUPPLY AT 50 PSI



DOMESTIC BOOSTER PUMP
GOULD HMS PUMP
MODEL 2HM1E200
VARIABLE SPEED
CONSTANT PRESSURE

COLD IN

COLD IN



BOILER

WATER COIL

RECIRC FOR COIL

HOT FROM COIL

DOMESTIC HOT WATER SUPPLY MIXING VALVE DISCHARGE

DOMESTIC RETURN



BELL & GOSSETT CIRCULATOR
NBF -25
103418LF1M61

TO MIXING VALVE BOARD