



NOTE 1 This figure conforms with the requirements of Section VIII of the ASME *Boiler and Pressure Vessel Code* for MAWPs greater than 30 psig.

NOTE 2 The pressure conditions shown are for pressure relief valves installed on a pressure vessel.

NOTE 3 Allowable set-pressure tolerances will be in accordance with the applicable codes.

NOTE 4 The maximum allowable working pressure is equal to or greater than the design pressure for a coincident design temperature.

NOTE 5 The operating pressure may be higher or lower than 90 %.

NOTE 6 Section VIII, Division 1, Appendix M of the ASME *Code* should be referred to for guidance on blowdown and pressure differentials.