

CLIENT: Client
 PROJECT: Cement Plant Water System
 DESCRIPTION: Estm. HGLs at "reservoir" for water model
 PROJECT No.: //job number//

PREPARED BY: ME!, P.E.
 DATE: June 7, 2023

Mathcad Prime 5.0 worksheet prepared by ME!, P.E. //edited for posting on ENG-TIPS.COM//

1.0 WORKSHEET INTRODUCTION

The purpose of this worksheet is to convert water system pressures to hydraulic grade lines (HGLs) for the Reservoir in the EPANET model of the plant's water system.

2.0 PROJECT DESCRIPTION

The cement plant receives water for domestic uses and fire protection from the City of _____. For modeling the on-site water system, I chose the intersection of _____ Blvd. and _____ Blvd. as the "reservoir" that feeds the plant's water system and which regulates the HGLs in the model. This intersection, which is about 650 feet north of the entrance to the plant, is one of the locations for which fire flows were both tested and modeled for the City's yyyy Water Master Plan Update [1], and it is the junction of three 12-inch water mains.

3.0 CONVERSION FACTORS (FYI)

$$1 \text{ ft} \cdot \gamma_w = 0.433 \text{ psi} \qquad \frac{1 \text{ psi}}{\gamma_w} = 2.308 \text{ ft}$$

4.0 DATA

- Unit weight of water: $\gamma_w \equiv 62.4 \text{ pcf}$ {1}
- Ground elevation at "reservoir": $Elev := 15.0 \text{ ft}$ {2}
- Excerpts from [1], Table #.#: {3}

Table 1 Fire Flow Calibration Results					Field Measured Data ⁽¹⁾				Model Simulated Data	
Test Site	Test Location	Date/ Time	Hydrant Type	Hydrant ID	Hydrant Flow (gpm)	Hydrant Pressure (psi)		Hydrant Pressure (psi)		
						Static	Residual	Static	Residual	
11	_____ Boulevard and _____ Boulevard	_____ 12:51 PM	Flowing Pressure	F18-09	942	--	--	--	--	
			Pressure	F18-02	--	62	61	60.8	57.5	
			Pressure	F17-13	--	64	61	60.8	57.7	

Estimated Pressures at Test Site 11 per [2]: {4}

HydID	$P_{@1500_gpm_FF}$	$P_{@1750_gpm_FF}$	$P_{@2000_gpm_FF}$	$P_{@2250_gpm_FF}$
	(psi)	(psi)	(psi)	(psi)
"F18-02_Field"	59.5	59.0	58.0	57.0
"F17-13_Field"	57.0	54.5	52.0	49.0
"F18-02_Model"	53.0	50.5	48.0	45.0
"F17-13_Model"	53.0	50.5	48.0	45.0

For the EPANET model, I split the difference between "F17-13_Field" and "F17-13_Model" (see next page). {5}

Pressures to convert:

<u>Analysis Condition</u>	<u>Fire Flow</u>	<u>Estm Pressure</u>
<i>AC</i>	<i>Q</i>	<i>P</i>
	<i>(gpm)</i>	<i>(psi)</i>
"PDH"	0	60.0
"MDD+FF"	1500	55.0
"MDD+FF"	1750	52.5
"MDD+FF"	2000	50.0
"MDD+FF"	2250	47.0

{6}

5.0 CALCULATIONS

Hydraulic grade lines:
$$HGL := Elev + \frac{P}{\gamma_w}$$
 {7}

Results:
$$Q = \begin{bmatrix} 0 \\ 1500 \\ 1750 \\ 2000 \\ 2250 \end{bmatrix} \text{ gpm} \quad P = \begin{bmatrix} 60.0 \\ 55.0 \\ 52.5 \\ 50.0 \\ 47.0 \end{bmatrix} \text{ psi} \quad HGL = \begin{bmatrix} 153.5 \\ 141.9 \\ 136.2 \\ 130.4 \\ 123.5 \end{bmatrix} \text{ ft} \quad HGL_{USE} := \begin{bmatrix} 153.0 \\ 142.0 \\ 136.0 \\ 130.0 \\ 123.0 \end{bmatrix} \text{ ft} \quad \{8\}$$

A. REFERENCES

- [1] _____, "City of _____, yyyy Water Master Plan Update," [date].
- [2] hosemaster.com/resources/hydrant-flow-test-calculator

B. NOTES

- {1} The most commonly used unit weight for water is 62.4 *pcf* and it occurs at a temperature of 58.5 °F. The temperature of water in buried pipelines in temperate climates is often cited as being about 60 °F and this is close enough to justify using 62.4 *pcf* here. At 40 °F, the specific weight of water is 62.43 *pcf*; at 68 °F (a commonly used standard temperature), the value is 62.31 *pcf*.
- {2} I estimated the ground elevation of the subject intersection using Google Earth. Google Earth produced an elevation closer to the site survey provided by the client than did the yyyy and yyyy USGS "_____ Quadrangle" maps that cover the site. The USGS maps have very sparse elevation information in the vicinity of the site and I considered them to be poor choices for this task.
- {3} Excerpts from [1], Table #.#. Test Site 11 is the "reservoir" for the EPANET model of the plant's on-site water system.
- {4} Use [2] and the data in [1], Table #.#, to estimate the pressures at Test Site 11 when providing different fire flows to the plant. Estimates are rounded to the nearest 0.5 *psi*. The 2000 *gpm* and 2250 *gpm* fire flows are included for modeling the future system in case the City increases the fire flow requirement. Preliminary model runs show that the maximum fire flow that the combined City-plant water system can deliver is approximately 2750 *gpm*. Any higher and additional improvements to either or both systems would be required.
- {5} _____ made and used a skeletonized model of the City's water distribution system for the Water Master Plan Update. Skeletonized models are conservative because even small-diameter looped pipes add to system capacity. For this project, I consider the field measurements to be more representative of the system. However, to be conservative and to approximately account for the small amount of domestic water that I did not include with the fire flow amounts, I split the difference between estimated pressures for "F17-13_Field" and estimated pressures for "F17-13_Model".
- {6} The estimated pressure for "PDH" is based on typical pressures mentioned in [1].
- {7} This formula is a subset of Bernoulli's Equation.
- {8} Convert pressures to HGLs, then round off the results for use in the EPANET model.