



2. Mo
3. No
4. To
5. Mi

Max. o

N.B. Po

fx

t14.

fx

t31.

1.31.01	1.29.0	1.27.3	1.31.01	1.40.00	1.32.54	1.35.61	1.40
---------	--------	--------	---------	---------	---------	---------	------

TERMINAL POINT SCHEDULE		
TP No	TERMINAL POINT DESCRIPTION	SIZE/RATING- (ANSI B16.5)
TP 1	PUMP SUCTION	24" 150lb RF
TP 2	PUMP DISCHARGE	14" 300lb RF
TP 3	PUMP DRAIN	2" 150lb RF
TP 4	PUMP VENT	1" 300lb RF
TP 5	PUMP PURGE	2" 150lb RF
TP 6	PLAN 32 EXTERNAL FLUSH	3/4" 300lb RF
TP 7	SEAL LEAKAGE DRAIN	1" 600lb RF

NOTES :

1. ALL SMALL BORE PIPING TERMINATION DIMENSIONS $\pm 50\text{MM}$.
2. ALL HOLES IN FLANGES STRADDLE C'S.
3. CAREFULLY CHECK ALIGNMENT BEFORE STARTING UNIT.
4. PLAN 31/32 PIPING IN TYPE 316 ST. STEEL.
5. PUMP DRAIN AND VENT VALVES IN CARBON STEEL.