

Example:

Fan ESP — 300 Pa.

Supply duct — 180 Pa.

Return duct — 150 Pa.

Comparison:

$$SD - 180 < 300 \quad \checkmark$$

$$RD - 150 < 300 \quad \checkmark$$

OK

$$SD + RD = 320 > 300 \quad \checkmark$$

(not ok)

REMINDERS

