


### One Pump On


Section	Flow			
A-B	100	200	300	400
B-C	100	200	300	400
HL	2	5	8	12

### Two Pumps On

Section	Flow			
A-B	100	200	300	400
B-C	200	400	600	800
HL	5	10	18	30



System Q (1 pump)



System Q (2 pumps)