

(E) Footing Check

$$q = 1500 \text{ PSF}$$

Req'd footing
depth,

$$d_r = \frac{1000 \text{ PLF}}{1500 \text{ PSF}}$$

$$= 8' < 15' \text{ (ok)}$$

(15' assumed.)

