

CABINET POWER SUPPLY STATUS (655A)

Pow Loc	Alm Cnt	Temp(F/C)		Hot Spot	Voltage			FAN			Ring Voltage			Input Power
		InLet	Exhst		+5	-5	-48	Ctrl	Alm	Stat	Ctrl	Set	Det	
06A00	0	75/24	75/24	ok	5.10	5.08	48.8	mid	N	ok	actv	20HZ	Y	AC
06A15	0	77/25	75/24	ok	5.10	5.10	48.5	mid	N	ok	stby	20HZ	Y	AC
06B00	0	75/24	75/24	ok	5.10	5.03	49.0	mid	N	ok	actv	20HZ	Y	AC
06B15	0	77/25	77/25	ok	5.10	5.03	49.0	mid	N	ok	stby	20HZ	Y	AC