

	C	D	E	F	G	H	I	J	K	L	M	N
1		DRAFTING	www..com								ASHRA	
2		Standards are	set by the type of construction codes		BIM Technical Standards: Naming or GSA				Academy MS/HS			
3									211069	Abbreviation	Term	
4		ABBREV.	DESCRIPTION		ABBREV.	DESCRIPTION					A	
5							A/C	AIR CONDITIONING		ABAN	Abandon	
6		A/E	ARCHITECT AND ENGINEER		AER	Aerator	AC	AIR CURTAIN		ABBRV	Abbreviation	
7		AC OR ACU	AIR CONDITIONING UNIT OR AIR COMPRESSOR		ABL	Air Blower	ACU	AIR CONDITIONING UNIT		ABNL	Abnormal	
8		ACCU	AIR COOLED CONDENSING UNIT		CMP	Air Compressor	AD	DUCT/PLENUM ACCESS DOOR		AFC	Above finished counter	
9		ACD	AIR CONDITIONING CONDENSATE DRAIN		CMP	Air Compressor, Recip	AE	ACOUSTICAL ELBOW (REFER TO DETAIL THIS SHEET)		AFF	Above finished floor	
10		AD	ACCESS DOOR		ACU	Air Conditioner Package	AFF	ABOVE FINISHED FLOOR		AFG	Above finished grade	
11		ADJ	ADJUSTABLE OR ADJACENT		ACW	Air Conditioner, Window	AFMS	AIR FLOW MONITOR/MEASURING STATION		AFS	Above finished slab	
12		AFCV	AIRFLOW CONTROL VALVE		ACT	Air Curtain	AFP	AIR FLOW MEASUREMENT PROBE				
13		AFF	ABOVE FINISHED FLOOR		ADR	Air Dryer	AFT	AIR FLOW TRANSDUCER/TEMPERATURE MONITOR		CHW	Chilled water	
14		AFMS	AIR FLOW MEASURING STATION		AHU-02	Air Handling Unit, 25 ton thru 50 ton	AHU	AIR HANDLING UNIT (W/ INTEGRAL DEVICES FOR COOLING,		CHWPP	Chilled water primary pump	
15		AHU	AIR HANDLING UNIT		AHU-01	Air Handling Unit, 3 ton thru 24 ton	HEATING,	CLEANING AND/OR FILTRATION OF THE CIRCULATED AIR). TE		CHWP	Chilled water pump	
16		APD	AIR PRESSURE DROP		AHU-04	Air Handling Unit, Computer Room	BE	USED INTERCHANGEABLY WITH ADU'S AND ARU'S.		CHWRP	Chilled water recirculating pump	
17		APPROX	APPROXIMATE		AHU-03	Air Handling Unit, over 50 ton	ADU	AIR HANDLING UNIT, W/ INTEGRAL DEVICES FOR INCREASED		CHWR	Chilled water return	
18		AR	AIR RECEIVER		BFP	Backflow Prevention Device	ARU	AIR HANDLING UNIT, W/ INTEGRAL DEVICES FOR ENERGY REC		CHWSP	Chilled water secondary pump	
19		ARCH	ARCHITECT		BLR-E	Boiler, Electric	AL	ALUMINUM		CHWS	Chilled water supply	
20		AS	AIR SEPARATOR		BLR-HW2	Boiler, Hot Water, Oil/Gas/Comb, 120 to 500 MBH	ALT	ALTERNATE, ALTERNATIVE		CH	Chiller	
21		ATM	ATMOSPHERE		BLR-HW3	Boiler, Hot Water, Oil/Gas/Comb, 500 to 1000 MBH	AMB	AMBIENT				
22		AV	ACID VENT		BLR-HW4	Boiler, Hot Water, Oil/Gas/Comb, over 1000 MBH	AP	ACCESS PANEL		MOT	Motor	
23		AVMS	AIR VOLUME MEASURING STATION		BLR-HW1	Boiler, Hot Water, Oil/Gas/Comb, up to 120 MBH	APD	AIR PRESSURE DROP (IN INCHES OF WATER COLUMN)		MCC	Motor control center	
24		AW	ACID WASTE		BLR-ST2	Boiler, Steam, Natural Gas	AS	AIR SEPARATOR		MDC	Motor direct connect	
25					BLR-ST2	Boiler, Steam, Oil/Gas/Comb	AR	ACID RESISTANT		MG	Motor generator	
26					BLR-ST3	Boiler, Steam, Oil/Gas/Comb, 500 to 1000 MBH	ARV	AIR RELIEF VALVE, MANUAL AIR VENT		MO	Motor operated	
27		B	BOILER		BLR-ST4	Boiler, Steam, Oil/Gas/Comb, over 1000 MBH	AT	AIR TRANSFER		MOD	Motor operated damper	
28		BCU	BLOWER COIL UNIT		BLR-ST1	Boiler, Steam, Oil/Gas/Comb, up to 120 MBH	ATD	AIR TEMPERATURE DROP (IN °F, UNLESS OTHERWISE NOTED)		MOV	Motor operated valve	
29		BDD	BACKDRAFT DAMPER		BAS-01	Building Automation System, DDC	ATR	AIR TEMPERATURE RISE (IN °F, UNLESS OTHERWISE NOTED)		MS	Motor starter	
30		BHP	BRAKE HORSEPOWER		BAS-02	Building Automation System, Pnuematic	ATV	AIR TURNING VANES				
31		BI	BACKWARD INCLINED		BAS-03	Building Automation System, Terminal End Devices	AUTO	AUTOMATIC		PDISCH	Pump discharge	
32		BLDG	BUILDING		CHT	Cabinet Heater	AVE	AIR VOLUME EXTRACTOR		PMPST	Pump suction	
33		BOT	BOTTOM		CMD	Carbon-Monoxide Detection Sensors				CNDP	Pumped condensate	
34		BP	BRINE PUMP		CHL-A2	Chiller, Absorption unit, 500 to 5000 tons	BCP	BOILER CIRCULATION PUMP		PR	Pumped return	