


GENERAL NOTES

1. EXPANSION JOINTS TO BE SPACED AT A MAXIMUM OF 60 FEET APART OR AS DIRECTED BY THE ENGINEER.
2. EXPANSION JOINTS WILL ALSO BE REQUIRED AT TANGENT POINTS, RAMPS, INLETS AND ANY APPURTENANCES.
3. CONTRACTION JOINTS ARE TO BE CUT INTO CURB AND GUTTER EVERY 10 FEET TO A DEPTH OF D/4, WHERE D EQUALS THE THICKNESS OF THE SECTION. THE SPACING OF 10 FEET MAY BE REDUCED AT CLOSURES BUT NO SECTION OF CURB AND GUTTER SHALL BE LESS THAN 10 FEET.
4. CONCRETE SHALL BE 3500 PSI AT 28 DAYS.
5. EXTEND #4 RODS 18" THRU EXPANSION JOINTS IN PLASTIC SLEEVES.
6. IN NO INSTANCES SHOULD MORE THAN 0.25 INCHES OF WATER POOL IN GUTTER IMMEDIATELY AFTER A RAIN EVENT.
7. MATERIALS AND INSTALLATION SHALL BE IN ACCORDANCE WITH THE DOT STANDARD SPECIFICATIONS FOR STATE AID ROAD AND BRIDGE CONSTRUCTION (LATEST EDITION).



ST-17 - 30" VERTICAL CURB AND GUTTER

NTS