



ALL 27KV SERVICE ENTRANCES ARE FED FROM REMOTE BREAKER AT NEARBY GENERATION STATION

TRANSFORMERS TO BE LOCATED OUTDOOR DIRECTLY OUTSIDE OF IPA BUILDING

NEW M-T-M-T-M SWITCHGEAR LINEUP TO BE LOCATED INSIDE NEW IPA BUILDING

MCC #4
DWG. 602404
ADD & CONNECT

(NOTE 5)
3-1/C #6 + 1/C #10G (DA21)
FIRE PROT. SYSTEM EMERGENCY FEED FUSED DISC. SW.

(NOTE 5)
3-1/C #6 + 1/C #10G (DA20)
FIRE PROT. SYSTEM NORMAL FEED FUSED DISC. SW.

