



Cant we eliminate the service ground and bonding jumper in the main panel if we run a ground wire from the transformer?