

June 24, 2024

Re: QuickTie™ Products, Inc.: QuickTie™ System (QTS) - Listing and TER 0910-01^{1, 2, 3, 4}

To whom it may concern:

The attached Listing and Technical Evaluation Report™ has been created by DrJ Engineering on behalf of QuickTie™ Products, Inc..


DrJ's code compliance work has been performed in concert with [ICC's Product Approval Checklist for Code Officials](#). DrJ has undertaken its engineering evaluation under the auspices of our [ANSI National Accreditation Board \(ANAB\) ISO/IEC 17065 \(17065\)](#) product evaluation process, which is the identical ANSI accredited certification approval process listed in the checklist. ANAB accreditation is often promoted by others stating they are "ICC Approved" As an example, [Los Angeles](#) has updated their Los Angeles Research Report (LARR) process to adopt the ANAB 17065 process.

[DrJ's procedures](#) are fully compliant with [17065 certification](#) procedures and DrJ's [scope of expertise](#).

If there are any questions or concerns, we will gladly provide a [professional engineering](#)⁵ and ANAB 17065 accredited [approved agency](#)⁶ response. Pursuant to Section [1707.1](#) and [104.11](#), we would sincerely appreciate knowing the specific building regulations and/or professional engineering law that this 17065 [Research Report](#) does not comply with, so that we can cure any non-conformance⁷. From specifics, we can then delineate a path forward that will serve everyone's free and fair market⁸ competition's best interests.

Our goal with this 17065 evaluation and certification is to provide both the accepted engineering analysis and regulatory compliance substance that supports efficient approval. Please contact us if we can help further in any way. If your request is time-sensitive, please contact Jill Zimmerman at (920) 988-7165. Thank you very much.


Respectfully yours,



Larry Wainright
Vice President Product Certification
608-310-6742



Ryan Dexter, P.E.
Arkansas P.E. No. 14722
Vice President
608-310-6744



This TER is reviewed and sealed by Ryan Dexter, P.E. of DrJ Engineering, LLC, as a specialty or delegated engineer. The scope of engineering work with respect to this TER is for the engineering analysis provided herein, supported by proprietary intellectual property and other substantiating data. No representation extending beyond this analysis is expressed or implied. Information or data that becomes available at a later date may justify modifications to this TER.

¹ All ideas, engineering analysis and test data are proprietary [intellectual property \(IP\)](#) and [trade secrets \(TS\)](#) and should not be provided to anyone. In particular, public regulatory officials are subject to freedom of information act requests -- [federal](#) and state [public records acts](#). This means that IP and TS will be in the public domain when any information is provided. In addition, each state also has legislation that mimics the federal [Defend Trade Secrets Act 2016 \(DTSA\)](#), where providing test reports, engineering analysis and/or other related IP/TS is subject to [prison of not more than 10 years](#) and/or [a \\$5,000,000 fine or 3 times the value](#) of the IP and TS. To follow DTSA and to comply with state public records and trade secret legislation requires approval through [ANAB ISO/IEC 17065 accredited certification bodies](#) or [approved sources](#). For more information, please visit the following websites: <https://www.drjengineering.org/AppendixC> and <https://www.drjcertification.org/cornell-2016-protection-trade-secrets>.

² The scope of work contained herein is limited to the specific engineering and/or code compliance analysis undertaken in this [duly authenticated report](#), which is also known as a technical evaluation, evaluation report, [research report](#), accepted evaluation to a reasonable degree of engineering certainty and so forth. This work has been prepared by an [Approved Source](#), who is a [Registered Design Professional \(RDP\)](#). No representation or warranty is expressed or implied by this [duly authenticated report](#) beyond the scope of work performed. Information, data, and/or analysis that becomes available in the future may justify modifications to this professional evaluation report.

³ Approval of an RDP takes place when the RDP is [properly licensed](#) in the pertinent jurisdiction. [Commercial](#) and [professional engineering laws](#) affirm that the RDP has the ability to [undertake commerce](#) applying engineering principles in their area of expertise without [restraint](#) or [discrimination](#). Ohio has set [legal precedent](#).

⁴ Capitalized terms and responsibilities are defined pursuant to the applicable building code, applicable reference standards, the latest edition of [TPI 1](#), the [NDS](#), [AISI S202](#), [US professional engineering law](#), [Canadian building code](#), [Canada professional engineering law](#) and [Appendix A: Definitions/Commentary](#). Otherwise, terms not defined shall have ordinarily accepted meanings as the context implies.

⁵ [Approved source](#). An independent person, firm or corporation, approved by the building official, who is competent and experienced in the application of engineering principles to materials, methods or systems analyses, which is a professional engineer. To find licensed professional engineers please see this website: <https://www.nspe.org/resources/licensure/licensing-boards>. An [approved source](#) is “approved” when a professional engineer (i.e., [Registered Design Professional \(RDP\)](#)) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the [state legislature](#) via its professional engineering regulations. [Commercial](#) and [professional engineering laws](#) affirm that the RDP has the ability to [undertake commerce](#) applying engineering principles in their area of expertise without [restraint](#) or [discrimination](#). Ohio has set [legal precedent](#).

⁶ An [approved agency](#) shall be objective, competent and independent. Language is found in [Section 1703.1.1](#).

⁷ [Where the alternative material](#), design or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved; Language is found in [Section 104.11](#).

⁸ Competition provides businesses the opportunity to compete on price, quality, innovation, and wages, in an open market and on a level playing field, unhampered by anticompetitive restraints. <https://www.justice.gov/atr/mission>. State statutes by topic can be found here: https://www.law.cornell.edu/wex/unfair_competition. Finally, given that government employees have monopoly approval power they are held to a high standards as it relates to bias in commerce (i.e. discrimination) as found here: <https://www.justice.gov/crt/deprivation-rights-under-color-law>



Listing and Technical Evaluation Report™

Report No: 0910-01



Issue Date: October 20, 2009

Revision Date: May 14, 2024

Subject to Renewal: April 1, 2025

QuickTie™ System (QTS)

Trade Secret Report Holder:

QuickTie™ Products, Inc.

Phone: 904-281-0525

Website: www.quicktieproducts.com

Email: info@quicktieproducts.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES

Section: 06 05 23 - Wood, Plastic, and Composite Fastenings

1 Innovative Products Evaluated¹

1.1 QuickTie™ System (QTS):

- 1.1.1 QTB(L) Blue $\frac{3}{16}$ " QuickTie™
- 1.1.2 QTG(L) Green $\frac{1}{4}$ " QuickTie™
- 1.1.3 QTO(L) Orange $\frac{5}{16}$ " QuickTie™
- 1.1.4 QTR(L) Red $\frac{3}{8}$ " QuickTie™

1.2 Quick Connectors:

- 1.2.1 CS20-250, CS18-200, CS16-150 and CS14-100 Coiled Straps
- 1.2.2 CMST16-54, CMST14-52.5 and CMST12-40 Coiled Straps
- 1.2.3 HA4, HA6, HA8 and HA10 Hurricane and Seismic Anchors
- 1.2.4 HDTT45 and HDTT6 Hold Downs
- 1.2.5 HDTT, HDTT3, HD5, HD7, HD8, HD11, HD14, HD15/20 and HD22 Hold Downs
- 1.2.6 HGA and HGAM Gusset Angles
- 1.2.7 LTT20 Light Tension Tie
- 1.2.8 PHGT2, PHHGT3 and PHHGT4
- 1.2.9 METAS and HETAS Embedded Anchors
- 1.2.10 MS and LS Straps
- 1.2.11 MTS and HTS Twist Straps
- 1.2.12 PBA44, PBA46, PBA66, PBA77 and PBA88 Post Base Anchors
- 1.2.13 PCM and EPCM Post Caps
- 1.2.14 PCS and PCES Post Cap Connectors



- 1.2.15 QGC and QGCW QuickTie™ Girder Connector
- 1.2.16 SC34 and SC35 Framing Angles and SC35F Framing Plate
- 1.2.17 SPArTan™ Sill Plate Anchor
- 1.2.18 TCC16L, TCC16R, TCC21L and TCC21R Drag Strut Connectors
- 1.3 QuickTie™ Screws:
 - 1.3.1 SWH Hex Head Screw
 - 1.3.2 SWF Flat Head Screw
 - 1.3.3 SWT Truss/Stud Screw
 - 1.3.4 SWL Fillister Head Screw

2 Product Description and Materials

2.1 The innovative products evaluated in this Report are shown in **Figure 1** through **Figure 36**.

2.2 QTS Description

2.2.1 The QTS is a wall anchoring system for conventional light-frame construction and masonry projects that involve a Registered Design Professional (RDP).

2.2.1.1 For use of the QTS wall anchoring system in masonry construction, see Report Number 1404-06.

2.2.2 The QTS provides a continuous load path from the top of the wall to the foundation by resisting and transferring wind uplift and/or laterally applied loads that result in overturning uplift forces.

2.2.3 The QTS consists of a galvanized aircraft wire rope (cable) with threaded studs swaged to each end.

2.2.4 Primary Connection (Epoxy):

2.2.4.1 QuickTie cable with threaded stud at the bottom is connected to the foundation via a formed or drilled hole in the foundation. The hole is filled with epoxy and the QuickTie cable is inserted into the hole and left to set.

2.2.4.2 The other end of QuickTie with threaded stud is extended vertically within the wood stud wall to the top of the wall, inserted through a hole drilled through the wood top plate(s) and attached to a steel plate washer using a nut. The nut is tightened to post-tension the QTS.

2.2.5 Alternative Connection (Mechanical):

2.2.5.1 QuickTie cable with threaded stud at the bottom is connected to the foundation via a cast-in-place embedded anchor bolt or embedded steel plate with headed studs. The QuickTie cable is attached to the embedded anchor bolt or steel plate by a mechanical coupling.

2.2.5.2 The other end of QuickTie cable with threaded stud is extended vertically within the wood stud wall to the top of the wall, inserted through a hole drilled through the wood top plate(s) and attached to a steel plate washer using a nut. The nut is tightened to post-tension the QTS.

2.2.6 Trusses, headers, and bottom plates are connected with Quick Connectors (See Section 1.2) to provide distribution of load through the QTS to the foundation.

2.2.7 Where one QuickTie cable does not provide sufficient capacity, multiple cables of the same type may be installed to increase the pre-stressing force and transfer accumulated loads to the foundation.

2.3 QTS – Types and Materials

2.3.1 The QTS consists of the following wood frame QuickTie, QTX(L), where X is the QuickTie type/cable diameter and L is the length in feet:

2.3.1.1 QTB(L) – QuickTie Blue: $\frac{3}{16}$ " diameter made of 7x19, galvanized steel wire rope with a minimum breaking force of 4,200 lb. per ASTM A1023. Refer to **Figure 1** for the details of swaged threaded studs, steel plate washer and nut.




Figure 1. Typical QuickTie Part Detail – QTB(L) Blue $\frac{3}{16}$ " Diameter

2.3.1.2 QTG(L) – QuickTie Green: $\frac{1}{4}$ " diameter made of 7x19 galvanized steel wire rope with a minimum breaking force of 7,000 lb. per ASTM A1023. Refer to **Figure 2** for the details of swaged threaded studs, steel plate washers and nut.




Figure 2. Typical QuickTie Part Detail – QTG(L) Green $\frac{1}{4}$ " Diameter

2.3.1.3 QTO(L) – QuickTie Orange: $\frac{5}{16}$ " diameter made of 7x19, galvanized steel wire rope with a minimum breaking force of 9,800 lb. per ASTM A1023. Refer to **Figure 3** for the details of swaged threaded studs, steel plate washers and nut.




Figure 3. Typical QuickTie Part Detail – QTO(L) Orange $\frac{5}{16}$ " Diameter

- 2.3.1.4 QTR(L) – QuickTie Red: $\frac{3}{4}$ " diameter made of 7x19, galvanized steel wire rope with a minimum breaking force of 14,400 lbs. per ASTM A1023. Refer to **Figure 4** for the details of swaged threaded studs, steel plate washer and nut.




Figure 4. Typical QuickTie Part Detail – QTR(L) Red $\frac{3}{4}$ " Diameter

- 2.3.2 Individual wires of the rope (cable) are 0.030" diameter or smaller, with a minimum $F_u = 268,000$ psi and galvanized with a minimum of 0.10 ounces per square foot of uncoated wire surface.
- 2.3.3 The steel plate washers are made of ASTM A36 or ASTM A653 Grade 33 steel, with a minimum yield and ultimate strengths of 33 ksi and 45 ksi, respectively.
- 2.3.4 The hex nuts are made of SAE J995 Grade 2 or equivalent material.
- 2.3.5 The length of QTS varies in 1" increments from 2' to 62'.
- 2.3.6 **Table 2** lists the allowable tensile loads (ASD basis) of the QTS.
- 2.3.7 *Tension Indicator Device:*
- 2.3.7.1 Tension Indicator Devices (TID) are inserted between the steel plate washer and the hex nut for visually identifying the pre-tension in the cable. TID are made from the following materials:
- 2.3.7.1.1 Blue: ASTM A653, Grade 33 structural steel, 14-gauge, min. thickness 0.0821", painted.
- 2.3.7.1.2 Green: ASTM A653, Grade 33 structural steel, 12-gauge, min. thickness 0.1120", painted.
- 2.3.7.1.3 Orange: ASTM A653, Grade 33 structural steel, 10-gauge, min. thickness 0.1419", painted.
- 2.3.7.1.4 Red: ASTM A653, Grade 33 structural steel, 8-gauge, min. thickness 0.1718", painted.
- 2.3.8 *Quick Connectors Description:*
- 2.3.8.1 Trusses, joists, rafters, headers, beams, studs and plates are connected with manufactured Quick Connector anchors and straps to provide a load path from the roof through to the foundation.
- 2.3.9 *Quick Connectors:*
- 2.3.9.1 *HA4, HA6, HA8, and HA10 Hurricane and Seismic Anchors:*
- 2.3.9.1.1 These 18-gauge (minimum thickness with coating 0.0466") steel clips are used to fasten rafters and trusses to wall top plates. The clips resist uplift loads and forces applied parallel to and perpendicular to the top plates. The HA4 clip is $4\frac{1}{2}$ " long, the HA6 clip is $6\frac{1}{4}$ " long, the HA8 is 8" and the HA10 is $6\frac{1}{2}$ " in length. The clips are manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with a G90 or better zinc coating (**Figure 5** and **Figure 6**). See **Table 3**, **Table 4**, **Table 5** and **Table 6** for fastening schedules and allowable loads.




Figure 5. HA4, HA6 and HA8 Hurricane/Seismic Anchors




Figure 6. HA10 Hurricane/Seismic Anchor

2.3.9.2 LS and MS Series Straps:

2.3.9.2.1 Light Straps (LS) are 20-gauge (minimum thickness with coating 0.0356") steel. Medium Straps (MS) are 16-gauge (0.0575") steel. The straps are manufactured in lengths varying from $9\frac{5}{8}"$ to $48\frac{5}{8}"$. Each strap is $1\frac{1}{4}"$ wide with nail holes punched at intervals of $1\frac{1}{2}"$ along its length. The nail holes are staggered across the width of the strap. At the mid-length of each strap is a 3" long area without any holes. The purpose of this space is to provide a distance of $1\frac{1}{2}"$ between the joint in the wood being joined and the first nail hole on either side of the joint. The last three nails on each end of the strap are spaced $\frac{3}{4}"$ apart and are staggered across the width of the strap. The straps are manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with a G90 or better zinc coating (**Figure 7**). See **Table 7** and **Table 8** for fastening schedules and allowable tension loads.




Figure 7. LS and MS Strap

2.3.9.3 MTS and HTS Series Twist Straps:

- 2.3.9.3.1 The Medium Twist Straps (MTS) are manufactured in a length of 12" and the Heavy Twist Straps (HTS) are manufactured in lengths of 16", 20", 24" and 28". The straps have an offset shape to allow for twisting and bending. Each strap is 1 1/4" wide with nail holes punched at intervals of 1" along its length. The nail holes are staggered across the width of the strap. The MTS12-3Z is 16-gauge (minimum thickness with coating 0.0575"). The HTS16-3Z, HTS20-3Z, HTS24-3Z and HTS28-3Z are 14-gauge (minimum thickness with coating 0.0705"). The straps are manufactured from minimum ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with a G90 or better zinc coating (**Figure 8**). See **Table 9** and **Table 10** for fastening schedules and allowable tension loads.




Figure 8. MTS and HTS Twist Strap

2.3.9.4 CS20-250, CS18-200, CS16-150 and CS14-100 Coiled Straps:

- 2.3.9.4.1 Coiled Straps (CS) are either 20-gauge (minimum thickness with coating 0.0356") steel (CS20-250), 18-gauge (minimum thickness with coating 0.0466") steel (CS18-200), 16-gauge (minimum thickness with coating 0.0575") steel (CS16-150), or 14-gauge (minimum thickness with coating 0.0705") steel (CS14-100). Each strap is 1 1/4" wide with 0.177" diameter nail holes punched at 3/4" intervals along its length. The straps are manufactured from ASTM A653 Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with a G90 or better zinc coating. The CS20-250 is manufactured from a 250' coil, the CS18-200 is manufactured from a 200' coil, the CS16-150 is manufactured from a 150' coil and the CS14-100 is manufactured from a 100' coil (**Figure 9**). See **Table 11**, **Table 12**, **Table 13** and **Table 14** for fastening schedules and allowable tension loads.




Figure 9. CS20-250, CS18-200, CS16-150 and CS14-100 Coiled Straps

2.3.9.5 CMST16-54, CMST14-52.5 and CMST12-40 Coiled Straps:

- 2.3.9.5.1 Coiled Straps (CMST) are either 16-gauge (minimum thickness with coating 0.0575") steel (CMST16-54), 14-gauge (minimum thickness with coating 0.0705") steel (CMST14-52.5), or 12-gauge (minimum thickness with coating 0.0994") steel (CMST12-40). Each strap is 3" wide, with 0.177" diameter nail holes, punched at 1½" intervals along its length (**Figure 10**). The straps are manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with a G90 or better zinc coating. The CMST16-54 is manufactured from a 54' coil, the CMST14-52.5 is manufactured from a 52.5' coil and the CMST12-40 is manufactured from a 40' coil. See **Table 15**, **Table 16** and **Table 17** for fastening schedules and allowable tension loads.




Figure 10. CMST16-54, CMST14-52.5 and CMST12-40 Coiled Straps

2.3.9.6 SC34 and SC35 Framing Angle and SC35F Framing Plate:

- 2.3.9.6.1 The SC34 and SC35 anchor floor and ceiling joists to headers while the SC35F anchors solid blocking to top plates. The SC34 and SC35 use a 90° framing angle to join posts to beams and to make other right-angle connections. The anchors are 18-gauge (0.0466") steel manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with a G90 or better zinc coating (**Figure 11** and **Figure 12**). See the notes in **Table 18**, **Table 19** and **Table 20** for fastening schedules.




Figure 11. SC34 Framing Angle




Figure 12. SC35 Framing Angle and SC35F Framing Plate

2.3.9.7 HGA and HGAM Gusset Angles:

- 2.3.9.7.1 The HGA and HGAM are 90° framing angles used to connect truss/rafter joists to wall top plates (HGA) and the top of masonry walls (HGAM). The HGA and HGAM are 14-gauge (minimum thickness with coating is 0.0705") steel manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with a G90 or better zinc coating (**Figure 13**). The HGA is anchored to the joist with four $\frac{1}{4}$ " diameter x $1\frac{1}{2}$ " long screws and to the top plate with four $\frac{1}{4}$ " diameter x 3" long screws. The HGAM is anchored to the joist with four $\frac{1}{4}$ " diameter x $1\frac{1}{2}$ " long screws and to the masonry block wall with four $\frac{1}{4}$ " x $2\frac{1}{4}$ " concrete screws. See the notes in **Table 21** for minimum screw requirements.




Figure 13. HGA and HGAM Gusset Angle

2.3.9.8 Post Base Anchor (PBA):

- 2.3.9.8.1 Post Base Anchors (PBA) are used to attach the base of a wood post to a concrete foundation. The PBAs are comprised of a Post Base Strap and Stand-Off (SO) Plate (**Figure 14** and **Figure 15**). The SO Plate is designed to provide a 1" clearance between the bottom of the wood post and top of foundation in order to meet IBC Section 2304.12 and IRC Section R317 requirements for protection of wood-based products against decay. The PBA Post Base Strap and SO Plate are 12-gauge steel (minimum thickness with coating is 0.0994"). The PBA66 Post Base Strap is also available in 10-gauge steel (minimum thickness with coating is 0.1250"). The PBA is manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 (min.) zinc coating. See **Table 22** for fastening schedules.




Figure 14. PBA44, PBA46 and PBA66




Figure 15. PBA77 and PBA88

2.3.9.9 SPArtan Sill plate Anchor:

- 2.3.9.9.1 SPArtan Sill Plate Anchors are post-installed anchors used to attach the sill plate of a wood framed wall to a concrete foundation. SPArtan anchors are designed to resist shear and tension loads due to wind and seismic forces. SPArtan anchors are 7.5" long and manufactured from AISI 1018 carbon steel, Hot-Dipped Galvanized (HDG) or equivalent, to meet ASTM A153, Class C. The diameter of the portion of the anchor that embeds in concrete is $\frac{3}{8}$ ". The diameter of the portion of the anchor in contact with the sill plate is $\frac{5}{8}$ " (**Figure 16** and **Figure 17**). SPArtan anchors are compliant with IBC Section 1901.3. See **Table 23** for allowable shear and tension resistance values.




Figure 16. SPArtan Sill Plate Anchor Measurements




Figure 17. SPArtan Sill Plate Anchor Section and Plan Views

2.3.9.10 Post Cap (PCM) and End Post Cap (EPCM):

2.3.9.10.1 PCM and EPCM connectors are used for post-to-beam connection applications. PCM and EPCMs are designed to resist uplift and shear loads due to wind and seismic forces. The PCM and EPCM are 16-gauge (minimum thickness with coating is 0.0575) and 12-gauge (minimum thickness with coating is 0.0994) steel manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 (min.) zinc coating (**Figure 18**). The PCM and EPCM are attached to the post and beam with 16d nails. See **Table 24** for fastener schedules.




Figure 18. Post Cap (PCM) and End Post Cap (EPCM)

2.3.9.11 QuickTie Girder Connector (QGC and QGCW):

2.3.9.11.1 QuickTie Girder Connectors are used for truss and rafter to top plate connections where uplift load design requirements are high, and for stud hold down connections. The QGC is 12-gauge (minimum thickness with coating is 0.0994") steel manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 or better zinc coating (**Figure 19**). The QGC is attached to the top plate with a $\frac{5}{8}$ " threaded rod or QuickTie Orange Cable, QTO(L), and is attached to the truss/rafter with $\frac{1}{4}$ " screws. See **Table 25** for QGC fastener schedules and minimum fastener requirements. See **Table 29** for QGCW fastener schedules and minimum fastener requirements.




Figure 19. QuickTie Girder Connector (QGC and QGCW)

2.3.9.12 Light Tension Tie (LTT20):

- 2.3.9.12.1 Light Tension Tie (LTT) is manufactured in a length of 20". The ties are used to connect wall bottom plates to studs or joist/purlin-to-wall attachment applications. Each strap is 2" wide with nail holes and a 2" x 2¹/₄" x 3³/₁₆" washer is riveted to the base. The LTT is 12-gauge (minimum thickness with coating 0.0994"). The LTT20 is manufactured from minimum ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 or better zinc coating (**Figure 20**). See **Table 26** for fastener schedules.




Figure 20. Light Tension Tie (LTT20)

2.3.9.13 HDTT45 and HDTT6 Hold Down Connectors:

- 2.3.9.13.1 HDTT45 and HDTT6 Hold Down Connectors are used to anchor stud walls into concrete. The HDTT45 and HDTT6 are 10-gauge (minimum thickness with coating is 0.135") steel. HDTT45 is manufactured from ASTM A653 Structural Steel, Grade 40 ($F_u = 55$ ksi, $F_y = 40$ ksi) steel galvanized with G90 or better zinc coating (see **Figure 21**). HDTT6 is manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G90 or better zinc coating (**Figure 22**). The HDTT45 is attached to the bottom plate with a $\frac{5}{8}$ " threaded rod and is attached to the stud with 16d nails. The HDTT6 is attached to the bottom plate with a $\frac{5}{8}$ " threaded rod through a 7-gauge steel washer and is attached to the stud with 16d x $2\frac{1}{2}$ " nails (0.162" x 2.50"). See **Table 27** for fastener schedules and minimum fastener requirements.



Figure 21. HDTT45 Hold Down




Figure 22. HDTT6 Hold Down

2.3.9.14 HDTT, HDTT3, HD5, HD7, HD8, HD11, HD14, HD15/20 and HD22 Hold Downs:

- 2.3.9.14.1 HDTT, HDTT3, HD5, HD7, HD11, HD14, HD15/20 and HD22 Hold Down Connectors are used to anchor stud walls and/or posts into concrete.
- 2.3.9.14.2 The HDTT is 14-gauge (minimum thickness with coating 0.0705") and is manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 or better zinc coating. The HDTT3 is 12-gauge (minimum thickness with coating 0.0994") and is manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 (min.). See **Figure 23** and **Table 28** for fastening schedules and design values.




Figure 23. HDTT and HDTT3 Hold Down

- 2.3.9.14.3 The HD5 is 14-gauge (minimum thickness with coating 0.0705") and is manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 or better zinc coating. See **Figure 24** and **Table 28** for fastening schedules and design values.




Figure 24. HD5 Hold Down

- 2.3.9.14.4 The HD7, HD8 and HD11 are 12-gauge (minimum thickness with coating 0.0994") and are manufactured from ASTM A653 Structural Steel, Grade 50, Class 3 ($F_u = 70$ ksi, $F_y = 50$ ksi) steel galvanized with G185 or better zinc coating. See **Figure 25** and **Table 28** for fastening schedules and design values.




Figure 25. HD7 and HD11 Hold Downs

- 2.3.9.14.5 The HD14 is 7-gauge (minimum thickness with coating is 0.1790") and is manufactured from ASTM A1011, Structural Steel, Grade 33 ($F_u = 52$ ksi, $F_y = 33$ ksi) uncoated steel, spray painted after welding the washer ($\frac{3}{8}$ " thick) to the bottom of the bent strap (offset = 1"). See **Figure 26** and **Table 28** for fastening schedules and design values.




Figure 26. HD14 Hold Down

- 2.3.9.14.6 The HD15/20 is 3-gauge (minimum thickness with coating is 0.239") and is manufactured from ASTM A36 Structural Steel ($F_u = 58$ ksi, $F_y = 36$ ksi) uncoated steel, spray painted after welding the washer ($\frac{3}{8}$ " thick) to the bottom of the bent strap (offset = $3\frac{1}{2}$ "). See **Figure 27** and **Table 28** for fastening schedules and design values.




Figure 27. HD15/20 Hold Down

- 2.3.9.14.7 The HD22 is 7-gauge (minimum thickness with coating is 0.1790") and is manufactured from ASTM A1011 Structural Steel, Grade 33 ($F_u = 52$ ksi, $F_y = 33$ ksi) uncoated steel, spray painted after welding the washer ($\frac{3}{8}$ " thick) to the bottom of the bent strap (offset = $3\frac{1}{2}$ "). See **Figure 28** and **Table 28** for fastening schedules and design values.




Figure 28. HD22 Hold Down

2.3.9.15 METAS/HETAS Embedded Truss Anchor Straps:

- 2.3.9.15.1 The METAS and HETAS are embedded anchors designed to connect truss/rafter joists to the top of Concrete Masonry Unit (CMU) and concrete walls. METAS (18-gauge) and HETAS (16-gauge) embedded anchors are manufactured from ASTM A653 Grade 50, Class 3 Structural Steel ($F_u = 70$ ksi, $F_y = 50$ ksi). See **Figure 29** and **Table 30** for fastening schedules and design values.




Figure 29. METAS and HETAS Embedded Anchor

2.3.9.16 PCS, PCES Post Caps and End Post Caps:

2.3.9.16.1 PCS connectors are post cap connectors used to join center posts to beams. PCES connectors are post cap connectors used to join end posts to beams. PCS and PCES connectors are manufactured from ASTM A653 Grade 50, Class 3 Structure Steel ($F_u = 70$ ksi, $F_y = 50$ ksi). See **Figure 30**, **Table 31** and **Table 32** for fastening schedules and design values.




Figure 30. PCS and PCES Connectors

2.3.9.17 PHGT, Post-Install Girder Tie Downs:

2.3.9.17.1 PHGT2, PHHGT3 and PHHGT4 connectors are tie downs used to join 2-ply, 3-ply or 4-ply girder trusses to wall frames or posts. PHGT connectors are cold-formed from 14-gauge (PHGT2) and 12-gauge (PHHGT3 and PHHGT4) steel with a specified ultimate tensile strength, F_u , of 70 ksi, and a specified yield strength, F_y , of 50 ksi. PHGT connectors are pre-punched for 10d common nails. See **Figure 31** and **Table 33** for fastening schedules and design values.




Figure 31. PHGT and PHHGT Post-install Girder Tie Downs

2.3.9.18 TCC Tension-Compression Drag Strut Connectors:

- 2.3.9.18.1 TCC16L, TCC16R, TCC21L and TCC21R connectors are Tension-Compression drag strut connectors used to transfer lateral forces from a truss to shear walls. TCC connectors are cold formed from 7-gauge (TCC16L and TCC16R) and 3-gauge (TCC21L and TCC21R) steel with a specified ultimate tensile strength, F_u , of 58 ksi, and a specified yield strength, F_y , of 36 ksi. See **Figure 32** and **Table 34** for fastening schedules and design values.




Figure 32. TCC Drag Strut Connectors

2.4 QuickTie Screws

- 2.4.1 QuickTie Screws are manufactured from carbon steel wire using a standard cold-formed process followed by a heat-treating process. All QuickTie Screws have a Dörken® coating. QuickTie Truss Screws (SWT) have an additional teal top coat over the Dörken® coating. All QuickTie screws have been tested and found to exceed the protection provided by code approved hot-dipped galvanized coatings meeting ASTM A153, Class D (IBC Section 2304.10.6² and IRC Section R317.3), allowing for its use in pressure treated wood.

- 2.4.1.1 The SWH screws have a hex head washer and are partially threaded (see **Figure 33**).




Figure 33. SWH Screw

- 2.4.1.2 The SWF screws have a round wafer (flat) head with a T30 star drive and are partially threaded (see **Figure 34**).




Figure 34. SWF Screw

- 2.4.1.3 The SWT screws have a truss head with a T30 star drive and are fully threaded (see **Figure 35**).




Figure 35. SWT Screw

- 2.4.1.4 The SWL screws have a fillister head with a T20 star drive and are partially threaded (see **Figure 36**).




Figure 36. SWL Screw



2.4.1.5 Specifications and mechanical properties of the screws evaluated in this Report are set forth in **Table 1**.

Table 1. Fastener Specifications³

Fastener Name	Part Number	Nominal Length ¹ (in)	Thread Length ² (in)	Head		Diameter (in)				Nominal Bending Yield, F _{yb} (psi)	Allowable Fastener Strength (lbf)	
				Style	Drive System	Head	Shank	Minor	Major		Tensile	Shear ⁴
SWH	SWH15	1½	1¼	Hex Head	¾" Hex	0.540	0.241	0.185	0.254	168,000	1,435	985
	SWH2	2	1¾									
	SWH25	2½	2¼									
	SWH3	3	2¼									
	SWH35	3½	2¾									
	SWH45	4½	3¼									
	SWH5	5	3¼									
	SWH6	6	4¼									
	SWH8	8	3¼									
SWF	SWF278	27/8	2¼	Flat Head	T30 Star Drive	0.750	0.241	0.185	0.280	175,000	1,645	1,145
	SWF338	33/8	2¼									
	SWF358	35/8	2¼									
	SWF45	4½	2¼									
	SWF5	5	2¼									
	SWF6	6	2¼									
	SWF638	63/8	2¼									
	SWF634	6¾	2¼									
	SWF8	8	2¼									
SWT	SWT45	4½	45/16	Truss/Stud	T30 Star Drive	0.330	-	0.160	0.235	190,000	1,160	820
	SWT6	6	513/16									
SWL	SWL15	13/8	11/8	Fillister Head	T20 Star Drive	0.365	-	0.109	0.170	160,000	465	385
	SWL3	27/8	1½									

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psi = 0.00689 MPa

- SWF and SWT fastener length is measured from the top side of the head to the tip. SWH and SWL fastener length is measured from the underside of the head to the tip.
- Thread length excludes the knurl on SWH and SWF. SWT and SWL do not contain a knurl.
- Measurements are based on manufactured thicknesses. Finished dimensions are larger due to the proprietary coatings added.
- Shear strength is determined in accordance with AISI S904 using minor thread diameter when fastener is tested in the threaded section.



- 2.5 Reference lateral design values for shear loads perpendicular to grain and parallel to grain in wood-to-wood connections and steel-to-wood connections are specified in **Table 35** and **Table 36**, respectively.
- 2.6 As needed, review material properties for design in Section 6 and to regulatory evaluation in Section 8.

3 Definitions

- 3.1 New Materials³ are defined as building materials, equipment, appliances, systems, or methods of construction not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.⁴ The design strengths and permissible stresses shall be established by tests⁵ and/or engineering analysis.⁶
- 3.2 Duly Authenticated Reports⁷ and Research Reports⁸ are test reports and related engineering evaluations, which are written by an approved agency⁹ and/or an approved source.¹⁰
 - 3.2.1 These reports contain intellectual property and/or trade secrets, which are protected by the Defend Trade Secrets Act (DTSA).¹¹
- 3.3 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is listed in the ANAB directory.
- 3.4 An approved source is “approved” when a professional engineer (i.e., Registered Design Professional) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.¹²
- 3.5 Testing and/or inspections conducted for this Duly Authenticated Report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body, and/or a licensed Registered Design Professional (RDP).
- 3.5.1 The Center for Building Innovation (CBI) is ANAB¹³ ISO/IEC 17025 and ISO/IEC 17020 accredited.
- 3.6 The regulatory authority shall enforce¹⁴ the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing¹⁵ stating the nonconformance and the path to its cure.
- 3.7 The regulatory authority shall accept Duly Authenticated Reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.¹⁶
- 3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory where recognition of certificates, validation, and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope, shall be approved.¹⁷ Therefore, all ANAB ISO/IEC 17065 Duly Authenticated Reports are approval equivalent.¹⁸
- 3.9 Approval equity is a fundamental commercial and legal principle.¹⁹

4 Applicable Standards for the Listing; Regulations for the Regulatory Evaluation²⁰

4.1 Standards

- 4.1.1 *ACI 318: Building Code Requirements for Structural Concrete and Commentary*
- 4.1.2 *ACI 355.2: Qualification of Post-Installed Mechanical Anchors in Concrete and Commentary*
- 4.1.3 *AISI S100: North American Specification for the Design of Cold-Formed Steel Structural Members*
- 4.1.4 *AISI S904: Test Standard for Determining the Tensile and Shear Strengths of Steel Screws*
- 4.1.5 *AISI S913: Test Standard for Hold-Downs Attached to Cold-Formed Steel Structural Framing*
- 4.1.6 *ANSI/AISC 360: Specification for Structural Steel Buildings*
- 4.1.7 *ANSI/AWC NDS: National Design Specification (NDS) for Wood Construction*
- 4.1.8 *ASCE/SEI 7: Minimum Design Loads and Associated Criteria for Buildings and Other Structure*



- 4.1.9 *ASCE/SEI 19: Structural Applications of Steel Cables for Buildings*
- 4.1.10 *ASTM A36: Standard Specification for Carbon Structural Steel*
- 4.1.11 *ASTM A153: Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*
- 4.1.12 *ASTM A370: Standard Test Methods and Definitions for Mechanical Testing of Steel Products*
- 4.1.13 *ASTM A510: Standard Specification for General Requirements for Wire Rods and Coarse Round Wire, Carbon Steel, and Alloy Steel*
- 4.1.14 *ASTM A653: Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process*
- 4.1.15 *ASTM A1011: Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength*
- 4.1.16 *ASTM A1023: Standard Specification for Carbon Steel Wire Ropes for General Purposes*
- 4.1.17 *ASTM B117: Standard Practice for Operating Salt Spray (Fog) Apparatus*
- 4.1.18 *ASTM D1761: Standard Test Methods for Mechanical Fasteners in Wood*
- 4.1.19 *ASTM D7147: Standard Specification for Testing and Establishing Allowable Loads of Joist Hangers*
- 4.1.20 *ASTM F1575: Standard Test Method for Determining Bending Yield Moment of Nails*
- 4.1.21 *ASTM F1667: Standard Specification for Driven Fasteners: Nails, Spikes, and Staples*
- 4.1.22 *ASTM G85: Standard Practice for Modified Salt Spray (Fog) Testing*
- 4.1.23 *AWC TR 12: General Dowel Equations for Calculating Lateral Connection Values*
- 4.2 **Regulations**
 - 4.2.1 *IBC – 15, 18, 21: International Building Code®*
 - 4.2.2 *IRC – 15, 18, 21: International Residential Code®*
 - 4.2.3 *FBC-B—20, 23: Florida Building Code – Building²¹ (FL 3557 and FL 13468)*
 - 4.2.4 *FBC-R—20, 23: Florida Building Code – Residential^{xxi} (FL 3557 and FL 13468)*
 - 4.2.5 *NCBC—18: North Carolina Building Code*

5 Listed²²

- 5.1 A nationally recognized testing laboratory such as CBI, states that the materials, designs, methods of construction, and/or equipment have met nationally recognized standards and/or have been tested and found suitable for use in a specified manner.

6 Tabulated Properties Generated from Nationally Recognized Standards

- 6.1 The QTS is used to anchor walls and floors to the foundation.
- 6.2 **QTS**
 - 6.2.1 The RDP responsible for the design of the building shall provide a connection to attach the QTS to the foundation. The anchorage shall be sufficient to resist the design loads imposed by uplift and/or overturning plus the pre-stress tension in the cable.
 - 6.2.2 Installation of the QTS to the foundation will depend on the connection design chosen by the RDP. The QTS-to-foundation design considerations include but are not limited to the following:
 - 6.2.2.1 The connection between the QTS and foundation is applied/installed per RDP specifications.

- 6.2.2.2 The QTS is pre-tensioned as specified per the QuickTie published installation instructions. The pre-tensioned level is dependent on the uplift requirements determined by the RDP but shall not exceed the allowable tensile capacity of the QTS listed in Section 9 of this Report.
- 6.2.2.3 In addition to providing positive anchorage for the walls and floors, the pre-tensioning of the QTS provides immediate verification of the adequacy of the connection between the QTS and the foundation, because the initial pre-tension load provides a proof test verification of this connection.
- 6.2.2.4 The RDP shall verify that the structural framing material is adequate to resist the compression forces induced by the pre-stressing of the QTS. In some locations, additional framing or reinforcement may be required.

6.3 Design

6.3.1 QTS:

- 6.3.1.1 **Table 2** lists the allowable tensile loads (based on ASD basis) of the QTS. See **Figure 37** for concrete connection details.

Table 2. Allowable Tensile Loads of the QTS

Cable Type	Cable Diameter (in)	Minimum Edge Distance (c_{a1}) (in)	Minimum Embedment Depth (h_{ef}) (in)	Allowable QTS Tension Loads ^{1,2,3} (lbs)
QTB(L) Blue	$\frac{3}{16}$	$2\frac{1}{4}$	4	1,910
QTG(L) Green	$\frac{1}{4}$	$2\frac{1}{4}$	4	3,180
QTO(L) Orange	$\frac{5}{16}$	3	$6\frac{5}{8}$	4,455
QTR(L) Red	$\frac{3}{8}$	$3\frac{1}{2}$	$7\frac{5}{8}$	6,545

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Allowable QTS loads are based on cables installed in uncracked normal weight concrete with no supplementary reinforcement in accordance with ASCE/SEI 19.
- Minimum end distance (c_{a2}) is 6 inches (See **Figure 37**).
- Minimum 28-day concrete compressive strength is 2,500 psi.




Figure 37. Concrete Connection Detail

- 6.3.1.2 Multiple QTS cables may be used together to transfer the applied load, where one QTS cable is not sufficient. See Figure 38 for details of cable spacing and capacity where multiple QTS cables are used. See Table 2 for embedment depths and edge distance requirements. Maximum rated capacity shown in Figure 38 is for the QTR cables.

MAXIMUM RATED CAPACITY 19,635 LBS

MAXIMUM RATED CAPACITY 13,090 LBS




Figure 38. Anchorage details for multiple cable installation.

- 6.3.1.3 Allowable loads are based on the published strength of the cables per ASTM A1023 using a safety factor of 2.2.
- 6.3.1.4 Construction documents shall include the information required by ASCE/SEI 19 Section 2 (see **Appendix C. ASCE/SEI 19 Section 2 Contract Documents and Shop Drawings**).
- 6.3.1.5 See **Appendix D. Design Loads for QTB(L) and QTG(L)** for additional details on design loads for uplift resistance.
- 6.3.2 *Quick Connector HA4, HA6, HA8 and HA10 Hurricane and Seismic Anchor:*
- 6.3.2.1 Allowable loads and fastener schedules for the HA4 anchor are provided in **Table 3**.
- 6.3.2.2 Allowable loads and fastener schedules for the HA6 anchor are provided in **Table 4**.
- 6.3.2.3 Allowable loads and fastener schedules for the HA8 anchor are provided in **Table 5**.
- 6.3.2.4 Allowable loads and fastener schedules for the HA10 anchors are provided in **Table 6**.

Table 3. HA4 Hurricane and Seismic Anchor Allowable Loads

Species (Specific Gravity)	Fasteners			Allowable Load ^{1,2,3} (lbs)		
				Uplift	Lateral – F1 ⁶	Lateral – F2 ⁷
	Type ^{4,5}	To Rafter/Truss ⁴	To Plates ⁵	Load Duration Factor, C _D : 1.60		
Southern Pine (SP) (0.55)	8d x 1½" (0.131 x 1.5")	5	4	660	180	120
	10d x 1½" (0.148 x 1.5")	5	4	660	180	120
Douglas Fir-Larch (DF-L) (0.50)	8d x 1½" (0.131 x 1.5")	5	4	600	160	120
	10d x 1½" (0.148 x 1.5")	5	4	600	160	120
Spruce-Pine-Fir (SPF) (0.42)	8d x 1½" (0.131 x 1.5")	5	4	515	135	105
	10d x 1½" (0.148 x 1.5")	5	4	515	135	105

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Clips may be installed on both sides of the framing member for twice the load.
3. The tabulated loads are valid for clips installed on the inside or the outside of the wall. However, to maintain a continuous load path for uplift connections in close proximity to one another, such as truss-to-plate and plate-to-stud, clips should be installed on the same side of the wall.
4. Nails attaching clip to rafter or truss are 8d x 1½" (0.131 x 1.5") or 10d x 1½" (0.148 x 1.5") nails.
5. Nails attaching clip to wall plates are 8d (0.131 x 2.5") or 10d (0.148 x 3") nails.
6. Loading in the F1 direction indicates shear forces parallel to the plane of the wall. Refer to manufacturer literature for further details (See **Figure 39**).
7. Loading in the F2 direction indicates shear forces perpendicular to the plane of the wall. Refer to manufacturer literature for further details (See **Figure 39**).




Figure 38. HA4 Load Directions

Table 4. HA6 Hurricane and Seismic Anchor Allowable Loads

Species (Specific Gravity)	Fasteners			Allowable Load ^{1,2,3} (lbs)					
				Uplift	Lateral – F1 ⁴	Lateral – F2 ⁵	Lateral – F3 ⁶	Lateral – F4 ⁷	
	Type	Rafter/Truss	Plates	Load Duration Factor					
				1.00	1.60	1.60			
SP (0.55)	8d x 1½ (0.131 x 1.50")	5	5	535	705	145	140	130	90
DF-L (0.50)				495	665	125	125	125	80
SPF (0.42)				425	575	80	100	80	65

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

8. Refer also to **Appendix B. General Notes for Tables.**
9. Clips may be installed on both sides of the framing member for twice the allowable load capacity.
10. The tabulated loads are valid for clips installed on the inside or the outside of the wall. However, to maintain a continuous load path for uplift connections in close proximity to one another, such as truss-to-plate and plate-to-stud, clips should be installed on the same side of the wall.
11. Loading in the F1 direction indicates shear forces parallel to the plane of the wall, connection to rafter in withdrawal (See **Figure 40**).
12. Loading in the F2 direction indicates shear forces parallel to the plane of the wall, connection to rafter in compression (See **Figure 40**).
13. Loading in the F3 direction indicates shear forces perpendicular to the plane of the wall, connection to top plate in withdrawal (See **Figure 40**).
14. Loading in the F4 direction indicates shear forces perpendicular to the plane of the wall, connection to top plate in compression (See **Figure 40**).




Figure 39. HA6 Load Directions

Table 5. HA8 Hurricane and Seismic Anchor Allowable Loads

Species (Specific Gravity)	Fasteners			Allowable Load ^{1,2,3} (lbs)	
				Uplift	Lateral – F1 ⁶ and F2 ⁷
	Type ^{4,5}	To Rafter/Truss ⁴	To Plates ⁵	Load Duration Factor, C _D : 1.60	
SP (0.55)	8d x 1 1/2 (0.131 x 1.5")	5	5	600	60
	10d x 1 1/2 (0.148 x 1.5")	5	5	815	95
DF-L (0.50)	8d x 1 1/2 (0.131 x 1.5")	5	5	600	60
	10d x 1 1/2 (0.148 x 1.5")	5	5	705	70
SPF (0.42)	8d x 1 1/2 (0.131 x 1.5")	5	5	485	60
	10d x 1 1/2 (0.148 x 1.5")	5	5	540	70

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**

2. Clips may be installed on both sides of the framing member for twice the load.

3. The tabulated loads are valid for clips installed on the inside or the outside of the wall. However, to maintain a continuous load path for uplift, connections in close proximity to one another, such as truss-to-plate and plate-to-stud, clips should be installed on the same side of the wall.

4. Nails attaching clip to rafter or truss are 8d x 1 1/2" (0.131 x 1.5") or 10d x 1 1/2" (0.148 x 1.5") nails.

5. Nails attaching clip to wall plates are 8d (0.131 x 2.5") or 10d (0.148 x 3") nails.

6. Loading in the F1 direction indicates shear forces parallel to the plane of the wall. Refer to manufacturer literature for further details (See **Figure 41**).

7. Loading in the F2 direction indicates shear forces perpendicular to the plane of the wall. Refer to manufacturer literature for further details (See **Figure 41**).




Figure 40. HA8 Load Directions

Table 6. HA10, HA10-2 and HA10R Hurricane and Seismic Anchor Allowable Loads

Species (Specific Gravity)	Fasteners				Allowable Load ^{1,2} (lbs)			
	To Rafter/Truss		To Top Plates		Uplift	Lateral – F1 ²	Lateral – F2 ³	
					Load Duration Factor, C _D			
	Type	Quantity	Type	Quantity	1.0	1.6	1.6	1.6
SP (0.55)	10d x 1½ (0.148 x 1.5")	9	10d x 1½ (0.148 x 1.5")	8	1,005	1,140	560	335
			10d common (0.148 x 3")			1,350		300
DF-L (0.50)		9	10d x 1½ (0.148 x 1.5")	8	930	1,055	515	310
			10d common (0.148 x 3")			1,245		280
SPF (0.42)		9	10d x 1½ (0.148 x 1.5")	8	800	910	335	220
			10d common (0.148 x 3")			1,075		230

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**
2. Loading in the F1 direction indicate shear forces parallel to the plane of the wall, one side of connection to rafter/truss in withdrawal (see **Figure 42**).
3. Loading in the F2 direction indicate shear forces perpendicular to the plane of the wall, connection to top plate in withdrawal (see **Figure 42**).




Figure 41. HA10 Load Directions



6.3.3 Quick Connector LS and MS Series Straps, and MTS and HTS Series Twist Straps:

6.3.3.1 Allowable loads for the LS and MS Straps, and the MTS and HTS Twist Straps are provided in **Table 7** through **Table 10**.

6.3.3.2 The nail sizes and nailing schedules are provided in:

6.3.3.2.1 **Table 7** for the LS Series Straps

6.3.3.2.2 **Table 8** for the MS Series Straps

6.3.3.2.3 **Table 9** for the MTS Series Twist Straps

6.3.3.2.4 **Table 10** for the HTS Series Twist Straps

Table 7. LS Series Strap Allowable Tension Loads

Model Number	Fasteners		Allowable Tension Load ^{1,2,3} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
	Size	Number of Nails Each End of Strap	Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
LS9	8d (0.131 x 2.5")	4	415	665	385	615	330	525
LS12		5	520	830	480	770	410	655
LS18		7	730	1,165	670	1,075	575	920
LS21		8	830	1,295	770	1,230	655	1,050
LS24		9	935	1,295	865	1,295	740	1,180
LS9	10d x 1½ (0.148 x 1.5")	4	500	800	460	735	390	625
LS12		5	625	1,000	575	920	490	785
LS18		7	875	1,295	805	1,290	685	1,100
LS21		8	1,000	1,295	920	1,295	785	1,255
LS24		9	1,125	1,295	1,035	1,295	880	1,295
LS9	10d (0.148 x 3")	4	505	805	465	740	395	635
LS12		5	630	1,010	580	930	495	790
LS18		7	880	1,295	810	1,295	695	1,110
LS21		8	1,010	1,295	930	1,295	790	1,265
LS24		9	1,135	1,295	1,045	1,295	890	1,295

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Refer also to **Appendix B. General Notes for Tables**.
- Allowable tension loads apply for uplift when the straps are installed vertically.
- Allowable tension loads for load durations of two months (i.e., 115%) and seven days (i.e., 125%) may be obtained by multiplying the corresponding allowable tension load in the load duration factor column marked "1.00" by 1.15 or 1.25 respectively, with a maximum of 1,295 lbs.

**Table 8. MS Series Strap Allowable Tension Loads. MS Series Strap Allowable Tension Loads**

Model Number	Fasteners		Allowable Tension Load ^{1,2,3} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
	Size	Number of Nails Each End of Strap	Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
MS24	8d (0.131 x 2.5")	9	980	1,570	910	1,455	785	1,255
MS27		10	1,090	1,745	1,010	1,615	870	1,390
MS30		11	1,200	1,920	1,110	1,780	955	1,530
MS36		13	1,415	2,120	1,315	2,100	1,130	1,810
MS39		14	1,525	2,120	1,415	2,120	1,220	1,950
MS48		14	1,525	2,120	1,415	2,120	1,220	1,950
MS24	10d x 1 1/2 (0.148 x 1.5")	9	1,150	1,845	1,060	1,700	910	1,455
MS27		10	1,280	2,050	1,180	1,890	1,010	1,615
MS30		11	1,410	2,120	1,300	2,075	1,110	1,780
MS36		13	1,665	2,120	1,535	2,120	1,315	2,100
MS39		14	1,790	2,120	1,650	2,120	1,415	2,120
MS48		14	1,790	2,120	1,650	2,120	1,415	2,120
MS24	10d (0.148 x 3")	9	1,180	1,885	1,090	1,740	935	1,500
MS27		10	1,310	2,095	1,210	1,935	1,040	1,665
MS30		11	1,440	2,120	1,330	2,120	1,145	1,830
MS36		13	1,705	2,120	1,575	2,120	1,350	2,120
MS39		14	1,835	2,120	1,695	2,120	1,455	2,120
MS48		14	1,835	2,120	1,695	2,120	1,455	2,120

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**

2. Allowable tension loads apply for uplift when the straps are installed vertically.

3. Allowable tension loads for load durations of two months (i.e., 115%) and seven days (i.e., 125%) may be obtained by multiplying the corresponding allowable tension load in the load duration factor column marked "1.00" by 1.15 or 1.25 respectively, with a maximum of 2,118 lbs.

**Table 9. MTS Twist Strap Allowable Tension Loads**

Model Number	Fasteners			Allowable Load ^{1,2,3} (lbs)					
				SP (0.55)		DF-L (0.50)		SPF (0.42)	
	Type	Min No. of Nails per Strap ⁴	Min No. of Nails at Each End	Load Duration Factor, C _D					
				1.00	1.60	1.00	1.60	1.00	1.60
MTS12-3Z	10d x 1½ (0.148 x 1.5")	14	7	895	1,085	825	1,000	715	865
MTS16-3Z									
MTS20-3Z									
MTS24-3Z									

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**
2. Straps do not have to be wrapped over the truss or rafter to achieve the loads shown.
3. Straps may be installed on either side of the framing member.
4. The number of fasteners shown in the table is the minimum required to achieve the loads shown.

Table 10. HTS Twist Strap Allowable Tension Loads

Model Number	Fasteners			Allowable Load ^{1,2,3} (lbs)					
				SP (0.55)		DF-L (0.50)		SPF (0.42)	
	Type	Min No. of Nails per Strap ⁴	Min No. of Nails at Each End	Load Duration Factor, C _D					
				1.00	1.60	1.00	1.60	1.00	1.60
HTS16-3Z	10d x 1½ (0.148 x 1.5")	22	11	1,445	1,665	1,340	1,540	1,160	1,330
HTS20-3Z									
HTS24-3Z	10d (0.148 x 3")								
HTS28-3Z									

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**
2. Straps do not have to be wrapped over the truss or rafter to achieve the loads shown.
3. Straps may be installed on either side of the framing member.
4. The number of fasteners shown in the table is the minimum required to achieve the loads shown.



6.3.4 Quick Connector CS20-250, CS18-200, S16-150 and CS14-100 Coiled Straps:

6.3.4.1 Allowable loads for the CS20-250, CS18-200, CS16-150 and CS14-100 Coiled Straps are provided in **Table 11** through **Table 14**.

6.3.4.2 The nail sizes and nailing schedules are provided in:

6.3.4.2.1 **Table 11** for the CS20-250

6.3.4.2.2 **Table 12** for the CS18-200

6.3.4.2.3 **Table 13** for the CS16-150

6.3.4.2.4 **Table 14** for the CS14-100

Table 11. CS20-250 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
8d x 1½ (0.131 x 1.5") and 8d Common (0.131 x 2.5")	4	3	415	670	385	615	330	530
	6	4½	625	1,000	575	925	495	795
	8	6	835	1,335	770	1,230	660	1,060
	10	7½	1,045	1,345	960	1,345	830	1,325
	11	8¼	1,145	1,345	1,060	1,345	910	1,345
	12	9	1,250	1,345	1,155	1,345	995	1,345
	13	9¾	1,345	1,345	1,250	1,345	1,075	1,345
	14	10½	1,345	1,345	1,345	1,345	1,160	1,345
	15	11¼	1,345	1,345	1,345	1,345	1,240	1,345
	16	12	1,345	1,345	1,345	1,345	1,325	1,345
	17	12¾	1,345	1,345	1,345	1,345	1,345	1,345
10d x 1½ (0.148 x 1.5") and 10d Common (0.148 x 3")	4	3	505	805	465	745	400	640
	6	4½	755	1,210	695	1,115	600	960
	8	6	1,005	1,345	930	1,345	800	1,280
	9	6¾	1,135	1,345	1,045	1,345	900	1,345
	10	7½	1,260	1,345	1,160	1,345	1,000	1,345
	11	8¼	1,345	1,345	1,275	1,345	1,100	1,345
	12	9	1,345	1,345	1,345	1,345	1,200	1,345
	13	9¾	1,345	1,345	1,345	1,345	1,300	1,345



Table 11. CS20-250 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
	14	10½	1,345	1,345	1,345	1,345	1,345	1,345

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**
2. Allowable tension loads apply for uplift when the straps are installed vertically.
3. The total strap cut length is equal to the Clear Span + 2 x End Length. See **Figure 42** for more detail.

Table 12. CS18-200 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
8d x 1½ (0.131 x 1.5") and 8d Common (0.131 x 2.5")	4	3	425	680	395	630	340	545
	6	4½	640	1,020	590	945	510	815
	8	6	850	1,365	785	1,260	680	1,085
	10	7½	1,065	1,705	985	1,575	850	1,355
	12	9	1,280	1,775	1,180	1,775	1,015	1,630
	14	10½	1,490	1,775	1,375	1,775	1,185	1,775
	16	12	1,705	1,775	1,575	1,775	1,355	1,775
	17	12¾	1,775	1,775	1,670	1,775	1,440	1,775
	18	13½	1,775	1,775	1,770	1,775	1,525	1,775
	19	14¼	1,775	1,775	1,775	1,775	1,610	1,775
	20	15	1,775	1,775	1,775	1,775	1,695	1,775
	21	15¾	1,775	1,775	1,775	1,775	1,775	1,775
10d x 1½	4	3	510	820	475	755	410	650
	6	4½	770	1,230	710	1,135	610	980
	8	6	1,025	1,640	945	1,515	815	1,305
	10	7½	1,280	1,775	1,180	1,775	1,020	1,630



Table 12. CS18-200 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
(0.148 x 1.5") and 10d Common (0.148 x 3")	11	8¼	1,410	1,775	1,300	1,775	1,120	1,775
	12	9	1,535	1,775	1,420	1,775	1,225	1,775
	13	9¾	1,665	1,775	1,535	1,775	1,325	1,775
	14	10½	1,775	1,775	1,655	1,775	1,425	1,775
	15	11¼	1,775	1,775	1,775	1,775	1,530	1,775
	16	12	1,775	1,775	1,775	1,775	1,630	1,775
	17	12¾	1,775	1,775	1,775	1,775	1,730	1,775
	18	13½	1,775	1,775	1,775	1,775	1,775	1,775

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Refer also to **Appendix B. General Notes for Tables.**
- Allowable tension loads apply for uplift when the straps are installed vertically.
- The total strap cut length is equal to the Clear Span + 2 x End Length. See **Figure 42** for more detail.



Table 13. CS16-150 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
8d x 1½ (0.131 x 1.5") and 8d Common (0.131 x 2.5")	4	3	440	700	405	650	350	560
	6	4½	660	1,050	610	970	525	840
	8	6	875	1,405	810	1,295	700	1,120
	10	7½	1,095	1,755	1,015	1,620	875	1,400
	12	9	1,315	2,105	1,215	1,945	1,050	1,680
	14	10½	1,535	2,205	1,420	2,205	1,225	1,960
	16	12	1,755	2,205	1,620	2,205	1,400	2,205
	18	13½	1,975	2,205	1,825	2,205	1,575	2,205
	20	15	2,190	2,205	2,025	2,205	1,750	2,205
	21	15¾	2,205	2,205	2,125	2,205	1,835	2,205
	22	16½	2,205	2,205	2,205	2,205	1,925	2,205
	24	18	2,205	2,205	2,205	2,205	2,100	2,205
	26	19½	2,205	2,205	2,205	2,205	2,205	2,205
10d x 1½ (0.148 x 1.5") and 10d Common (0.148 x 3")	4	3	525	840	485	775	420	670
	6	4½	790	1,260	730	1,165	630	1,005
	8	6	1,050	1,680	970	1,555	840	1,340
	10	7½	1,315	2,100	1,215	1,940	1,045	1,675
	12	9	1,575	2,205	1,455	2,205	1,255	2,010
	14	10½	1,840	2,205	1,700	2,205	1,465	2,205
	16	12	2,100	2,205	1,940	2,205	1,675	2,205
	18	13½	2,205	2,205	2,185	2,205	1,885	2,205
	20	15	2,205	2,205	2,205	2,205	2,095	2,205
	22	16½	2,205	2,205	2,205	2,205	2,205	2,205

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**

2. Allowable tension loads apply for uplift when the straps are installed vertically.

3. The total strap cut length is equal to the Clear Span + 2 x End Length. See **Figure 43** for more detail.



Table 14. CS14-100 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
8d x 1½ (0.131 x 1.5") and 8d Common (0.131 x 2.5")	4	3	455	730	425	675	365	585
	6	4½	685	1,100	635	1,015	550	880
	8	6	915	1,465	845	1,355	730	1,170
	10	7½	1,145	1,830	1,060	1,690	915	1,465
	12	9	1,370	2,195	1,270	2,030	1,100	1,755
	14	10½	1,600	2,560	1,480	2,370	1,280	2,050
	16	12	1,830	2,720	1,690	2,710	1,465	2,345
	18	13½	2,060	2,720	1,905	2,720	1,645	2,635
	20	15	2,285	2,720	2,115	2,720	1,830	2,720
	22	16½	2,515	2,720	2,325	2,720	2,015	2,720
	24	18	2,720	2,720	2,540	2,720	2,195	2,720
	25	18¾	2,720	2,720	2,645	2,720	2,290	2,720
	26	19½	2,720	2,720	2,720	2,720	2,380	2,720
	27	20¼	2,720	2,720	2,720	2,720	2,470	2,720
	28	21	2,720	2,720	2,720	2,720	2,560	2,720
	29	21¾	2,720	2,720	2,720	2,720	2,655	2,720
	30	22½	2,720	2,720	2,720	2,720	2,720	2,720
10d x 1½ (0.148 x 1.5") and 10d Common (0.148 x 3")	4	3	545	870	505	805	435	695
	6	4½	820	1,310	755	1,210	655	1,045
	8	6	1,090	1,745	1,010	1,615	870	1,395
	10	7½	1,365	2,180	1,260	2,015	1,090	1,745
	12	9	1,635	2,615	1,510	2,420	1,305	2,090
	14	10½	1,910	2,720	1,765	2,720	1,525	2,440
	16	12	2,180	2,720	2,015	2,720	1,745	2,720
	18	13½	2,455	2,720	2,270	2,720	1,960	2,720
	20	15	2,720	2,720	2,520	2,720	2,180	2,720
	21	15¾	2,720	2,720	2,645	2,720	2,290	2,720
10d x 1½	22	16½	2,720	2,720	2,720	2,720	2,395	2,720

Table 14. CS14-100 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
(0.148 x 1.5") and 10d Common (0.148 x 3")	23	17 ¹ / ₄	2,720	2,720	2,720	2,720	2,505	2,720
	24	18	2,720	2,720	2,720	2,720	2,615	2,720
	25	18 ³ / ₄	2,720	2,720	2,720	2,720	2,720	2,720

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Refer also to **Appendix B. General Notes for Tables.**
- Allowable tension loads apply for uplift when the straps are installed vertically.
- The total strap cut length is equal to the Clear Span + 2 x End Length. See **Figure 43** for more detail.




Figure 42. Coiled Straps – Total Cut Length



6.3.5 Quick Connector CMST16-54, CMST14-52.5 and CMST12-40 Coiled Straps:

6.3.5.1 Allowable loads for the CMST16-54, CMST14-52.5 and CMST12-40 Coiled Straps are presented in **Table 15** through **Table 17**.

6.3.5.2 The nail sizes and nailing schedules are provided in:

6.3.5.2.1 **Table 15** for the CMST16-54

6.3.5.2.2 **Table 16** for the CMST14-52.5

6.3.5.2.3 **Table 17** for the CMST12-40

Table 15 . CMST16-54 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
10d Common (0.148 x 3")	6	4½	790	1,260	730	1,165	630	1,005
	12	9	1,575	2,520	1,455	2,330	1,255	2,010
	18	13½	2,365	3,780	2,185	3,495	1,885	3,015
	24	18	3,150	5,040	2,910	4,660	2,515	4,020
	30	22½	3,940	5,295	3,640	5,295	3,140	5,025
	36	27	4,725	5,295	4,365	5,295	3,770	5,295
	42	31½	5,295	5,295	5,095	5,295	4,395	5,295
	48	36	5,295	5,295	5,295	5,295	5,025	5,295
	54	40½	5,295	5,295	5,295	5,295	5,295	5,295
16d Common (0.162 x 3.5")	6	4½	935	1,495	860	1,380	745	1,190
	12	9	1,865	2,985	1,725	2,755	1,485	2,380
	18	13½	2,800	4,480	2,585	4,135	2,230	3,565
	24	18	3,730	5,295	3,445	5,295	2,970	4,755
	30	22½	4,665	5,295	4,305	5,295	3,715	5,295
	36	27	5,295	5,295	5,170	5,295	4,460	5,295
	42	31½	5,295	5,295	5,295	5,295	5,200	5,295
	48	36	5,295	5,295	5,295	5,295	5,295	5,295

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Allowable tension loads apply for uplift when the straps are installed vertically.
3. The total strap cut length is equal to the Clear Span + 2 x End Length. See **Figure 43** for more detail.



Table 16. CMST14-52.5 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
10d Common (0.148 x 3")	6	4½	820	1,310	755	1,210	655	1,045
	12	9	1,635	2,615	1,510	2,420	1,305	2,090
	18	13½	2,455	3,925	2,270	3,630	1,960	3,140
	24	18	3,270	5,235	3,025	4,840	2,615	4,185
	30	22½	4,090	6,525	3,780	6,050	3,270	5,230
	36	27	4,905	6,525	4,535	6,525	3,920	6,275
	42	31½	5,725	6,525	5,295	6,525	4,575	6,525
	48	36	6,525	6,525	6,050	6,525	5,230	6,525
	54	40½	6,525	6,525	6,525	6,525	5,885	6,525
	60	45	6,525	6,525	6,525	6,525	6,525	6,525
16d Common (0.162 x 3.5")	6	4½	960	1,540	890	1,425	770	1,230
	12	9	1,925	3,080	1,780	2,845	1,535	2,460
	18	13½	2,885	4,620	2,670	4,270	2,305	3,690
	24	18	3,850	6,160	3,560	5,690	3,075	4,920
	30	22½	4,810	6,525	4,445	6,525	3,840	6,145
	36	27	5,775	6,525	5,335	6,525	4,610	6,525
	42	31½	6,525	6,525	6,225	6,525	5,380	6,525
	48	36	6,525	6,525	6,525	6,525	6,145	6,525
	54	40½	6,525	6,525	6,525	6,525	6,525	6,525

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1.

Refer also to **Appendix B. General Notes for Tables.**

2.

Allowable tension loads apply for uplift when the straps are installed vertically.

3.

The total strap cut length is equal to the Clear Span + 2 x End Length. See **Figure 43** for more detail.



Table 17. CMST12-40 Coiled Straps Allowable Tension Load

Fasteners		Minimum Required End Length ³ (in)	Allowable Tension Load ^{1,2} (lbs)					
			SP (0.55)		DF-L (0.50)		SPF (0.42)	
Size	# Each End of Strap		Load Duration Factor, C _D ²					
			1.00	1.60	1.00	1.60	1.00	1.60
10d Common (0.148 x 3")	6	4½	905	1,450	840	1,340	725	1,165
	12	9	1,810	2,900	1,680	2,685	1,455	2,330
	18	13½	2,715	4,345	2,515	4,025	2,180	3,490
	24	18	3,620	5,795	3,355	5,370	2,910	4,655
	30	22½	4,530	7,245	4,195	6,710	3,635	5,820
	36	27	5,435	8,695	5,035	8,055	4,365	6,985
	42	31½	6,340	9,255	5,870	9,255	5,090	8,150
	48	36	7,245	9,255	6,710	9,255	5,820	9,255
	54	40½	8,150	9,255	7,550	9,255	6,545	9,255
	60	45	9,055	9,255	8,390	9,255	7,275	9,255
	66	49½	9,255	9,255	9,230	9,255	8,000	9,255
	72	54	9,255	9,255	9,255	9,255	8,730	9,255
	78	58½	9,255	9,255	9,255	9,255	9,255	9,255
16d Common (0.162 x 3.5")	6	4½	1,050	1,680	975	1,555	845	1,350
	12	9	2,100	3,365	1,945	3,115	1,685	2,700
	18	13½	3,155	5,045	2,920	4,670	2,530	4,050
	24	18	4,205	6,725	3,890	6,230	3,375	5,395
	30	22½	5,255	8,405	4,865	7,785	4,215	6,745
	36	27	6,305	9,255	5,840	9,255	5,060	8,095
	42	31½	7,355	9,255	6,810	9,255	5,905	9,255
	48	36	8,405	9,255	7,785	9,255	6,745	9,255
	54	40½	9,255	9,255	8,760	9,255	7,590	9,255
	60	45	9,255	9,255	9,255	9,255	8,435	9,255
	66	49½	9,255	9,255	9,255	9,255	9,255	9,255

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Refer also to **Appendix B. General Notes for Tables.**
- Allowable tension loads apply for uplift when the straps are installed vertically.
- The total strap cut length is equal to the Clear Span + 2 x End Length. See **Figure 43** for more detail.



6.3.6 Quick Connector SC34 and SC35 Framing Angles and SC35F Framing Plate:

6.3.6.1 Nail sizes, nail schedule and allowable loads for the SC34 and SC35 Framing Angle and SC35F Framing Plate are provided in **Table 18**, **Table 19** and **Table 20**, respectively.

Table 18. SC34 Framing Angle Allowable Loads

Species (Specific Gravity)	Fasteners		Allowable Load ^{1,2,4,5} (lbs)					
			Load Direction F1		Load Direction F2		Load Direction F3 ³	
	Type	Total	Load Duration Factor, C _D					
			1.00	1.60	1.00	1.60	1.00	1.60
SP (0.55)	8d x 1½ (0.131 x 1.5")	8	425	685	425	685	215	325
DF-L (0.50)	8d x 1½ (0.131 x 1.5")	8	395	630	395	630	170	255
SPF (0.42)	8d x 1½ (0.131 x 1.5")	8	340	545	340	540	110	175

SI: 1 in = 25.4 mm, 1 lb = 4.4575

- Refer also to **Appendix B. General Notes for Tables**.
- Tabulated loads are per connector.
- Connectors are required on both sides of the joist to achieve the F3 loads in both directions.
- When connectors are installed directly across from each other on both sides of the joist, the thickness of the joist should be twice the length of the fastener.
- Refer to **Figure 44** for an illustration of directions F1, F2, and F3.

Table 19. SC35 Framing Angle Allowable Loads

Species (Specific Gravity)	Fasteners		Allowable Load ^{1,2,4,5} (lbs)					
			Load Direction F1		Load Direction F2		Load Direction F3 ³	
	Type	Total	Load Duration Factor, C _D					
			1.00	1.60	1.00	1.60	1.00	1.60
SP (0.55)	10d x 1½ (0.148 x 1.5")	12	755	840	755	1,075	295	295
	10d (0.148 x 3")	12	770	940	770	1,015	260	260
DF-L (0.50)	10d x 1½ (0.148 x 1.5")	12	695	765	695	975	265	265
	10d (0.148 x 3")	12	710	840	710	905	235	235
SPF (0.42)	10d x 1½ (0.148 x 1.5")	12	595	650	595	830	200	230
	10d (0.148 x 3")	12	605	720	605	775	200	200

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Refer also to **Appendix B. General Notes for Tables**.
- Tabulated loads are per connector.
- Connectors are required on both sides of the joist to achieve the F3 loads in both directions.
- When connectors are installed directly across from each other on both sides of the joist, the thickness of the joist should be twice the length of the fastener.
- Refer to **Figure 44** for an illustration of directions F1, F2, and F3.




Figure 43 . Illustration of Load Directions F1, F2, and F3 for the SC34 and SC35 Framing Angle

Table 20. SC35F Framing Plate Allowable Loads

Species (Specific Gravity)	Fasteners		Allowable Load ^{1,2} (lbs)			
			Uplift – F5		Lateral – F4	
	Type	Total	Load Duration Factor, C _D			
			1.00	1.60	1.00	1.60
SP (0.55)	10d x 1½ (0.148 x 1.5")	12	500	500	755	775
	10d (0.148 x 3")	12	550	550	735	735
DF-L (0.50)	10d x 1½ (0.148 x 1.5")	12	430	430	655	655
	10d (0.148 x 3")	12	470	470	615	615
SPF (0.42)	10d x 1½ (0.148 x 1.5")	12	370	370	560	560
	10d (0.148 x 3")	12	400	400	525	525

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**

2. Refer to **Figure 45** for an illustration of directions F4 and F5.




Figure 44. Illustration of Load Directions F4 and F5 for the SC35F Framing Plate



6.3.7 Quick Connector HGA Gusset Angle:

- 6.3.7.1 The screw sizes, screw schedules, and allowable loads for the HGA and HGAM gusset angles are provided in **Table 21**.

Table 21. HGA and HGAM Gusset Angle Allowable Loads

Species (Specific Gravity)	Fasteners ⁵				Allowable Load ¹ (lbs)			
					Uplift	F1 ²	F2 ³	F3 ⁴
	To Rafter/Truss		To Top Plate or Concrete		Load Duration Factor, C _D			
	Type ⁶	Quantity	Type ^{7,8}	Quantity	1.00	1.60	1.60	1.60
DF-L (0.50)	Wood, 1/4" x 1 1/2" (Note 9)	4	Wood, 1/4" x 3" (Note 11)	4	1,085	1,085	895	1,150
			Concrete, 1/4" x 2 1/4" (Note 13)	4	815	1,005	955	1,005
SPF (0.42)	Wood, 1/4" x 1 1/2" (Note 10)	4	Wood, 1/4" x 3" (Note 12)	4	740	695	420	825
			Concrete, 1/4" x 2 1/4" (Note 13)	4	815	805	505	825

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Loading in the F1 direction indicates shear forces parallel to the plane of the wall (**Figure 46**).
3. Loading in the F2 direction indicates shear forces perpendicular to the plane of the wall, acting towards the gusset angle (**Figure 46**).
4. Loading in the F3 direction indicates shear forces perpendicular to the plane of the wall, acting away from the gusset angle (**Figure 46**).
5. Minimum fastener penetration must be equal to the screw length less the thickness of the metal side plate.
6. Minimum Specified Wood Screw Requirements: Major Diameter = 0.25", Minor (Root) Diameter = 0.185", Thread Length (including tip) = 1.25", Bending Yield Strength = 180,000 psi
7. Minimum Specified Wood Screw Requirements: Major Diameter = 0.25", Minor (Root) Diameter = 0.185", Thread Length (including tip) = 2.25", Bending Yield Strength = 180,000 psi
8. Minimum Specified Masonry screws Requirements: Major Diameter = 0.25", Thread Length = 1.75", Min. F_y and F_u = 80,000 psi and 100,000 psi
9. Screw minimum Reference Lateral Design Value (Z) = 182 lbs, Minimum Reference Withdrawal Value (W) = 164 lbs/in
10. Screw minimum Reference Lateral Design Value (Z) = 136 lbs, Minimum Reference Withdrawal Value (W) = 103 lbs/in
11. Screw minimum Reference Lateral Design Value (Z) = 244 lbs, Minimum Reference Withdrawal Value (W) = 179 lbs/in
12. Screw minimum Reference Lateral Design Value (Z) = 210 lbs, Minimum Reference Withdrawal Value (W) = 126 lbs/in
13. Minimum Allowable Tension (T) and Shear (S) Capacities When Installed in Concrete, T = 204 lb and S = 219 lb, Min. Edge Distance = 2", Min. Spacing = 1", Min End Distance = 2.65", Min. Embedment = 1 1/2", Min. Concrete Compression Strength, f_c = 2,500 psi, Load combination 1.2D+1.6L with D = 0.3, L = 0.7 and α = 1.48.




Figure 45. HGAM Load Directions for Wood and Masonry Applications

6.3.8 Quick Connector PBA Post Base Anchor:

6.3.8.1 The PBA Post Base Anchor dimensions, nails schedules, anchor schedules, and allowable loads are provided in **Table 22**.

Table 22. PBA Post Base Anchor Allowable Loads

Species (Specific Gravity)	Part No.	Strap Dimensions (in)			Stand-Off Dimensions (in)			Nominal Post Size	Steel Thickness (gauge)		Fasteners				Allowable Loads ^{1,2,3} (lb)	
		Width (W)	Length (L)	Height (H)	Width (W)	Length (L)	Height (H)		Strap	Stand-Off	Post		Anchor		Bearing C _D = 1.0	Uplift C _D = 1.6
											Qty	Size	Qty	Size		
SP (0.55) or DF-L (0.50)	PBA44	3 ⁹ / ₁₆	3 ¹ / ₂	5 ¹ / ₂	3 ¹ / ₂	3 ⁵ / ₁₆	1	4x4	12	12	12	16d	1	5/8	11,140	2,335
	PBA46	3 ⁹ / ₁₆	5	6	3 ¹ / ₂	4 ³ / ₄	1	4x6	12	12	12	16d	1	5/8	13,000	2,335
	PBA66	5 ¹ / ₂	5	6	5 ⁷ / ₁₆	4 ³ / ₄	1	6x6	12 ⁽⁴⁾	12	12	16d	1	5/8	16,485 ⁴	2,335 ⁴
	PBA77	7 ¹ / ₈	7 ¹ / ₁₆	7 ¹ / ₄	7	6 ⁷ / ₈	1	7x7	12	12	14	16d	2	5/8	16,485	3,590
	PBA88	7 ¹ / ₂	7 ¹ / ₁₆	7 ¹ / ₁₆	7 ³ / ₈	6 ⁷ / ₈	1	8x8	12	12	14	16d	2	5/8	27,065	3,590

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Refer also to **Appendix B. General Notes for Tables**.
- Allowable load values provided are for wet service condition, no further reduction required.
- The square washer shall be installed below the heavy hex nut. The heavy hex nut shall be installed flush with the bottom of the standoff plate. See Section 9 for installation instructions. See **Figure 47** for three-dimensional view of post base installed in concrete.
- With 10-gauge strap, the allowable bearing and uplift loads (C_D = 1.6) are 16,485 lb and 2,545 lb, respectively.




Figure 46. PBA Post Base Anchor
(PBA77 and PBA88 Shown)

6.3.9 Quick Connector SPArtan Sill plate Anchor:

- 6.3.9.1 The SPArtan anchor allowable shear loads for concrete and wood are provided in **Table 23**. See **Figure 48** for load directions. An example of the SPArtan installed in a concrete curb is shown in **Figure 49**.

Table 23. SPArtan Anchor Allowable Shear and Tension Values (ASD) – Concrete and Wood

Applied Load	Allowable Loads ^{1,2,3,4,5,6} (lb)	
	Load Direction	Slab/Curb ^{7,8,9}
Shear	Parallel (F ₁)	1,395
	Perpendicular (F ₂)	665
Tension	Uplift	1,155
	Uplift with Washer ¹⁰	1,705

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Tabulated values are applicable to uncracked concrete and pressure treated Southern Pine #2 lumber.
2. Allowable load values are determined using a conversion factor (α ASD) of 1.6. The conversion factor is based on the controlling load case: $(0.9D + W) / (0.6D + 0.6W)$, where Dead Load (D) = 30% and Wind Load (W) = 70%. Adjustments shall be made where other load combinations control.
3. Anchor design conforms to ACI 318 with no supplementary reinforcement considered.
4. Anchor bending yield strength, $F_{yb} = 100,000$ psi and Concrete dowel bearing strength = 7,500 psi.
5. Allowable loads are provided for a 1.6 load duration (C_D). No further increases are permitted.
6. Allowable loads use a wet service factor $C_M = 0.7$ (MC > 19%). No further reduction required.
7. Minimum edge distance = 2.25 inches. Minimum end distance = 6 inches. Minimum anchor spacing = 6.75 inches. Minimum embedment = 6 inches.
8. Minimum normal weight concrete, with a compressive strength of 2,500 psi.
9. Minimum curb width is 6 inches.
10. Washer size is 2 inch x 2 inch x 1/8 inch.




Figure 47. Sill Plate Anchor Load Directions (F₁ and F₂) - Installation in Slab




Figure 48. Sill Plate Anchor Installation in Concrete Curb

6.3.10 Quick Connector Post Caps (PCM) and End Post Caps (EPCM):

6.3.10.1 The PCM and EPCM dimensions, nails schedules, and allowable loads are provided in **Table 24**.

Table 24. PCM and EPCM Allowable Loads¹

Part Name	Part No.	Member Size		Post Cap Dimensions (in)					Fasteners ²				Allowable Load ^{3,4,5} (lb)					
		Beam	Post	W1	W2	H1	L1	L2	Beam		Post		SP (0.55)			DF-L (0.50)		
									Qty	Size	Qty	Size	Uplift	F1	F2	Uplift	F1	F2
12-gauge Post Cap	PCM44	4x	4x	3 ⁹ / ₁₆	3 ⁹ / ₁₆	3 ⁹ / ₁₆	2 ⁷ / ₁₆	11	12	16d	8	16d	2,120	2,050	1,955	2,085	1,855	1,795
	PCM46		6x		5 ⁹ / ₁₆			13										
	PCM48		8x		7 ⁹ / ₁₆			15										
	PCM64	6x	4x	5 ¹ / ₂	3 ⁹ / ₁₆	3 ¹ / ₂	3 ¹³ / ₁₆	11										
	PCM66		6x		5 ⁹ / ₁₆			13										
	PCM68		8x		7 ⁹ / ₁₆			15										
12-gauge Post Cap	PCM77	7 ¹ / ₈	7 ¹ / ₈	7 ¹ / ₈	7 ¹ / ₈	3 ¹¹ / ₁₆	5 ⁵ / ₈	14 ⁹ / ₁₆	12	16d	8	16d	2,120	2,050	1,955	2,085	1,855	1,795
	PCM84	8x	4x	7 ¹ / ₂	3 ⁹ / ₁₆	3 ³ / ₈	5 ⁵ / ₈	11										
	PCM86		6x		5 ⁹ / ₁₆			13										
	PCM88		8x		7 ⁹ / ₁₆			15										
16-gauge Post Cap	PCM44-16	4x	4x	3 ⁹ / ₁₆	3 ⁹ / ₁₆	3 ⁹ / ₁₆	2 ⁷ / ₁₆	11	12	16d	8	16d	1,875	1,815	1,730	1,845	1,640	1,590
	PCM46-16		6x		5 ⁹ / ₁₆			13										
	PCM48-16		8x		7 ⁹ / ₁₆			15										
	PCM64-16	6x	4x	5 ¹ / ₂	3 ⁹ / ₁₆	3 ¹ / ₂	3 ¹³ / ₁₆	11										
	PCM66-16		6x		5 ⁹ / ₁₆			13										
	PCM68-16		8x		7 ⁹ / ₁₆			15										
	PCM84-16	8x	4x	7 ¹ / ₂	3 ⁹ / ₁₆	3 ¹ / ₂	5 ⁵ / ₈	11										
	PCM86-16	4x	6x	3 ⁹ / ₁₆	5 ⁹ / ₁₆	3 ³ / ₈	2 ⁷ / ₁₆	13										
	PCM88-16		8x		7 ⁹ / ₁₆			15										
	PCM44-16		4x		3 ⁹ / ₁₆			11										
12-gauge	EPCM44	4x	4x	3 ⁹ / ₁₆	3 ⁹ / ₁₆	3 ⁹ / ₁₆	2 ⁷ / ₁₆	7 ¹ / ₄	8	16d	8	16d	2,120	2,050	1,955	2,085	1,855	1,795

Table 24. PCM and EPCM Allowable Loads¹

Part Name	Part No.	Member Size		Post Cap Dimensions (in)					Fasteners ²				Allowable Load ^{3,4,5} (lb)					
		Beam	Post	W1	W2	H1	L1	L2	Beam		Post		SP (0.55)			DF-L (0.50)		
									Qty	Size	Qty	Size	Uplift	F1	F2	Uplift	F1	F2
	EPCM46		6x		5 ⁹ / ₁₆			9 ¹ / ₄										
	EPCM48		8x		7 ⁹ / ₁₆			11 ¹ / ₄										
	EPCM64		4x		3 ⁹ / ₁₆			7 ¹ / ₄										
	EPCM66	6x	6x	5 ¹ / ₂	5 ⁹ / ₁₆	3 ¹ / ₂	3 ¹³ / ₁₆	9 ¹ / ₄										
	EPCM68		8x		7 ⁹ / ₁₆			11 ¹ / ₄										
	EPCM77	7 ¹ / ₈	7 ¹ / ₈	7 ¹ / ₈	7 ¹ / ₈	3 ¹¹ / ₁₆	5 ⁵ / ₈	10 ¹³ / ₁₆										
	EPCM84		4x		3 ⁹ / ₁₆	3 ¹ / ₂		7 ¹ / ₄										
	EPCM86	8x	6x	7 ¹ / ₂	5 ⁹ / ₁₆	3 ³ / ₈	5 ⁵ / ₈	9 ¹ / ₄										
	EPCM88		8x		7 ⁹ / ₁₆	3 ¹ / ₂		11 ¹ / ₄										
16-gauge End Post Cap	EPCM44-16		4x		3 ⁹ / ₁₆			7 ¹ / ₄										
	EPCM46-16	4x	6x	3 ⁹ / ₁₆	5 ⁹ / ₁₆	3 ⁹ / ₁₆	2 ⁷ / ₁₆	9 ¹ / ₄	8	16d	8	16d	1,875	1,815	1,730	1,845	1,640	1,590
	EPCM48-16		8x		7 ⁹ / ₁₆			11 ¹ / ₄										
	EPCM64-16	6x	4x	5 ¹ / ₂	3 ⁹ / ₁₆	3 ¹ / ₂	3 ¹³ / ₁₆	7 ¹ / ₄										
16-gauge End Post Cap	EPCM66-16	6x	6x	5 ¹ / ₂	5 ⁹ / ₁₆	3 ¹ / ₂	3 ¹³ / ₁₆	9 ¹ / ₄										
	EPCM68-16		8x		7 ⁹ / ₁₆			11 ¹ / ₄										
	EPCM84-16		4x		3 ⁹ / ₁₆	3 ¹ / ₂		7 ¹ / ₄	8	16d	8	16d	1,875	1,815	1,730	1,845	1,640	1,590
	EPCM86-16	8x	6x	7 ¹ / ₂	5 ⁹ / ₁₆	3 ³ / ₈	5 ⁵ / ₈	9 ¹ / ₄										
	EPCM88-16		8x		7 ⁹ / ₁₆	3 ¹ / ₂		11 ¹ / ₄										

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**
2. Nails designated as 16d shall be 16d common nails (0.162" x 3.5", F_y = 90,000 psi).
3. Allowable load values provided are for wet service condition and for a load duration factor (C_D) of 1.60, no further reduction required.
4. Loading in the F1 direction indicates shear forces parallel to the beam (**Figure 50**).
5. Loading in the F2 direction indicates shear forces perpendicular to the beam (**Figure 50**).




Figure 49. PCM and EPCM Load Directions (Uplift, F1 and F2)



6.3.11 Quick Connector QuickTie Girder Connector (QGC):

6.3.11.1 Allowable uplift and lateral loads, and fastener schedules for the QGC are provided in **Table 25**.

Table 25. QGC Allowable Loads¹

Species (Specific Gravity)	Fasteners				Allowable Load ^{2,3} (lbs)					
	Rafter/Truss		Top Plates		Uplift		Lateral – F1		Lateral – F2	
					Load Duration Factor, C _D					
	Type ^{4,5,6}	Quantity	Type ^{7,8,9}	Quantity	1.0	1.6	1.0	1.6	1.0	1.6
SP (0.55)	1/4" x 3" (wood screw)	16 ¹⁰	QTO	1	4,350	4,455	1,665	2,040	935	935
			5/8" TR			5,445	770	1,235	480	770
DF-L (0.50)			QTO		4,015	4,455	1,630	1,910	885	885
			5/8" TR			5,085	740	1,185	440	705
SPF (0.42)			QTO		3,465	4,390	1,370	1,570	765	765
			5/8" TR			4,455	685	1,090	345	550
SP (0.55)	32 ¹¹	QTO or 5/8" TR	2	8,715	8,715	-				
DF-L (0.50)				8,450	8,450					
SPF (0.42)				7,295	7,295					

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Loading in the F1 direction indicates shear forces parallel to the plane of the wall, connection to truss/rafter in withdrawal (see **Figure 50**).
3. Loading in the F2 direction indicates shear forces perpendicular to the plane of the wall, connection to truss/rafter in shear (see **Figure 50**).
4. Minimum specified screw requirements: Major diameter = 0.24", Minor (root) diameter = 0.185", Thread length (including tip) = 2.25" and Bending yield strength = 180,000 psi
5. Minimum reference lateral design value for wood screws, Z = 272 lb (SP), 251 lb (DF-L) and 217 lb (SPF)
6. Minimum reference withdrawal value for wood screws, W = 168 lb (SP), 132 lb (DF-L) and 86 lb (SPF)
7. The minimum allowable tensile strength of QTO (5/16" QuickTie Orange Cable) is 4,455 lbs and threaded rod is 5,445 lbs.
8. QTO cable shall be installed per QuickTie installation instructions. 5/8" threaded rod and nut at top shall be finger tight at a minimum.
9. QTO cable or threaded rod shall be installed before connecting QGC to truss/rafter.
10. Tabulated values are applicable to a single sided connection, as shown in **Figure 51**.
11. Tabulated values are applicable to a double-sided connection, as shown in **Figure 52**. Tabulated values are for uplift only and require two (2) 2x6 members as truss or header to achieve tabulated values.




Figure 50. QGC Load Directions
(Uplift, F1 and F2)




Figure 51. QGC Double Sided Connection

6.3.12 Quick Connector Light Tension Tie (LTT):

6.3.12.1 Allowable uplift loads and fastener schedules for the LTT20 are provided in **Table 26**. The LTT20 in the installed condition is shown in **Figure 53**.

Table 26. LTT20 Allowable Loads

Species (Specific Gravity)	Fasteners				Allowable Load ^{1,2,3} (lbs)	
	Nail		Anchor Bolt ^{4,5}		Uplift	
	Type	Quantity	Type	Quantity	1.0	1.6
SP (0.55)	10d x 1 1/2 (0.148 x 1.5")	10	3/4" diameter	1	1,515	1,680
DF-L (0.50)					1,405	1,575
SPF (0.42)					1,220	1,375

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Allowable loads based on connector attached to 2x4 member from 1" above the base (i.e., no resistance from prying action).
3. Total deflection of connector assembly at allowable loads are 0.194" (SP), 0.186" (DF-L), and 0.172" (SPF).
4. Anchor bolt installation into any substrates should be designed to resist the allowable uplift loads.
5. Washer size is 2 1/4" x 2" x 3/16" with a 13/16" diameter hole.




Figure 52. Installed LTT20

6.3.13 Quick Connector HDTT45 and HDTT6 Hold Down:

6.3.13.1 Allowable uplift loads and fastener schedules for HDT45 and HDTT6 are provided in **Table 27**. The HDTT45 and HDTT6 in the installed condition is shown in **Figure 54**.

Table 27. HDTT45 and HDTT6 Allowable Loads

Species (Specific Gravity)	Fasteners				Allowable Load ^{1,3} (lbs)			
	Nail		Rod ⁴		HDTT45 ⁵		HDTT6 ²	
					Floor	Roof	Floor	Roof
	Type	Quantity	Type	Quantity	1.0	1.6	1.0	1.6
SP/DF-L (0.50)	16d x 2½ (0.162 x 2.5")	26	5/8" diameter	1	4,480	6,155	4,480	5,480
HF/SPF (0.42)					3,900	5,650	3,900	4,895

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Refer also to **Appendix B. General Notes for Tables**.
- Connector deflection is limited to 0.145" (SP/DF-L).
- Minimum wood member size is 3" x 3.5" (2x4, 2-ply)
- The nut on the 5/8" anchor shall be installed finger tight plus approximately two turns to achieve the tabulated loads.
- Connector deflection is limited to 0.082" (SP/DF-L).




Figure 53. Installed HDTT45 (Left) and HDTT6 (Right)



6.3.14 Quick Connectors HDTT, HDTT3, HD5, HD7, HD11, HD14, HD15/20 and HD22 Hold Downs:

6.3.14.1 Allowable uplift loads for Hold Down Connectors are provided in **Table 28**.

Table 28. Hold Down Allowable Loads^{1,2,3}

Part No.	Steel Gauge	Species	Min Wood Size ³ (in)	Dimensions (in)				Fasteners				Uplift (lb)		
								Screw/Bolt		Anchor Bolt ²		Load Duration Factor, C _D		
				Height H	Width W	Depth D	Stud Face to Anchor CL	Type	Qty	Size	Qty	1.0	1.6	Δ (1.6)
HDTT	14-gauge	SP (0.55)	1.5 x 3.5	6 ⁷ / ₈	3 ¹ / ₄	1 ³ / ₄	1	SWH15	8	1/2"	1	1,715	2,300	0.190
		DF-L (0.50)										1,455	2,055	0.149
		HF/SPF (0.42)										1,080	1,525	0.088
HDTT3	12-gauge	SP (0.55)	3 x 3.5	6 ⁷ / ₈	3 ¹ / ₄	1 ³ / ₄	1	SWH3	8	1/2"	1	2,170	3,475	0.074
		DF-L (0.50)										2,005	3,210	0.067
		HF/SPF (0.42)										1,730	2,770	0.055
HD5	14-gauge	SP (0.55)	3 x 3.5	8 ³ / ₄	3	3	1 ³ / ₈	SWH3	10	1/2"	1	5,240	5,885	0.197
		DF-L (0.50)										5,240	5,445	0.181
		HF/SPF (0.42)										2,080	2,080	0.059
HD7	12-gauge	SP (0.55)	3 x 3.5	10 ³ / ₄	3	3	1 ³ / ₈	SWH3	14	7/8"	1	6,750	7,280	0.102
		DF-L (0.50)										6,750	6,980	0.098
		HF/SPF (0.42)										3,025	4,845	0.069
HD8	12-gauge	SP (0.55)	3 x 5.5	12 ³ / ₄	3	3	1 ³ / ₈	SWH3	18	7/8"	1	8,390	8,390	0.065
		DF-L (0.50)										7,755	7,755	0.058
		HF/SPF (0.42)										3,955	6,325	0.043



Table 28. Hold Down Allowable Loads^{1,2,3}

Part No.	Steel Gauge	Species	Min Wood Size ³ (in)	Dimensions (in)				Fasteners				Uplift (lb)		
								Screw/Bolt		Anchor Bolt ²		Load Duration Factor, C _D		
				Height H	Width W	Depth D	Stud Face to Anchor CL	Type	Qty	Size	Qty	1.0	1.6	Δ (1.6)
HD11	12-gauge	SP (0.55)	3 x 3.5	15 ³ / ₄	3	3	1 ³ / ₈	SWH3	24	7/8"	1	12,120	12,755	0.139
		DF-L (0.50)										12,120	12,755	0.139
		HF/SPF (0.42)										5,195	8,310	0.085
HD14 ⁴	7-gauge	SP (0.55)	3.5 x 5.5	18 ³ / ₄	3	3 ¹ / ₂	1 ¹ / ₂	SWH3	30	1"	1	10,500	14,120	0.095
		DF-L (0.50)										10,500	14,060	0.095
		HF/SPF (0.42)										6,980	11,170	0.075
HD 15/20 ^{5,6}	3-gauge	SP (0.55)	3 x 7.25	25	3 ¹ / ₄	3 ¹ / ₂	2 ¹ / ₈	1"	5	1 ¹ / ₄ "	1	10,740	15,895	0.102
		DF-L (0.50)										9,847	15,635	0.100
		HF/SPF (0.42)										8,410	13,460	0.082
HD 15/20 ^{5,6}	3-gauge	SP (0.55)	5.5 x 5.5	25	3 ¹ / ₄	3 ¹ / ₂	2 ¹ / ₈	1"	5	1 ¹ / ₄ "	1	14,845	20,065	0.087
		DF-L (0.50)										14,220	20,065	0.087
		HF/SPF (0.42)										13,125	19,695	0.086
HD22 ⁵	7-gauge	SP (0.55)	3.5 x 5.5	24 ¹ / ₂	3 ¹ / ₈	3 ⁷ / ₈	2	SWH3	36	1 ¹ / ₄ "	1	15,660	22,245	0.087
		DF-L (0.50)										15,660	20,115	0.078
		HF/SPF (0.42)										8,925	14,280	0.053

**Table 28.** Hold Down Allowable Loads^{1,2,3}

Part No.	Steel Gauge	Species	Min Wood Size ³ (in)	Dimensions (in)				Fasteners				Uplift (lb)		
								Screw/Bolt		Anchor Bolt ²		Load Duration Factor, C _D		
				Height H	Width W	Depth D	Stud Face to Anchor CL	Type	Qty	Size	Qty	1.0	1.6	Δ (1.6)

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Anchor bolt installation into any substrates should be designed to resist the allowable uplift loads.
3. Hold-downs shall be installed into the wide face of the wood member in order to achieve the tabulated allowable load values.
4. Bend washer ($\frac{3}{8}$ ") welded to bend strap around perimeter with 1" offset from the base.
5. Bend washer ($\frac{3}{8}$ ") welded to bend strap around perimeter with 3 $\frac{1}{2}$ " offset from the base.
6. Minimum bolt requirements: bending yield strength = 45,000 psi and dowel bearing strength, F_{es} = 87,000 psi.

6.3.15 Quick Connector QuickTie Girder Connectors as a Hold Down (QGCW):

6.3.15.1 Allowable uplift loads and fastener schedules for the QGCW are provided in **Table 29**.

Table 29. QGCW Allowable Loads¹

Species (Specific Gravity)	Fasteners				Minimum Stud/Joist Size and Quantity Required		Allowable Load ^{7,8} (lb)
	Stud/Joist		Anchor Bolt				Uplift
	Type ^{2,3}	Quantity	Type ^{4,5,6}	Quantity	Size	Quantity	1.6
SP (0.55)	1/4" x 3" (wood screw)	16	5/8" TR	1	2x4	2	4,300
DF-L (0.50)							4,295
SPF (0.42)							3,705

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Minimum specified screw requirements: Major diameter = 0.24", Minor (root) diameter = 0.185", Thread length (including tip) = 2.25" and Bending yield strength = 180,000 psi
3. Minimum reference lateral design value for wood screws, Z = 272 lb (SP), 251 lb (DF-L) and 217 lb (SPF)
4. Anchor bolt installation into any substrates should be designed to resist the allowable uplift loads. The minimum allowable tensile strength of threaded rod shall meet or exceed the allowable loads listed above.
5. 5/8" threaded rod and nut at top shall be finger tight at a minimum.
6. Threaded rod shall be installed before connecting QGCW to stud/joist. The QGCW shall be installed with at least 3" edge distance to the bottom of the stud.
7. Tabulated values are applicable to a hold down connection, as shown in **Figure 55**.
8. Deflection measured at allowable load: 0.228 (SP), 0.227 (DF-L), and 0.188 (HF/SPF).




Figure 54. Installed QGCWs

6.3.16 METAS and HETAS Embedded Truss Anchor Straps:

6.3.16.1 Allowable loads for embedded anchors are provided in **Table 30**.

Table 30. METAS and HETAS Allowable Loads¹

Part		Fasteners		Allowable Loads (lb) - Southern Pine ($C_D = 1.6$) ^{2,3,4,5,6,7,8}											
				Single Anchor						Double Anchor					
No.	Length (in.)	Type	Qty	CMU			Concrete			CMU			Concrete		
				Uplift	F1	F2	Uplift	F1	F2	Uplift	F1	F2	Uplift	F1	F2
METAS12	12	10d x 1 1/2" (0.148 x 1.50")	7	1,445	340	760	1,445	340	760	2,890	1,335	1,140	2,890	1,335	1,140
METAS16	16		9	1,600	440	760	1,600	440	760	3,195	1,375	1,140	3,195	1,375	1,140
METAS18	18														
METAS20	20														
METAS24	24														
METAS40	40														
HETAS12	12	10d x 1 1/2" (0.148 x 1.50")	7	1,475	340	760	1,475	340	760	2,950	1,335	1,140	2,950	1,335	1,375
HETAS16	16		9	1,895	440	760	1,895	440	760	3,324	1,375	1,140	3,175	1,405	1,375
HETAS20	20														
HETAS24	24														
HETAS40	40														

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Allowable loads are provided for load duration factor (C_D) of 1.6. No further increase is permitted.
3. Minimum specified compressive strength of grout is 2,000 psi.
4. Minimum specified compressive strength of concrete is 2,500 psi.
5. Loading in the F1 direction indicates shear forces parallel to the plane of the concrete/CMU wall.
6. Loading in the F2 direction indicates shear forces perpendicular to the plane of the concrete/CMU wall.
7. Minimum edge distance for CMU installation is 2 in.
8. Minimum edge distance for concrete installation is 1.5 in.




Figure 55. Installed METAS/HETAS Embedded Anchors

6.3.17 PCS and PCES Post Cap Connectors:

6.3.17.1 Dimensions for PCS and PCES connectors are provided in **Table 31** and **Figure 57**.

6.3.17.2 Allowable uplift and lateral loads for PCS and PCES connectors are provided in **Table 32**.

Table 31. PCS and PCES Dimensions

Part No.	Steel Thickness	Dimensions				
		Width	Length		Height	
			L1 (in.)	L2 (in.)	H1 (in.)	H2 (in.)
PCS44	18-gauge	$1\frac{3}{8}$	$3\frac{9}{16}$	$6\frac{1}{4}$	$2\frac{5}{8}$	$2\frac{7}{8}$
PCS44R		$1\frac{1}{2}$	4	7		
PCS66		$1\frac{1}{4}$	$5\frac{1}{2}$	8		
PCS66R		$1\frac{1}{2}$	6	9		
PCES44		$1\frac{1}{2}$	$3\frac{1}{4}$	$4\frac{3}{4}$	$2\frac{3}{8}$	$2\frac{3}{4}$
PCES66			$5\frac{1}{2}$	7		$2\frac{1}{8}$

SI: 1 in = 25.4 mm, 1 lb = 4.45 N




Figure 56. PCS and PCES Dimensions

Table 32. Uplift and Lateral Design Values for PCS and PCES Connectors

Part No.	Fasteners			Allowable Loads (lb) ^{1,2,3}					
				SP		DF-L		HF/SPF	
	Size	Quantity		Uplift	F1	Uplift	F1	Uplift	F1
		Beam	Post						
PCS44	16d (0.162" x 3.5")	12	12	2,935	2,175	2,295	1,950	2,295	1,870
PCS44R									
PCS66									
PCS66R									
PCES44		12	12	1,955	1,500	1,800	1,220	1,550	1,090
PCES66									
		12	12	1,645	1,205	1,520	925	1,310	835

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables.**
2. Allowable loads and fastener size/quantity provided are for a pair of post caps.
3. Allowable loads are provided for a load duration factor (C_D) of 1.6. No further increase is permitted.




Figure 57. Installed PCS and PCES Connectors

6.3.18 PHGT Girder Tie Downs:

6.3.18.1 Allowable uplift and lateral design values for PHGT2, PHHGT3, and PHHGT4 connectors are provided in **Table 33**.

Table 33. Uplift and Lateral Design Values for PHGT Connectors

Part No.	Fasteners				Allowable Loads (lb) ^{1,2,3,4}								
	Rafter/Truss		Stud/Top Plate		SP			DF-L			HF/SPF		
	Type	Qty	Type	Qty	Uplift	F1	F2	Uplift	F1	F2	Uplift	F1	F2
PHGT2	10d Common	16	10d common	18	2,435	980	255	2,435	900	255	2,240	745	210
PHHGT3	SWH3	12	10d common	26	3,355	1,230	410	3,130	1,230	360	2,710	1,060	280
PHHGT4	SWH3	16	10d common	37	4,185	2,230	590	3,625	1,825	510	4,185	2,230	590

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.
2. Loading in the F1 direction indicates shear forces parallel to the plane of the wall, connection to truss/rafter in withdrawal (see **Figure 59**).
3. Loading in the F2 direction indicates shear forces perpendicular to the plane of the wall, connection to truss/rafter in shear (see **Figure 59**).
4. Allowable loads are provided for a load duration factor (C_D) of 1.6. No further increase is permitted.




Figure 58. Installed PHHGT3 Connector

6.3.19 TCC Tension-Compression Drag Strut Connectors:

6.3.19.1 Allowable compression and tension design values for TCC16L/R and TCC21L/R connectors are provided in **Table 34**.

Table 34. Compression and Tension Design Values for TCC Connectors

Part No.	Fasteners				Allowable Loads (lb) ^{1,2}					
	Rafter/Truss		Stud/Top Plate		SP		DF-L		HF/SPF	
	Type	Qty	Type	Qty	Compression	Tension	Compression	Tension	Compression	Tension
TCC16L/R	SWH3	10	SWH3	10	2,600	3,890	2,410	3,605	2,095	3,130
TCC21L/R	SWH3	12	SWH3	12	4,370	5,780	4,370	5,500	3,920	4,720

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Refer also to **Appendix B. General Notes for Tables**.

2. Allowable loads are provided for a load duration factor (C_D) of 1.6. No further increase is permitted.




Figure 59. Installed TCC16 Connector



6.3.20 QuickTie Screws:

- 6.3.20.1 QuickTie Screws are used to attach wood framing members in conventional light-frame constructions and to provide resistance against withdrawal, head pull-through, axial and shear loads.
- 6.3.20.2 The design of QuickTie Screws is governed by the applicable code and the provisions for dowel-type fasteners in NDS.
- 6.3.20.3 QuickTie Screws are installed without lead holes as prescribed in NDS.
- 6.3.20.4 Reference lateral design values for shear loads perpendicular to grain and parallel to grain in wood-to-wood connections and steel-to-wood connections are specified in **Table 35** and **Table 36**, respectively.

Table 35. Reference Lateral Design Values (Z) for Connections in Sawn Lumber

Fastener Name	Part Number	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁴ (in)	Reference Lateral Shear Value ^{1,2,3} Z (lbf)	
						Wood Species (Specific Gravity)	
						SP/DF-L (0.50) ³	
						Z	Z _⊥
SWH	SWH3	3	2 ¹ / ₄	1.5	1.5	420	330
	SWH35	3 ¹ / ₂	2 ³ / ₄				
	SWH45	4 ¹ / ₂	3 ¹ / ₄				
	SWH5	5	3 ¹ / ₄	1.5	3.5	500	330
	SWH6	6	4 ¹ / ₄				
	SWH8	8	3 ¹ / ₄				
SWF	SWF278	2 ⁷ / ₈	2 ¹ / ₄	1.5	1.2	425	330
	SWF338	3 ³ / ₈	2 ¹ / ₄				
	SWF358	3 ⁵ / ₈	2 ¹ / ₄				
	SWF45	4 ¹ / ₂	2 ¹ / ₄	1.5	1.5	420	330
	SWF5	5	2 ¹ / ₄				
	SWF6	6	2 ¹ / ₄				
	SWF638	6 ³ / ₈	2 ¹ / ₄				
	SWF634	6 ³ / ₄	2 ¹ / ₄				
	SWF8	8	2 ¹ / ₄				
SWT	SWT45	4 ¹ / ₂	4.3	1.5	3	295 ⁵	
	SWT6	6	5.8				
SWL	SWL3	2 ⁷ / ₈	1 ¹ / ₂	1.5	1.38	240	85



Table 35. Reference Lateral Design Values (Z) for Connections in Sawn Lumber

Fastener Name	Part Number	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁴ (in)	Reference Lateral Shear Value ^{1,2,3} Z (lbf)	
						Wood Species (Specific Gravity)	
						SP/DF-L (0.50) ³	
						Z	Z _⊥
SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/in = 0.175 kN/m							
3. Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the fastener is oriented perpendicular to grain, unless otherwise noted.							
4. Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.							
5. Z _⊥ = Lateral Design Values Perpendicular to Grain, Z = Lateral Design Values Parallel to Grain.							
6. Fastener main member penetration is the length embedded in the main member, including the tip.							
7. Value is applicable where the main member is loaded parallel to grain and the side member is loaded perpendicular to grain.							

Table 36. Reference Lateral Design Values (Z) for Connections with Steel Side Plate

Fastener Name	Minimum Side Member Thickness ⁴ (in)	Minimum Main Member Penetration ³ (in)	Reference Lateral Shear Value ^{1,2} Z (lb)	
			Wood Species (Specific Gravity)	
			SP/DF-L (0.50) ²	
			Z	Z _⊥
SWH15	0.075 (14-gauge)	1.425	180	145
	0.105 (12-gauge)	1.395	195	160
	0.120 (11-gauge)	1.380	205	165
	0.134 (10-gauge)	1.366	215	175
	0.179 (7-gauge)	1.321	240	195
	0.239 (3-gauge)	1.261	240	195
SWH2	0.075 (14-gauge)	1.925	225	180
	0.105 (12-gauge)	1.895	240	195
	0.120 (11-gauge)	1.880	250	200
	0.134 (10-gauge)	1.866	260	210
	0.179 (7-gauge)	1.821	285	230
	0.239 (3-gauge)	1.761	285	230
SWH25	0.075 (14-gauge)	2.425	230	185
	0.105 (12-gauge)	2.395	255	205
	0.120 (11-gauge)	2.380	265	215



Table 36. Reference Lateral Design Values (Z) for Connections with Steel Side Plate

Fastener Name	Minimum Side Member Thickness ⁴ (in)	Minimum Main Member Penetration ³ (in)	Reference Lateral Shear Value ^{1,2} Z (lb)	
			Wood Species (Specific Gravity)	
			SP/DF-L (0.50) ²	
			Z	Z _⊥
	0.134 (10-gauge)	2.366	280	220
	0.179 (7-gauge)	2.321	315	250
	0.239 (3-gauge)	2.261	315	250
SWH3 SWH35 SWH45	0.075 (14-gauge)	2.925	710	595
	0.105 (12-gauge)	2.895	730	615
	0.120 (11-gauge)	2.880	740	625
	0.134 (10-gauge)	2.866	750	630
	0.179 (7-gauge)	2.821	780	660
	0.239 (3-gauge)	2.761	780	660
SWH5 SWH6 SWH8	0.075 (14-gauge)	4.925	825	820
	0.105 (12-gauge)	4.895	790	815
	0.120 (11-gauge)	4.880	775	810
	0.134 (10-gauge)	4.866	760	810
	0.179 (7-gauge)	4.821	710	800
	0.239 (3-gauge)	4.761	710	800
SWL15 SWL3	0.048 (18-gauge)	1.330	330	310

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/in = 0.175 kN/m

1. Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
2. Z_⊥ = Lateral Design Values Perpendicular to Grain, Z_{||} = Lateral Design Values Parallel to Grain.
3. Fastener main member penetration is the length embedded in the main member, including the tip.
4. Tabulated allowable shear values apply to assemblies having a wood main member with a specific gravity of at least 0.50 and a steel side plate with an ultimate tensile strength of at least 65 ksi.



6.3.20.5 Reference withdrawal design values (lb/in) and maximum withdrawal values (lb) are specified in **Table 37**.

Table 37. Reference Withdrawal Design Values, lb/in and Maximum Withdrawal Values

Fastener Name	Part Number	Nominal Length (in)	Thread Length (in)	Withdrawal Design Value ^{1,2} W (lb/in)		Max. Withdrawal Design Value ^{1,2} (lb)
				Thread Penetration Includes Tip	Thread Penetration Excludes Tip	
				Wood Species (Specific Gravity)		
				SP/DF-L (0.50)		
SWH	SWH15	1½	1¼	310	390	405
	SWH2	2	1¾			600
	SWH25	2½	2¼			795
	SWH3	3	2¼			990
	SWH35	3½	2¾			1,180
	SWH45	4½	3¼			1,435
	SWH5	5	3¼			1,180
	SWH6	6	4¼			
	SWH8	8	3¼			
SWF	SWF278	2⅞	2¼	340	480	935
	SWF338	3⅜	2¼			
	SWF358	3⅝	2¼			
	SWF45	4½	2¼			
	SWF5	5	2¼			
	SWF6	6	2¼			
SWF	SWF638	6⅜	2¼	340	480	935
	SWF634	6¾	2¼			
	SWF8	8	2¼			
SWT	SWT45	4½	4.3	335	-	940
	SWT6	6	5.8			940
SWL	SWL15	1⅜	1⅞	225	-	250
	SWL3	2⅞	1½			335

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/in = 0.175 kN/m

1.

Tabulated withdrawal values (W) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.

2.

Minimum fastener penetration into main member of 1" is required. Fastener penetration is the threaded length embedded in the main member.



6.3.20.6 Reference head pull-through design values are specified in **Table 38**.

Table 38. Reference Head Pull-Through Design Values

Fastener Name	Head Diameter (in)	Head Pull-Through Design Value ^{1,2} P (lb)
		Wood Species (Specific Gravity)
		SP/DF-L (0.50)
SWH	0.540	790
SWF	0.750	1,210
SWL	0.365	430
SI: 1 in = 25.4 mm, 1 lb = 4.45 N 1. Tabulated pull-through values (P) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1. 2. Pull-through design values apply to connections having a minimum wood side member thickness of at least 1.5".		

6.3.21 SWT6 Truss-to-Plate Connection Design Values:

6.3.21.1 SWT6 fasteners are used in the construction of walls that meet the requirements of IBC Section 2308 or IRC Section R602 for the following applications:

6.3.21.1.1 To attach minimum 1 1/2" thick wood trusses, rafters or floor joists to wood walls.

6.3.21.1.2 To attach minimum 1 1/2" thick gable end trusses to wood walls.

6.3.21.1.3 To attach minimum 1 1/2" thick valley trusses to wood walls.

6.3.21.1.4 To attach minimum 1 1/2" thick wood studs to wall top and bottom plates.

6.3.21.2 Walls shall consist, at a minimum, of a single or double top plate installed in accordance with IBC Section 2308.5.3.2 or IRC Section R602.3.2.

6.3.21.3 SWT6 fasteners are used in buildings requiring design in accordance with IBC Section 1609 or wind analysis in accordance with IRC Section R301.2.1.

6.3.21.4 SWT6 fasteners are used in buildings requiring design in accordance with IBC Section 1613 or seismic analysis in accordance with IRC Section R301.2.2.

6.3.21.5 To maintain a continuous uplift load path, connections in the same area must be stacked on the same side of the wall (i.e., rafter to top plate connection and top plate to stud connection).

6.3.21.6 Allowable design loads for uplift and lateral resistance for truss, rafter, and joist to top plate connections are provided in **Table 39**.

6.3.21.7 Allowable design loads are applicable to fasteners installed in accordance with **Table 39**.

Table 39. Allowable Uplift and Lateral Loads for SWT6 Screw in Truss/Rafter/Joist to Top Plate Connections

Fastener Designation	Min. Penetration into Truss/Rafter/Joist ¹ (in)	Top Plate	Fastener Angle to Vertical ⁵	Allowable Loads ^{2,3} (lb)		
				Uplift	F1	F2
				Wood Species ⁴ (Specific Gravity)		
				SP (0.55)		
SWT6	2 1/2	Double	22.5°	940	360	705
			0°	940	530	500

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

1. Wood truss, rafter, or floor joist members shall be a minimum of 2" nominal thickness. Design of truss, rafter, or floor joist is by others.
2. Includes 1.6 duration of load increase for wind and seismic. No further duration of load increases permitted. Reduce design values for other load durations as applicable.
3. See **Figure 61** for load directions.
4. Equivalent specific gravity of Structural Composite Lumber (SCL) shall be equal to or greater than the specific gravities provided in this table. Refer to product information from SCL manufacturer.
5. Install fastener at an upward angle from the vertical of 20° to 25° (22.5° is optimal) or 0° (see **Figure 62**). For installation between 20° and 25°, design values for 22.5° may be used.




Figure 60. Truss/Rafter/Joist to Double top Plate - Uplift and Lateral Load (F1 and F2) Directions




Figure 61. Installation of Fasteners in Truss/Rafter/Joist to Double Top Plate Connections

6.3.21.8 Allowable design loads for uplift and lateral resistance for gable end truss to top plate connections are provided in **Table 40**.

6.3.21.9 Allowable design loads are applicable to fasteners installed in accordance with **Table 40**.

Table 40. Allowable Uplift and Lateral Loads for SWT6 Screw in Gable End Truss to Top Plate Connections

Fastener Designation	Min. Penetration into Gable End Truss (in) ¹	Top Plate	Fastener Angle to Vertical ⁵	Allowable Loads ^{2,3} (lb)		
				Uplift	F1	F2
				Wood Species ⁴ (Specific Gravity)		
				SP (0.55)		
SWT6	3	Double	0°	940	650	565

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

- Gable end truss bottom chord shall be a minimum of 2" nominal thickness. Design of truss, rafter, or floor joist is by others.
- Includes 1.6 duration of load increase for wind and seismic. No further duration of load increases permitted. Reduce design values for other load durations as applicable.
- See **Figure 63** for load directions.
- Equivalent specific gravity of SCL shall be equal to or greater than the specific gravities provided in this table. Refer to product information from SCL manufacturer.
- Install fastener at an upward angle from the vertical of 0°. Fastener edge distance is 3/4" (see **Figure 64**).




Figure 62. Gable End Truss to Top Plate - Uplift and Lateral Load (F1 and F2) Directions




Figure 63. Gable End Truss to Top Plate Installation Configuration

6.3.21.10 Allowable design loads for uplift and lateral resistance for valley truss connections are provided in **Table 41**.

6.3.21.11 Allowable design loads are applicable to fasteners installed in accordance with **Table 41**.

Table 41. Allowable Uplift Load for SWT6 Screw in Valley Truss Connection

Fastener Designation	Min. Penetration into Main Member (in)	Fastener Angle to Vertical ¹	Allowable Uplift Load ^{2,3,4} (lb)
			Wood Species ⁵ (Specific Gravity)
			SP (0.55)
SWT6	2	0°	675

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

1. Install fastener at an angle from the vertical of 0° with the fastener centered on the truss members (see **Figure 65**).
2. Truss members shall be a minimum of 2" nominal thickness. Sheathing may be installed between the truss members, as shown in **Figure 65**.
3. Lower truss member may have a maximum 6:12 pitch. A minimum 2" penetration into the main member is required (see **Figure 65**).
4. Includes 1.6 duration of load increase for wind and seismic. No further duration of load increases permitted. Reduce design values for other load durations as applicable.
5. Equivalent specific gravity of SCL shall be equal to or greater than the specific gravities provided in this table. Refer to product information from SCL manufacturer.




Figure 64. Valley Truss Connection

6.3.22 SWT45 Stud to Plate Connection Design Values:

6.3.22.1 Allowable design loads for uplift and lateral resistance in stud to plate connections for fasteners installed in the narrow face of the stud are provided in **Table 42**.

6.3.22.2 Allowable design loads are applicable to fasteners installed in accordance with **Table 42**.

Table 42. Allowable Design Values for Stud to Plate Connections, Fastener Installed in Narrow Face

Fastener Designation ¹	Nominal Plate Thickness ²	Allowable Loads ^{3,4} (lb)	
		Uplift	Lateral (F2) ⁵
		Wood Species (Specific Gravity)	
		SP (0.55)	
SWT45	2x	565	405

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

1. Fastener shall be installed at an angle between 20° - 30°. 22° is optimal (see **Figure 65**).
2. Dimensional lumber members shall be a minimum of 2" nominal thickness.
3. Includes 1.6 duration of load increase for wind and seismic. No further duration of load increases permitted. Reduce design values for other load durations as applicable.
4. Limit: one fastener installed in the narrow face of each stud.
5. The lateral load direction (F2) is perpendicular to the face of the wall.




Figure 65. Fastener Installed in Narrow Face of Stud

6.4 The allowable loads provided in this report are for the QTS, QuickTie Connectors, and QuickTie Screws only. The adequacy of the connected structural framing members to resist the loads applied to them by the QuickTie products, building type and occupancy and/or the environment shall be verified in accordance with the requirements of the building code adopted by the jurisdiction in which the project is to be constructed.

6.4.1 Portal Frame with Hold-Downs (PFH):

- 6.4.1.1 Use of Method PFH shall be in accordance with IRC Section R602.10 and IRC Section R602.10.6.2.
- 6.4.1.2 The maximum allowable tensile loads (based on Allowable Stress Design) of the QTS are presented in **Table 2**.
- 6.4.1.3 Two (2) QuickTie Orange cables shall be used to meet the required two (2) 3,500 lb. hold-downs, with one (1) QuickTie Orange on each side of the pier. QuickTie Blue cables shall be used on the non-pier end of the portal frame where only a single 1,000 lb. hold-down is required. The detail below using QTS is considered equivalent to the Method PFH detail of the IRC (**Figure 67** and **Figure 68**).




Figure 66. Diagram for Portal Frame with QuickTie Cables

MODIFIED TABLE R602.10.6.4 TENSION STRAP CAPACITY FOR RESISTING WIND PRESSURES PERPENDICULAR TO METHOD PFH															
MINIMUM WALL STUD FRAMING NOMINAL SIZE AND GRADE	MAXIMUM PONY WALL HEIGHT (feet)	MAXIMUM TOTAL WALL HEIGHT (feet)	MAXIMUM OPENING WIDTH (feet)	ADJACENT TO QUICKTIE ORANGE CABLE						ADJACENT TO QUICKTIE BLUE CABLE					
				TENSION STRAP CAPACITY REQUIRED (pounds) ^{a,b,c}						TENSION STRAP CAPACITY REQUIRED (pounds) ^{a,b,c}					
				Ultimate Design Wind Speed V_{ue} (mph)						Ultimate Design Wind Speed V_{ue} (mph)					
				110	115	130	110	115	130	110	115	130	110	115	130
				Exposure B			Exposure C			Exposure B			Exposure C		
2 x 4 No. 2 Grade	0	10	18	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
			9	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	750
	1	10	16	NR	NR	NR	NR	NR	450	NR	NR	1,050	1,075	1,500	2,950
			18	NR	NR	NR	NR	NR	DR	NR	275	1,375	1,400	1,850	DR
	2	10	9	NR	NR	NR	NR	NR	NR	NR	NR	475	500	875	2,125
			16	NR	NR	NR	NR	625	DR	775	1,175	2,525	2,550	3,125	DR
	2	12	18	NR	NR	450	475	DR	DR	1,075	1,500	2,950	2,975	DR	DR
			9	NR	NR	NR	NR	NR	DR	150	500	1,650	1,675	2,175	DR
	2	12	16	NR	NR	DR	DR	DR	DR	1,875	2,375	DR	DR	DR	DR
			18	NR	475	DR	DR	DR	DR	2,425	2,975	DR	DR	DR	DR
	4	12	9	NR	NR	DR	DR	DR	DR	1,275	1,750	DR	DR	DR	DR
			12	NR	275	DR	DR	DR	DR	2,225	2,775	DR	DR	DR	DR
2 x 6 Stud Grade	2	12	9	NR	NR	NR	NR	NR	NR	NR	NR	700	700	1,025	2,050
			16	NR	NR	NR	NR	175	DR	825	1,150	2,225	2,225	2,675	DR
			18	NR	NR	225	250	DR	DR	1,200	1,550	2,725	2,750	DR	DR
	4	12	9	NR	NR	NR	NR	NR	DR	450	750	1,700	1,725	2,125	DR
			16	NR	NR	DR	DR	DR	DR	1,050	1,400	DR	DR	DR	DR
			18	NR	300	DR	DR	DR	DR	2,350	2,800	DR	DR	DR	DR

For SI: 1 inch = 25.4 mm, 1 mile per hour = 0.447 m/s

a. DR = Design Required

b. Straps shall be installed in accordance with manufacturer's recommendations.

c. NR = Not Required

Figure 67. Design Parameters for Portal Frame with QuickTie Cables

6.5 Reference Lateral Design Values for Deck Ledger to Stud Attachment

6.5.1 Without Gypsum Wallboard (GWB) Interlayer:

6.5.1.1 Installation details for ledger to stud connections without GWB for 2x6, 2x8, 2x10 and 2x12 ledgers are shown in **Figure 69**, **Figure 70**, **Figure 71** and **Figure 72**, respectively.

6.5.1.1.1 Distances shown in **Figure 69**, **Figure 70**, **Figure 71** and **Figure 72** are ideal. See Table 44 for minimum edge and end distance requirements.




Figure 68. 2x6 Ledger Directly Attached to Stud




Figure 69. 2x8 Ledger Directly Attached to Stud




Figure 70. 2x10 Ledger Directly Attached to Stud




Figure 71. 2x12 Ledger Directly Attached to Stud

6.5.2 With One Layer GWB Interlayer:

6.5.2.1 Installation details for ledger to stud connections with a single layer of GWB for 2x6, 2x8, 2x10 and 2x12 ledgers are shown in **Figure 73**, **Figure 74**, **Figure 75** and **Figure 76**, respectively.

6.5.2.1.1 Distances shown in **Figure 73**, **Figure 74**, **Figure 75** and **Figure 76** are ideal. See Table 44 for minimum edge and end distance requirements.




Figure 72. 2x6 Ledger Attached to Stud through One Layer of GWB




Figure 73. 2x8 Ledger Attached to Stud through One Layer of GWB




Figure 74. 2x10 Ledger Attached to Stud through One Layer of GWB




Figure 75. 2x12 Ledger Attached to Stud through One Layer of GWB

6.5.3 With Two Layers GWB Interlayer:

6.5.3.1 Installation details for ledger to stud connections with a double layer of GWB for 2x6, 2x8, 2x10 and 2x12 ledgers are shown in **Figure 77**, **Figure 78**, **Figure 79** and **Figure 80**, respectively.

6.5.3.1.1 Distances shown in **Figure 77**, **Figure 78**, **Figure 79** and **Figure 80** are ideal. See Table 44 for minimum edge and end distance requirements.




Figure 76. 2x6 Ledger Attached to Stud through Two Layers of GWB




Figure 77. 2x8 Ledger Attached to Stud through Two Layers of GWB




Figure 78. 2x10 Ledger Attached to Stud through Two Layers of GWB




Figure 79. 2x12 Ledger Attached to Stud through Two Layers of GWB

6.5.4 Allowable loads for deck ledger to stud connections installed with QuickTie SWH screws detailed in **Figure 69** through **Figure 80**, are provided in **Table 43**.

6.5.4.1 Allowable loads are designated per stud connection, which refers to the specified number of SWH screws shown in **Figure 69** through **Figure 80**.

6.5.4.1.1 A 2x6 ledger requires two SWH screws at each stud location.

6.5.4.1.2 A 2x8 ledger requires three SWH screws at each stud location.

6.5.4.1.3 A 2x10 ledger requires three SWH screws at each stud location.

6.5.4.1.4 A 2x12 ledger requires four SWH screws at each stud location.

Table 43. Design Values for ledger to Stud Attachment

Fastener Designation	Nominal Fastener Length ⁶	Minimum Penetration into Main Member (in)	Layers of GWB ⁵	Nominal Ledger Species	Nominal Stud Species	Allowable Load per Stud Connection ^{2,3,4} (lb)			
						Ledger Size ¹			
						2x6	2x8	2x10	2x12
SWH3	3	1½	0	SPF (0.42)	SPF (0.42)	310	465	465	620
SWH35	≥ 3½	2	0			355	535	535	715
SWH35	3½	1¾	1			220	330	330	440
SWH4	≥ 4	1⅞	1			260	385	385	515
SWH4	4	1¼	2			150	225	225	300
SWH5	≥ 5	2¼	2			190	280	280	375



Table 43. Design Values for ledger to Stud Attachment

Fastener Designation	Nominal Fastener Length ⁶	Minimum Penetration into Main Member (in)	Layers of GWB ⁵	Nominal Ledger Species	Nominal Stud Species	Allowable Load per Stud Connection ^{2,3,4} (lb)			
						Ledger Size ¹			
						2x6	2x8	2x10	2x12
SWH3	3	1½	0	SPF (0.42)	DF-L (0.50)	360	540	540	720
SWH35	≥ 3½	2	0			380	565	565	755
SWH35	3½	1¾	1			255	385	385	510
SWH4	≥ 4	1⅞	1			265	400	400	535
SWH4	4	1¼	2			180	265	265	355
SWH5	≥ 5	2¼	2			195	290	290	385
SWH3	≥ 3	1½	0	SPF (0.42)	SP (0.55)	390	580	580	775
SWH35	≥ 3½	1¾	1			270	405	405	540
SWH4	≥ 4	1¼	2			195	295	295	390
SWH3	3	1½	0	DF-L (0.50)	SPF (0.42)	355	535	535	710
SWH35	≥ 3½	2	0			430	645	645	860
SWH35	3½	1¾	1			230	340	340	455
SWH4	≥ 4	1⅞	1			280	420	420	560
SWH4	4	1¼	2			155	230	230	305
SWH5	≥ 5	2¼	2			195	290	290	385
SWH3	3	1½	0	DF-L (0.50)	DF-L (0.50)	425	640	640	850
SWH35	≥ 3½	2	0			460	690	690	920
SWH35	3½	1¾	1			275	410	410	545
SWH4	≥ 4	1⅞	1			295	440	440	585
SWH4	4	1¼	2			180	275	275	365
SWH5	≥ 5	2¼	2			200	295	295	395
SWH3	3	1½	0	DF-L (0.50)	SP (0.55)	465	695	695	925
SWH35	≥ 3½	2	0			475	710	710	950
SWH35	≥ 3½	1¾	1			300	450	450	600



Table 43. Design Values for ledger to Stud Attachment

Fastener Designation	Nominal Fastener Length ⁶	Minimum Penetration into Main Member (in)	Layers of GWB ⁵	Nominal Ledger Species	Nominal Stud Species	Allowable Load per Stud Connection ^{2,3,4} (lb)			
						Ledger Size ¹			
						2x6	2x8	2x10	2x12
SWH4	≥ 4	1 1/4	2			200	300	300	400
SWH3	3	1 1/2	0	SP (0.55)	SPF (0.42)	365	550	550	730
SWH35	≥ 3 1/2	2	0			430	670	670	890
SWH35	3 1/2	1 3/8	1			230	345	345	465
SWH4	≥ 4	1 7/8	1			285	430	430	570
SWH4	4	1 1/4	2			155	230	230	310
SWH5	≥ 5	2 1/4	2			195	295	295	390
SWH3	3	1 1/2	0	SP (0.55)	DF-L (0.50)	440	660	660	880
SWH35	≥ 3 1/2	2	0			490	735	735	980
SWH35	3 1/2	1 3/8	1			280	415	415	555
SWH4	≥ 4	1 7/8	1			300	450	450	600
SWH4	4	1 1/4	2			185	275	275	365
SWH5	≥ 5	2 1/4	2			200	300	300	400
SWH3	3	1 1/2	0	SP (0.55)	SP (0.55)	490	735	735	975
SWH35	≥ 3 1/2	2	0			510	770	770	1,025
SWH35	≥ 3 1/2	1 3/8	1			310	460	460	615
SWH4	≥ 4	1 1/4	2			205	305	305	405

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Two fasteners are required for 2x6 ledger connections. Three fasteners are required for 2x8 and 2x10 ledger connections. Four fasteners are required for 2x12 ledger connections. Additional fasteners prohibited.
- Allowable loads shall be limited to parallel-to-grain loaded solid sawn main members (minimum 2" nominal). Wood side members shall be loaded perpendicular to grain.
- Allowable loads are shown at the wood load duration factor of $C_D = 1.00$. Loads may be increased for load duration as permitted by the building code up to a $C_D = 1.60$. All adjustment factors shall be applied per NDS. For in-service moisture content greater than nineteen percent (19%), use Wet Service Factor (C_M) = 0.70.
- Fasteners shall be centered in the stud and spaced as shown in **Figure 69** through **Figure 80**.
- GWB must be attached as required per the building code.
- Where designated as, '≥ Fastener Length,' allowable loads per stud connection are applicable to fasteners with lengths greater than or equal to the specified length. Fastener shall not penetrate through the stud depth.



- 6.6 Where the application falls outside of the performance evaluation, conditions of use and/or installation requirements set forth herein, alternative techniques shall be permitted in accordance with accepted engineering practice and experience. This includes but is not limited to the following areas of engineering: mechanics or materials, structural, building science, and fire science.

7 Certified Performance²³

- 7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.²⁴
- 7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.²⁵

8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 QTS complies with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
- 8.1.1 Structural performance of connectors under uplift and lateral load conditions.
 - 8.1.2 Compliance for use in buildings assigned to Seismic Design Categories A through F.
 - 8.1.3 QuickTie Screws were tested and evaluated to determine their structural resistance properties, which were used to develop reference design values for Allowable Stress Design (ASD). The following properties were evaluated:
 - 8.1.3.1 Bending yield in accordance with ASTM F1575
 - 8.1.3.2 Tensile and shear strengths in accordance with AISI S904
 - 8.1.3.3 Lateral shear, withdrawal and head pull-through strengths in accordance with ASTM D1761
 - 8.1.4 QuickTie SWT Screws were evaluated:
 - 8.1.4.1 As an alternate means of attaching metal plate connected wood trusses, rafters or floor joists to the tops of walls to provide uplift and lateral load resistance. The fasteners were evaluated for shear strength, withdrawal strength and head pull-through strength for use as an alternative to toenail connections, hurricane and seismic clips/straps or nails in tension (uplift) load applications.
 - 8.1.4.2 As an alternative means of attaching wall studs to top and bottom plates. The fasteners were evaluated for shear strength, withdrawal strength and head pull-through strength for use as an alternative to toenail connections.
 - 8.1.4.3 For lateral strength of ledger connections to wood-framed walls. This applicable includes zero, one, or two layers of 5/8" GWB between the ledger and the wall studs.
 - 8.1.5 Compliance for use as an alternative to the Portal Frame with Hold-Down (PFH) as prescribed in [IRC Section R602.10.6.2](#).
 - 8.1.6 SWH screws were evaluated for corrosion resistance in accordance with ASTM B117 and ASTM G85.
 - 8.1.6.1 Corrosion resistance for all other QuickTie Screws is outside the scope of this report.
- 8.2 Any building code, regulation, and/or accepted engineering evaluations (i.e., research reports, duly authenticated reports, etc.) that are conducted for this Listing were performed by DrJ Engineering, LLC (DrJ), an [ISO/IEC 17065 accredited certification body](#) and a professional engineering company operated by [RDP/approved sources](#). DrJ is qualified²⁶ to practice product and regulatory compliance services within its scope of accreditation and engineering expertise, respectively.

- 8.3 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which are also its areas of professional engineering competence.
- 8.4 Any regulation specific issues not addressed in this section are outside the scope of this Report.

9 Installation

- 9.1 QTS and Quick Connectors shall be installed in accordance with the approved construction documents, the manufacturer installation instructions, this Report, and the applicable building code.
- 9.1.1 Refer to the specific product sections of this Report as applicable.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this Report, the more restrictive shall govern.
- 9.3 A copy of the manufacturer published installation instructions shall be available at all times on the jobsite during installation.
- 9.4 *SPArtan Sill Plate Anchor Installation*
- 9.4.1 Clean the top surface of sill plate and mark the SPArtan anchor location(s).
- 9.4.2 Use a rotary hammer drill and SPArtan stepped drill bit (sold by QuickTie Products, Inc., see **Figure 81** and **Figure 82**) to drill a hole in the sill plate. Stop and remove wood dust as necessary (see Section 9.5.3).




Figure 80. Proprietary SPArtan Drill Bit
(Supplied by QuickTie Products, Inc.)




Figure 81. Installation of SPArtan

- 9.4.3 Once the drill bit hits concrete, take precaution not to overwork the drill and/or drill bit. Intermittently, stop and clean concrete dust from the hole. If necessary, use compressed air (or other means) to remove debris around hole. Stop drilling when the wood bit stopper hits the top surface of sill plate. Over drilling may damage the carbide tips of wood bit.



- 9.4.4 Install SPArten anchor using an impact gun with square drive bit. Stop once the anchor flange hits the top surface of sill plate. *NOTE:* Appropriate Personal Protection Equipment (PPE) must be worn.

9.5 *PBA (Post Base Anchor) Installation*

- 9.5.1 Use all fasteners as specified in **Table 22** to achieve the full capacity.
- 9.5.2 The designer or specifier shall check the requirements and capacity of wood post and concrete (embedment, edge distance and end distance) for resisting uplift loads.
- 9.5.3 Nails (16d common) and fastener assembly ($\frac{5}{8}$ " threaded rod with heavy hex nut, or anchor bolt and washer ($2\frac{3}{4}$ " x $2\frac{3}{4}$ " x $\frac{3}{8}$ ") are not included.
- 9.5.4 Clean concrete surface, place PBA Strap, and install fastener assembly.
- 9.5.5 Place standoff plate and then the wood post. The top of the heavy hex nut must be installed flush with underside of standoff plate with a square washer below the hex nut.
- 9.5.6 Use specified fasteners to attach wood post to PBA Strap.

9.6 *QuickTie Girder Connector (QGC)*

- 9.6.1 The QTO cable shall be installed per manufacturer installation instructions.
- 9.6.2 Threaded rod and nut shall be installed finger tightened, at a minimum.
- 9.6.3 QTO cable or threaded rod shall be connected to the top plate prior to fastening the QGC to the truss/rafter.



9.7 QuickTie Screws

9.7.1 Lead holes are not required, but may be used where wood is prone to splitting.

9.7.1.1 Refer to Section 12.1 of the NDS for appropriate size of lead hole.

9.7.2 Screws shall be installed with the appropriate rotating powered driver.

9.7.3 Minimum requirements for screw spacing, edge distance and end distance shall be in accordance with **Table 44**.

Table 44. Screw Spacing, Edge Distance, and End Distance Requirements,¹ (in)

Connection Geometry	SWH	SWF	SWT	SWL
Edge Distance – Load in any direction	5/8			1/2
End Distance – Load parallel to grain, towards end	3 5/8		3 3/8	2 5/8
End Distance – Load parallel to grain, away from end	2 1/2		2 1/4	1 3/4
End Distance – Load perpendicular to grain	2 1/2		2 1/4	1 3/4
Spacing between Fasteners in a Row – Parallel to grain	3 5/8		3 3/8	2 5/8
Spacing between Fasteners in a Row – Perpendicular to grain	2 1/2		2 1/4	1 3/4
Spacing between Rows of Fasteners – In-line	1 1/4		1 1/8	7/8
Spacing between Rows of Fasteners – Staggered ²	5/8			1/2
SI: 1 in = 25.4 mm				
1. Edge distances, end distances and spacing of fasteners shall be sufficient to prevent splitting of the wood or as shown in this table, whichever is the more restrictive.				
2. Values for "Spacing between Rows of Fasteners-Staggered" apply where the screws in adjacent rows are offset by one-half of the "Spacing between Fasteners in a Row".				

9.7.4 SWT Screw Connections:

9.7.4.1 Truss Connections:

- 9.7.4.1.1 For truss/rafter/joist to top plate connections, install SWT6 fasteners upward through the wall top plates or wood structural framing member at the bottom corner of the top plate(s) and into the center of the wood truss or rafter. The fastener should be installed at an upward angle from the vertical of 20° to 25° and should penetrate the wood truss, rafter or joist within $\frac{1}{4}$ " of the centerline. Fasteners located between studs may be installed at a 90° angle.
- 9.7.4.1.2 If the wood truss, rafter or floor joist is located directly over a top plate splice, offset the fastener $\frac{1}{4}$ " to one side of the splice. Note that the splice may be in either top plate.
- 9.7.4.1.3 Minimum penetration for truss/rafter/joist to top plate connections is $2 \frac{1}{2}$ ".
- 9.7.4.1.4 Minimum penetration for gable truss to top plate connections is 3".
- 9.7.4.1.5 Minimum penetration into the main member and sheathing for valley truss connections is 2".
- 9.7.4.1.6 Minimum requirements for fastener spacing, edge distance and end distance shall be in accordance with **Table 44**.



9.7.4.2 Stud-to-Plate Connections:

- 9.7.4.2.1 Install SWT45 screws through the stud into the wall top or bottom plate. The fastener should be installed at an angle from the vertical of 20° to 30°.
- 9.7.4.2.2 Minimum requirements for fastener spacing, edge distance, and end distance shall be in accordance with **Table 44**, with the following exception:
 - 9.7.4.2.2.1 Fasteners shall be located a minimum of 2³/₄" from the end of the stud.

10 Substantiating Data

- 10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:
 - 10.1.1 Test reports for evaluation of the QTS and Quick Connectors for QTS Assembly's Tension Load Strength and Elongation Properties (Pre-load and 30+ Day Relaxation)
 - 10.1.2 HTS and MTS connector testing in accordance with ASTM D1761
 - 10.1.3 Test reports for connector uplift, gravity and lateral loads
 - 10.1.4 Test report for QTS assemblies
 - 10.1.5 Fastener bending yield testing in accordance with ASTM F1575
 - 10.1.6 Fastener tensile and shear strength testing in accordance with AISI S904
 - 10.1.7 Fastener lateral shear, withdrawal and head pull-through strength testing in accordance with ASTM D1761
 - 10.1.8 Connection design value calculations by DrJ Engineering, LLC in accordance with AWC TR12 and accepted engineering practices
- 10.2 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources, and/or RDPs. Accuracy of external test data and resulting analysis is relied upon.
- 10.3 Where pertinent, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability, and safety.
- 10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate, or Duly Authenticated Reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this Duly Authenticated Report, may be dependent upon published design properties by others.
- 10.5 Testing and engineering analysis: The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.²⁷
- 10.6 Where additional condition of use and/or regulatory compliance information is required, please search for QTS on the DrJ Certification website.



11 Findings

- 11.1 As outlined in Section 6, the QTS have performance characteristics that were tested and/or meet applicable regulations and are suitable for use pursuant to its specified purpose.
- 11.2 When used and installed in accordance with this [Duly Authenticated Report](#) and the manufacturer installation instructions, QTS shall be approved for the following applications:
- 11.2.1 QTS and Quick Connectors are approved for use in Seismic Design Categories A through F.
- 11.2.2 Connection of ledger boards to wall studs is approved with zero, one or two layers of $\frac{5}{8}$ " GWB between the ledger and wall studs.
- 11.3 Unless exempt by state statute, when QTS are to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an RDP.
- 11.4 Any application specific issues not addressed herein can be engineered by an RDP. Assistance with engineering is available from QuickTie™ Products, Inc.
- 11.5 [IBC Section 104.11](#) ([IRC Section R104.11](#) and [IFC Section 104.10](#)²⁸ are similar) in pertinent part states:
- 104.11 Alternative materials, design and methods of construction and equipment.** The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code. Where the alternative material, design or method of construction is not approved, the building official shall respond in writing, stating the reasons the alternative was not approved.
- 11.6 **Approved:**²⁹ Building regulations require that the [building official](#) shall accept [Duly Authenticated Reports](#).³⁰
- 11.6.1 An [approved agency](#) is "approved" when it is [ANAB ISO/IEC 17065 accredited](#).
- 11.6.2 An [approved source](#) is "approved" when an [RDP](#) is properly licensed to transact engineering commerce.
- 11.6.3 Federal law, [Title 18 US Code Section 242](#), requires that where the alternative product, material, service, design, assembly, and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.
- 11.7 DrJ is a licensed engineering company, employs licensed RDPs and is an [ANAB-Accredited Product Certification Body – Accreditation #1131](#).
- 11.8 Through the [IAF Multilateral Agreements](#) (MLA), this [Duly Authenticated Report](#) can be used to obtain product approval in any [jurisdiction](#) or [country](#) because all ANAB ISO/IEC 17065 [Duly Authenticated Reports](#) are equivalent.³¹

12 Conditions of Use

- 12.1 Material properties shall not fall outside the boundaries defined in Section 6.
- 12.2 As defined in Section 6, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.
- 12.3 Structural framing members (i.e., wood, masonry, concrete, steel, etc.) connected with the QTS and Quick Connectors shall be designed in accordance with the requirements of their specific design standards/specifications as referenced in the building code adopted by the jurisdiction in which the project is to be constructed.
- 12.4 Each QTS and/or Quick Connector shipment shall contain the manufacturer installation instructions. A copy of the installation instructions must be available at the jobsite at all times during installation.
- 12.5 The QTS shall be installed by contractors trained and certified by QuickTie Products, Inc.



- 12.6 Each QTS and Quick Connectors that are exposed directly to weather or subject to salt corrosion in coastal areas as determined by the local building official, shall be protected in accordance with the building code adopted by the jurisdiction in which the project is to be constructed.
- 12.7 QuickTie screws are approved for use in wood members in both dry and wet service conditions. All applicable adjustment factors specified in Table 11.3.1 of the NDS shall be applied.
- 12.8 When installed in preservative-treated wood or fire-retardant treated wood, connections using QuickTie screws shall be designed using the treatment manufacturer reductions for connections.
- 12.9 Use of QuickTie screws in locations exposed to saltwater or saltwater spray is outside the scope of this evaluation.
- 12.10 For conditions not covered in this Report, connections shall be designed in accordance with generally accepted engineering practices. When the capacity of a connection is controlled by fastener metal strength rather than wood strength, the metal strength shall not be increased by the adjustment factors specified in the NDS.
- 12.11 When required by adopted legislation and enforced by the building official, also known as the authority having jurisdiction (AHJ) in which the project is to be constructed:
- 12.11.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.
 - 12.11.2 This Report and the installation instructions shall be submitted at the time of permit application.
 - 12.11.3 These innovative products have an internal quality control program and a third-party quality assurance program.
 - 12.11.4 At a minimum, these innovative products shall be installed per Section 9 of this Report.
 - 12.11.5 The review of this Report by the AHJ shall comply with IBC Section 104 and IBC Section 105.4.
 - 12.11.6 These innovative products have an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.4, IBC Section 110.4, IBC Section 1703, IRC Section R104.4, and IRC Section R109.2.
 - 12.11.7 The application of these innovative products in the context of this Report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2, and any other regulatory requirements that may apply.
- 12.12 The approval of this Report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *"the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new material or assemblies as provided for in Section 104.11,"* all of IBC Section 104, and IBC Section 105.4.
- 12.13 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).
- 12.14 The actual design, suitability, and use of this Report for any particular building, is the responsibility of the owner or the authorized agent of the owner.



13 Identification

- 13.1 The innovative products listed in Section 1 are identified by a label on the board or packaging material bearing the manufacturer name, product name, this Report number, and other information to confirm code compliance.
- 13.2 Additional technical information can be found at www.quicktieproducts.com.

14 Review Schedule

- 14.1 This Report is subject to periodic review and revision. For the latest version, visit drjcertification.org.
- 14.2 For information on the status of this Report, please contact DrJ Certification.

15 Approved for Use Pursuant to U.S. and International Legislation Defined in Appendix A

- 15.1 The QuickTie System (QTS) is included in this Report published by an approved agency that is concerned with evaluation of products or services, maintains periodic inspection of the production of listed materials or periodic evaluation of services. This Report states either that the material, product, or service meets recognized standards or has been tested and found suitable for a specified purpose. This Report meets the legislative intent and definition of being acceptable to the AHJ.



Appendix A

1 Legislation that Authorizes AHJ Approval

- 1.1 **Fair Competition:** State legislatures have adopted Federal regulations for the examination and approval of building code referenced and alternative products, materials, designs, services, assemblies, and/or methods of construction that:
 - 1.1.1 Advance innovation,
 - 1.1.2 Promote competition so all businesses have the opportunity to compete on price and quality in an open market on a level playing field unhampered by anticompetitive constraints, and
 - 1.1.3 Benefit consumers through lower prices, better quality, and greater choice.
- 1.2 **Adopted Legislation:** The following local, state, and federal regulations affirmatively authorize these innovative products to be approved by AHJs, delegates of building departments, and/or delegates of an agency of the federal government:
 - 1.2.1 Interstate commerce is governed by the Federal Department of Justice to encourage the use of innovative products, materials, designs, services, assemblies, and/or methods of construction. The goal is to “*protect economic freedom and opportunity by promoting free and fair competition in the marketplace.*”
 - 1.2.2 Title 18 US Code Section 242 affirms and regulates the right of individuals and businesses to freely and fairly have new products, materials, designs, services, assemblies, and/or methods of construction approved for use in commerce. Disapproval of alternatives shall be based upon non-conformance with respect to specific provisions of adopted legislation and shall be provided in writing stating the reasons why the alternative was not approved, with reference to the specific legislation violated.
 - 1.2.3 The federal government and each state have a public records act. In addition, each state also has legislation that mimics the federal Defend Trade Secrets Act 2016 (DTSA),³² where providing test reports, engineering analysis and/or other related IP/TS is subject to prison of not more than ten years³³ and/or a \$5,000,000 fine or 3 times the value of³⁴ the Intellectual Property (IP) and Trade Secrets (TS).
 - 1.2.3.1 Compliance with public records and trade secret legislation requires approval through the use of Listings, certified reports, Technical Evaluation Reports, duly authenticated reports, and/or research reports prepared by approved agencies and/or approved sources.
 - 1.2.4 For new materials³⁵ that are not specifically provided for in any regulation, the design strengths and permissible stresses shall be established by tests, where suitable load tests simulate the actual loads and conditions of application that occur.
 - 1.2.5 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design using accepted engineering practice.³⁶
 - 1.2.6 The commerce of approved sources (i.e., registered PEs) is regulated by professional engineering legislation. Professional engineering commerce shall always be approved by AHJs, except where there is evidence provided in writing, that specific legislation have been violated by an individual registered PE.
 - 1.2.7 The AHJ shall accept Duly Authenticated Reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in IBC Section 104.11.³⁷



- 1.3 **Approved³⁸ by Los Angeles:** The Los Angeles Municipal Code (LAMC) states in pertinent part that the provisions of LAMC are not intended to prevent the use of any material, device, or method of construction not specifically prescribed by LAMC. The Department shall use Part III, Recognized Standards in addition to Part II, Uniform Building Code Standards of Division 35, Article 1, Chapter IX of the LAMC in evaluation of products for approval where such standard exists for the product or the material and may use other approved standards that apply. Whenever tests or certificates of any material or fabricated assembly are required by Chapter IX of the LAMC, such tests or certification shall be made by a testing agency approved by the Superintendent of Building to conduct such tests or provide such certifications. The testing agency shall publish the scope and limitation(s) of the listed material or fabricated assembly.³⁹ The Superintendent of Building Approved Testing Agency Roster is provided by the Los Angeles Department of Building and Safety (LADBS). The Center for Building Innovation (CBI) Certificate of Approval License is TA24945. Tests and certifications found in a DrJ Listing are LAMC approved. In addition, the Superintendent of Building shall accept Duly Authenticated Reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in the California Building Code (CBC) Section 1707.1.⁴⁰
- 1.4 **Approved by Chicago:** The Municipal Code of Chicago (MCC) states in pertinent part that an Approved Agency is a Nationally Recognized Testing Laboratory (NRTL) acting within its recognized scope and/or a certification body accredited by the American National Standards Institute (ANSI) acting within its accredited scope. Construction materials and test procedures shall conform to the applicable standards listed in the MCC. Sufficient technical data shall be submitted to the building official to substantiate the proposed use of any product, material, service, design, assembly, and/or method of construction not specifically provided for in the MCC. This technical data shall consist of research reports from approved sources (i.e., MCC defined Approved Agencies).
- 1.5 **Approved by New York City:** The 2022 NYC Building Code (NYCBC) states in part that an approved agency shall be deemed⁴¹ an approved testing agency via ISO/IEC 17025 accreditation, an approved inspection agency via ISO/IEC 17020 accreditation, and an approved product evaluation agency via ISO/IEC 17065 accreditation. Accrediting agencies, other than federal agencies, must be members of an internationally recognized cooperation of laboratory and inspection accreditation bodies subject to a mutual recognition agreement⁴² (i.e., ANAB, International Accreditation Forum [IAF], etc.).
- 1.6 **Approved by Florida:** Statewide approval of products, methods, or systems of construction shall be approved, without further evaluation by:
- 1.6.1 A certification mark or listing of an approved certification agency,
 - 1.6.2 A test report from an approved testing laboratory,
 - 1.6.3 A product evaluation report based upon testing or comparative or rational analysis, or a combination thereof, from an approved product evaluation entity, or
 - 1.6.4 A product evaluation report based upon testing, comparative or rational analysis, or a combination thereof, developed, signed and sealed by a professional engineer or architect, licensed in Florida.
 - 1.6.5 For local product approval, products or systems of construction shall demonstrate compliance with the structural wind load requirements of the Florida Building Code (FBC) through one of the following methods:
 - 1.6.5.1 A certification mark, listing or label from a commission-approved certification agency indicating that the product complies with the code,
 - 1.6.5.2 A test report from a commission-approved testing laboratory indicating that the product tested complies with the code,
 - 1.6.5.3 A product-evaluation report based upon testing, comparative or rational analysis, or a combination thereof, from a commission-approved product evaluation entity which indicates that the product evaluated complies with the code,



- 1.6.5.4 A product-evaluation report or certification based upon testing or comparative or rational analysis, or a combination thereof, developed and signed and sealed by a Florida professional engineer or Florida registered architect, which indicates that the product complies with the code, or
- 1.6.5.5 A statewide product approval issued by the Florida Building Commission.
- 1.6.6 The [Florida Department of Business and Professional Regulation \(DBPR\)](#) website provides a listing of companies certified as a [Product Evaluation Agency](#) (i.e., EVLMiami 13692), a [Product Certification Agency](#) (i.e., CER10642), and as a [Florida Registered Engineer](#) (i.e., ANE13741).
- 1.7 **Approved by Miami-Dade County (i.e., Notice of Acceptance [NOA]):** A Florida statewide approval is an NOA. An NOA is a Florida local product approval. By Florida law, Miami-Dade County shall accept the statewide and local Florida Product Approval as provided for in Florida legislation [553.842](#) and [553.8425](#).
- 1.8 **Approved by New Jersey:** Pursuant to the 2018 Building Code of New Jersey in [IBC Section 1707.1 General](#),⁴³ it states: “*In the absence of approved rules or other approved standards, the building official shall accept duly authenticated reports from [approved agencies](#) in respect to the quality and manner of use of new materials or assemblies as provided for in the administrative provisions of the Uniform Construction Code (N.J.A.C. 5:23)*”.⁴⁴ Furthermore N.J.A.C 5:23-3.7 states: “*Municipal approvals of alternative materials, equipment, or methods of construction.*”
 - 1.8.1 **Approvals:** Alternative materials, equipment, or methods of construction shall be approved by the appropriate subcode official provided the proposed design is satisfactory and that the materials, equipment, or methods of construction are suitable for the intended use and are at least the equivalent in quality, strength, effectiveness, fire resistance, durability, and safety of those conforming with the requirements of the regulations.
 - 1.8.1.1 A field evaluation label and report or letter issued by a nationally recognized testing laboratory verifying that the specific material, equipment, or method of construction meets the identified standards or has been tested and found to be suitable for the intended use, shall be accepted by the appropriate subcode official as meeting the requirements of the above.
 - 1.8.1.2 Reports of engineering findings issued by nationally recognized evaluation service programs such as but not limited to, the Building Officials and Code Administrators (BOCA), the International Conference of Building Officials (ICBO), the Southern Building Code Congress International (SBCCI), the International Code Council (ICC), and the National Evaluation Service, Inc., shall be accepted by the appropriate subcode official as meeting the requirements of the above.
 - 1.8.2 The [New Jersey Department of Community Affairs](#) has confirmed that technical evaluation reports, from any accredited entity listed by [ANAB](#), meets the requirements of item the previous paragraph, given that the listed entities are no longer in existence and/or do not provide “*reports of engineering findings.*”
- 1.9 **Approved by the Code of Federal Regulations Manufactured Home Construction and Safety Standards:** Pursuant to Title 24, Subtitle B, Chapter XX, [Part 3282.14](#)⁴⁵ and [Part 3280](#),⁴⁶ the Department encourages innovation and the use of new technology in manufactured homes. The design and construction of a manufactured home shall conform to the provisions of Part 3282 and Part 3280 where key approval provisions in mandatory language follow:
 - 1.9.1 “*All construction methods shall be in conformance with accepted engineering practices.*”
 - 1.9.2 “*The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.*”
 - 1.9.3 “*The design stresses of all materials shall conform to accepted engineering practice.*”



- 1.10 Approval by US, Local and State Jurisdictions in General:** In all other local and state jurisdictions, the adopted building code legislation states in pertinent part that:
- 1.10.1 For new materials that are not specifically provided for in this code, the design strengths and permissible stresses shall be established by tests.⁴⁷
 - 1.10.2 For innovative alternatives and/or methods of construction, the building official shall accept Duly Authenticated Reports from approved agencies with respect to the quality and manner of use of new materials or assemblies.⁴⁸
 - 1.10.2.1 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is in the ANAB directory.
 - 1.10.2.2 An approved source is “approved” when an RDP is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.⁴⁹
 - 1.10.3 The design strengths and permissible stresses of any structural material...shall conform to the specifications and methods of design of accepted engineering practice performed by an approved source.⁵⁰
- 1.11 Approval by International Jurisdictions:** The USMCA and GATT agreements provide for approval of innovative materials, designs, services, and/or methods of construction through the Agreement on Technical Barriers to Trade and the IAF Multilateral Recognition Arrangement (MLA), where these agreements:
- 1.11.1 State that conformity assessment procedures (i.e., ISO/IEC 17020, 17025, 17065, etc.) are prepared, adopted, and applied so as to grant access for suppliers of like products originating in the territories of other Members under conditions no less favourable than those accorded to suppliers of like products of national origin or originating in any other country, in a comparable situation.
 - 1.11.2 **Approved:** The purpose of the MLA is to ensure mutual recognition of accredited certification and validation/verification statements between signatories to the MLA and subsequently, acceptance of accredited certification and validation/verification statements in many markets based on one accreditation for the timely approval of innovative materials, designs, services, and/or methods of construction.
 - 1.11.3 ANAB is an IAF-MLA signatory where recognition of certificates, validation, and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA, with the appropriate scope, shall be approved.⁵¹
 - 1.11.4 Therefore, all ANAB ISO/IEC 17065 Duly Authenticated Reports are approval equivalent.⁵²
- 1.12 Approval equity is a fundamental commercial and legal principle.⁵³



Appendix B. General Notes for Tables

1. Allowable loads are in pounds.
2. Unless noted otherwise, nails are common wire nails of the pennyweight noted in the tables. Nails shall comply with ASTM F1667 and shall have the following minimum bending yield strengths, F_{yb} .

$$8d, D = 0.131 \text{ in.}, F_{yb} = 100,000 \text{ psi}$$

$$10d, D = 0.148 \text{ in.}, F_{yb} = 90,000 \text{ psi}$$

$$16d, D = 0.162 \text{ in.}, F_{yb} = 90,000 \text{ psi}$$

3. Nails designated as 8d x 1½ are assumed to be 0.131" x 1.5" nails, nails designated as 8d are assumed to be 0.131" x 2.5" nails, nails designated as 10d x 1½ are assumed to be 0.148" x 1.5" nails, and nails designated as 10d are assumed to be 0.148" x 3" nails. The number of fasteners shown is the minimum required to achieve the loads shown.
4. Tabulated allowable loads listed for a load duration factor of 1.00 (i.e. "Normal" load duration) are to be used in applications in which the shortest load duration in the combination of loads is 10 years. These values may be increased for applications in which the governing load duration factor is 1.15 or 1.25 in accordance with NDS up to the tabulated allowable loads for load duration factors of 1.33 and 1.60 or in accordance with the building code adopted by the jurisdiction in which the project is to be constructed.
5. The allowable loads included in this Report are for QuickTie Connectors only. All framing members shall be designed in accordance with the building code adopted by the jurisdiction in which the project is to be constructed.
6. Load capacities in the design tables are valid for the species shown. For other species, adjust values in accordance with NDS.
7. Unless indicated otherwise, the allowable loads provided in these tables assume the connector is attached to a wood member with a minimum nominal thickness of 2".
8. Allowable simultaneous loads in more than one direction on a single connector must be evaluated using the following equation:

$$\frac{\text{Design Load Uplift}}{\text{Allowable Load Uplift}} + \frac{\text{Design Load Parallel to Wall Plate}}{\text{Allowable Load Parallel to Wall Plate}} + \frac{\text{Design Load Perpendicular to Wall Plate}}{\text{Allowable Load Perpendicular to Wall Plate}} \leq 1.0$$

9. The building designer is responsible for determining the simultaneous loading conditions.
10. When cross-grain bending or cross-grain tension cannot be avoided in the members, mechanical reinforcement to resist such forces should be considered.



Appendix C. ASCE/SEI 19 Section 2 Contract Documents and Shop Drawings

2.1. Contract Documents

2.1.1 Contract drawings. The Contract Drawings shall indicate the horizontal and vertical location of the cables and their connections for a specified load and temperature, typically the final dead load condition at the ambient temperature. Dimensions and loading data shall be shown to enable the computation of cable lengths under the specified condition. Required pre-stressing at erection shall be shown.

Terminations, fittings, anchorages, and other support details shall be fully detailed or sufficient data shall be provided to enable their selection and procurement. The required camber of supporting structural members and the required initial out-of-plumb of columns shall be shown on the drawings. The erection procedure modeled in the structural analysis and design shall be outlined in the contract documents with a statement indicating whether it is a suggested procedure or is mandatory because of controlling loadings or displacements of the cables or the supporting structure.

2.1.2 Contract specifications. For each cable in the proposed cable structure, the Contract Specifications shall indicate the diameter (size), the type of cable, the wire coating, the grade of cable, pre-stretching requirements and the applicable material or testing specification. If there are additional design requirements for cables, they shall be included in the contract specifications. The required tension on the cables when length and diameter measurements are made shall be indicated. Cable and fitting manufacturing tolerances required for design or erection conditions shall also be given. The Construction Documents shall also state the erection tolerances, both for the final geometry of the system and the pre-stressing forces. The Contract Specifications shall identify all other required submittals, including shop drawings and test reports.

2.2 Shop Drawings

Drawings for the fabrication of cables and fittings shall reflect the requirements indicated in the Contract Documents. Exact locations, material, sizes, and lengths of all cables and fittings shall be shown, as well as fabrication and preparation procedures for cables and fittings. Where approved substitutions or changes from the contract documents are made, an alternate member or fitting shall be detailed, that will satisfy the loading and configurations indicated in the Contract Documents

As part of the Shop Drawings, Separate erection drawings shall be prepared to show the critical sequence, procedures, and methods of erection. The Erection Drawings shall be accompanied by an erection analysis; see section 3.4.5.

Shop Drawings and test reports shall be submitted to the Engineer for review.

3.4.5 Erection Analysis

A structural analysis shall be performed for the suggested or mandatory erection procedure considering the effects listed in section 3.4.1. Should deviations be made in the suggested erection procedure, the erector shall have an independent professional engineer experienced in cable-system erection perform an erection analysis to match the revised methods, equipment, and sequence.



Appendix D. Design Loads for QTB(L) and QTG(L)

For uplift resistance, on-center spacing, allowable loads and design notes are provided in **Table 45** and **Figure 82** for the QTB(L) Blue $\frac{3}{16}$ " System and the QTG(L) Green $\frac{1}{4}$ " System.

Table 45. QuickTie System (QTS) Allowable Loads for Uplift Resistance^{2,3,4,5,6,7}

Uplift (lbs) per Truss (assumes trusses @ 2 ft o.c.)	QTB(L) Blue $\frac{3}{16}$ " Spacing ¹	QTG(L) Green $\frac{1}{4}$ " Spacing ¹
3,180	N/A	2' 0"
2,800	N/A	2' 3"
2,600	N/A	2' 5"
2,400	N/A	2' 8"
2,200	N/A	2' 11"
2,000	N/A	3' 2"
1,910	2' 0"	3' 4"
1,800	2' 1"	3' 6"
1,700	2' 3"	3' 9"
1,600	2' 5"	4' 0"
1,500	2' 7"	4' 3"
1,400	2' 9"	4' 3"
1,300	2' 11"	4' 5"
1,200	3' 2"	4' 7"
1,100	3' 6"	4' 10"
1,000	3' 10"	5' 1"
950	4' 0"	5' 2"
900	4' 3"	5' 4"
850	4' 6"	5' 6"
800	4' 9"	5' 8"
775	4' 11"	5' 9"
750	5' 1"	5' 10"
725	5' 3"	5' 11"
700	5' 5"	6' 1"
675	5' 8"	6' 2"




Table 45. QuickTie System (QTS) Allowable Loads for Uplift Resistance^{2,3,4,5,6,7}

Uplift (lbs) per Truss (assumes trusses @ 2 ft o.c.)	QTB(L) Blue ³ / ₁₆ " Spacing ¹	QTG(L) Green ¹ / ₄ " Spacing ¹
650	5' 11"	6' 3"
625	6' 1"	6' 5"
600	6' 4"	6' 6"
575	6' 8"	6' 8"
550	6' 10"	6' 10"
525	7' 0"	7' 0"
500	7' 2"	7' 2"
475	7' 4"	7' 4"
450	7' 7"	7' 7"
425	7' 9"	7' 9"
≤ 400	8' 0"	8' 0"


SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. The exact location can change slightly if the maximum spacing between any two QuickTie Systems does not exceed 8' +/- 3" on either side. Therefore, an absolute maximum spacing of 8' - 6" is acceptable.
2. The allowable design load with edge distance equal to or greater than 2 1/4": QTB(L) Blue ³/₁₆" QuickTie = 1,910 lbs. / QTG(L) Green ¹/₄" QuickTie = 3,180 lbs.
3. Space all QTS as specified in this table for all walls subject to uplift loads.
4. All QTS shall be installed according to these specifications unless designed and certified by a registered design professional.
5. QTB(L) Blue ³/₁₆" QuickTie / QTG(L) Green ¹/₄" QuickTie specified in this table are embedded 4" into minimum 2,500 psi concrete using an epoxy capable of resisting the given loads.
6. Loads require a minimum 1/2" thick gypsum wallboard on each side of the wall fastened to studs with 1 1/2" long wallboard nails spaced at 6" o.c. at edges and 12" o.c. in the field.
7. Use only QTS materials as specified and supplied by QuickTie Products, Inc.


QuickTie Placement



Header Tie-Down Requirements



Girder Tie-Downs



NOTES:

1. Sheathing for shear walls removed for clarity.
2. All QuickTies shall be installed according to these specifications unless designed and certified by a registered design professional.
3. Install QuickTies at each end of all shear wall segments. More than one QuickTie may be required to resist combined forces due to uplift and overturning.
4. Refer to Table for maximum spacing requirements for QuickTies used to resist uplifts only. Install one QuickTie within 12" of each load bearing corner (one side of corner, preferably the side where the top plates lap over the other wall.)
5. Allowable loads provided in this figure are for QuickTie System only. Building designer must verify that the wall structural framing elements are capable of transferring the loads to the QTS.
6. See header connection schedule for connections required for headers 8'-0" and greater.
7. Use only QuickTie System materials as supplied by QuickTie Products, Inc.

Figure 82. QuickTie System (QTS) Allowable Loads for Uplift Resistance



Issue Date: April 4, 2021

Subject to Renewal: April 1, 2025

FBC Supplement to Report Number 0910-01

REPORT HOLDER: QuickTie™ Products, Inc.

1 Evaluation Subject

- 1.1 QuickTie™ System (QTS)

2 Purpose and Scope

- 2.1 Purpose
 - 2.1.1 The purpose of this Report Supplement is to show QTS, recognized in Report Number 0910-01, have also been evaluated for compliance with the codes listed below as adopted by the Florida Building Commission.
- 2.2 *Applicable Code Editions*
 - 2.2.1 *FBC-B—20, 23: Florida Building Code – Building (FL 3557 and FL 13468)*
 - 2.2.2 *FBC-R—20, 23: Florida Building Code – Residential (FL 3557 and FL 13468)*

3 Conclusions

- 3.1 QTS, as described in Report Number 0910-01, comply with the FBC-B and FBC-R and are subject to the conditions of use described in this supplement.
- 3.2 Where there are variations between the IBC and IRC and the FBC-B and FBC-R applicable to this Report, they are listed here:
 - 3.2.1 FBC-B Section 104.4, Section 110.4 and Section 2308 are reserved.
 - 3.2.2 FBC-R Section R104, Section R109, Section R602.3.2, Section R602.10, Section R602.10.5.2 and Section R602.10.6.2 are reserved.
 - 3.2.3 FBC-B Section 1901.3 replaces IBC Section 1901.3.
 - 3.2.4 FBC-B Section 2304.10.5 replaces IBC Section 2304.10.6.
 - 3.2.5 FBC-B Section 2304.12 replaces IBC Section 2304.12.
 - 3.2.6 FBC-R Section R301.2.1 replaces IRC Section R301.2.1.
 - 3.2.7 FBC-R Section R301.2.2 replaces IRC Section R301.2.2.
 - 3.2.8 FBC-R Section R602 replaces IRC Section R602.

4 Conditions of Use

- 4.1 QTS, described in Report Number 0910-01, must comply with all of the following conditions:
 - 4.1.1 All applicable sections in Report Number 0910-01.
 - 4.1.2 The design, installation, and inspections are in accordance with additional requirements of FBC-B Chapter 16 and Chapter 17, as applicable.



Notes

Subject to Renewal: 04/01/25
Page 105 of 106



<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>

Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<http://www.drjengineering.org/AppendixC> AND <https://www.drjcertification.org/cornell-2016-protection-trade-secrets>

<https://www.law.cornell.edu/uscode/text/18/1832#:~:text=imprisoned%20not%20more%20than%2010%20years>

<https://www.law.cornell.edu/uscode/text/18/1832#:~:text=Any%20organization%20that.has%20thereby%20avoided>

<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706.2>

IBC 2021, Section 1706.1 Conformance to Standards

IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General

See Section 11 for the distilled building code definition of **Approved**

Los Angeles Municipal Code, SEC. 98.0503. TESTING AGENCIES

<https://up.codes/viewer/california/ca-building-code-2022/chapter/17/special-inspections-and-tests#1707.1>

New York City, The Rules of the City of New York, § 101-07 Approved Agencies

New York City, The Rules of the City of New York, § 101-07 Approved Agencies

<https://up.codes/viewer/new-jersey/ibc-2018/chapter/17/special-inspections-and-tests#1707.1>

<https://www.nj.gov/dca/divisions/codes/codreg/ucc.html>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>

IBC 2021, Section 1706 Design Strengths of Materials, 1706.2 New Materials. Adopted law pursuant to IBC model code language 1706.2.

IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General. Adopted law pursuant to IBC model code language 1707.1.

<https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>

IBC 2021, Section 1706 Design Strengths of Materials, Section 1706.1 Conformance to Standards Adopted law pursuant to IBC model code language 1706.1.

<https://iaf.nu/en/about-iaf-mla/#:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope>

True for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>