

The Voice of the Networks

**Energy
Networks
Association**



***Loss of Mains Protection Settings
for all Small Generators***

Stakeholder Webinar

1:30pm-3:30pm

5 July 2018

- Presentation will be made with inputs muted
- Please ask questions via the chat facility
- Questions will be answered either at the time, or at the question/answer session at the end
- Slides from today will be published, along with a fuller set from the 15 June presentation in London

Agenda

Welcome and Introductions

Mike Kay 5mins

Background and Work so far

**Graham Stein
15mins**

Loss of Mains setting change

**Mike Kay
20 mins**

Q&A

10mins

Retrospective setting change cost & benefit

**Graham Stein
15 mins**

Implementation and next steps

**Mike Kay
Graham Stein
15mins**

Q&A

- Provide an update on Loss of Mains protection setting changes
- Provide an update on potential further changes to the Distribution Code, ER G59 and ER G83
 - Loss of Mains protection settings
- Explain why changes are being considered and how they might be implemented
- Inform affected parties how they can contribute to the implementation plan

Background

Graham Stein


Network Operability Manager

Electricity System Operator

National Grid

graham.stein@nationalgrid.com

Electricity Networks - Transmission



Electricity Networks - Transmission


Electricity Distribution



Independent distribution network operators



Frequency



<http://www2.nationalgrid.com/uk/industry-information/electricity-transmission-operational-data/>


Loss of Mains Protection (RoCoF based)

RoCoF relay Operation


1. An event on either the transmission or the distribution network can force the breaker to open and create an AC island isolated from the main AC system

2. The frequency of the AC island is dependent on the balance of the generation and the demand within the island. It is very likely that the frequency of the AC island will deviate rapidly from 50Hz.

3. Caused by the rapid rate of change of frequency, the embedded generation RoCoF protection relay triggers and therefore the AC island is forced to black out




Background




Evolution of system inertia

Historic System Inertia



Background



Summary of the RoCoF Risk

- The maximum rate of change risk occurs when demand is low and there is a large instantaneous infeed or offtake risk to manage
- The maximum rate of change is rising because
 - Synchronous generation is being displaced by non-synchronous plant – interconnectors, wind, photo-voltaic etc
 - There will be larger infeed losses in the future



Loss of Mains Protection (Vector Shift based)

Vector Shift Operation

1. An event on either the transmission or the distribution network can force the breaker to open and create an AC island isolated from the main AC system


2. When the main AC system is removed and the generator could experiences a relatively large change in load (in either direction) then there will be a near instantaneous change in the phase shift

3. The embedded generation Vector Shift protection relay triggers and therefore the AC island is forced to black out




EG tripping for transmission fault

- VS protection could trip inappropriately over a wide area for transmission faults
- 22/5/2016 11:15; following the transmission fault at Langage – Landulph 400kV circuit, 380MW demand increase was observed




EG tripping for transmission fault

Date	Fault	Demand Increase Seen
22 May 2016 11:15	Langage – Landulph 400kV circuit	Lightning OHL 380 MW



Simulated VS during the 22/5/2016 fault



Other VS risk system events

Date/ Time	Fault	T Demand Increase	National Solar Output
17/3/2016 12:27	Grain Bus Coupler 4	469MW	61%
20 /3/2016 16:13	Grain- Kingsnorth 400kV circuit	200MW	17%
22/5/2016 11:15	Langage – Landulph 400kV circuit	380 MW	52%
07/6/2016 17:04	Cowley-Leighton Buzzard-Sundon 400kV circuit	145MW	28%
21/5/2017 18:20	Littlebrook 400kV Reserve Bar	200 MW	39%
08/6/2017 16:47	COTT – EASO – RYHACCT energised from EASO4 only	241MW	22%
10/7/2017 14:19	Bramford – Sizewell 4 400kV circuit	300 MW	37%
17/7/2017 15:26	Kensal Green Reserve Bar	580MW DG Loss less 160MW demand loss	50%

Technical Solutions

- Options for Managing the Risk
 - Limiting the largest loss limits the rate of change
 - Increasing inertia by synchronising additional plant reduces the rate of change
 - displaces non synchronous generation
 - Limiting the Rate of Change using automatic action (not currently feasible)
 - Changing or Removing RoCoF based protection
 - Changing or Removing VS based protection
 - Different LoMs approach
- Each option comes at a cost

The Voice of the Networks

**Energy
Networks
Association**



Changing LoM Settings

- GC0035 WG started work on RoCoF risks in 2012
- Revision to settings etc are implemented through changes to the Distribution Code (and G59 and G83)
- All changes subject to industry governance, overseen by the Distribution Code Review Panel and have to be approved by Ofgem
- Worth noting that the EU Network Codes (currently being implemented in GB UK law) require RoCoF withstand and ride through.
- G59 and G83 republished for EU Network Code requirements, as G99 and G98, to take effect from 27 April 2019.
- G59 and G83 (and G98 and G99) are compatible with the EU Network Code requirements
- All the settings issues discussed here apply equally to storage

- GC0035 Workgroup
 - Recommended the new RoCoF setting for DG >5MW
 - Up to 0.5Hzs^{-1} and to 1Hzs^{-1} with 0.5s definite time delay
 - Base-lined against current recommended settings
 - Encompassing 'larger' distributed generation (between 5MVA and 50MVA)
 - Building on previous LoM and NVD work
 - Risk assessment completed by the University of Strathclyde
 - Proposals approved on 24 July 2014 and has been implemented; to date, setting changes on 5GW of generation has been completed

- Summary of LoM protection changes recommended:
- August 2014
 - RoCoF to be set at 1.0 Hzs^{-1} , 0.5s definite time for all >5MW generation (0.5 Hzs^{-1} , 0.5s allowed for synchronous)
 - VS unchanged
- Feb 2018
 - RoCoF to be set at 1.0 Hzs^{-1} , 0.5s definite time for new non-type-tested generation <5MW
 - VS banned for all new non-type-tested generation
 - Only applies to generation connected under G59

- July 2018
 - RoCoF to be set at 1.0Hzs^{-1} , 0.5s definite time for new type-tested generation <5MW
 - VS banned for all new type-tested generation
 - Applies to both G59 and G83 generation
- Proposal is now:
 - to retrospectively apply the 1.0Hzs^{-1} , 0.5s definite time, and to remove VS, to all non-type-tested **G59** generation
 - No need to change G83 (or G59) type tested generation
 - Change the O/F setting to single stage 52.0 Hz where possible
 - On non-synchronous plant, other than DFIG, in cases where RoCoF relay settings cannot be changed LoM protection should be disabled
 - The ability remains to agree different settings with the DNO in exceptional circumstances

Proposed settings for <5MW generation

RoCoF settings for Power Stations <5MW Registered Capacity		
Date of Commissioning		
Generating Plant Commissioned before 01/02/18	Settings permitted until [01/01/22]	Not to be less than $K2 \times 0.125 \text{ Hz/s}^\#$ and not to be greater than $1.0 \text{ Hz/s}^\#$, time delay 0.5s
	Setting permitted on or after [01/01/22]	$1.0 \text{ Hz/s}^\#$, time delay 0.5s
Generating Plant commissioned on or after 01/02/18		$1.0 \text{ Hz/s}^\#$, time delay 0.5s

Note – only applies retrospectively to non-type-tested generation

Proposed settings for $\geq 5\text{MW}$ generation


RoCoF[§] settings for Power Stations $\geq 5\text{MW}$ Registered Capacity			
Date of Commissioning	Small Power Stations		Medium Power Stations
	Asynchronous	Synchronous	
Generating Plant Commissioned before 01/08/14	1.0Hz/s^{###}, time delay 0.5s Not to be less than K2 x 0.125 Hz/s[#] and not to be greater than 1.0Hz/s^{###}, time delay 0.5s	0.5Hz/s^{###}, time delay 0.5s Not to be less than K2 x 0.125 Hz/s[#] and not to be greater than 0.5Hz/s^{###}, time delay 0.5s	Intertripping Expected
Settings permitted until 01/08/16			
Generating Plant commissioned between 01/08/14 and 31/07/16 inclusive	1.0Hz/s^{###}, time delay 0.5s	0.5Hz/s^{###}, time delay 0.5s	Intertripping expected
Generating Plant commissioned on or after 01/08/16	1.0Hz/s^{###}, time delay 0.5s	1.0Hz/s^{###}, time delay 0.5s	Intertripping expected

RoCoF settings for Power Stations $\geq 5\text{MW}$ Registered Capacity	
Small Power Stations	Medium Power Stations
1.0Hz/s, time delay 0.5s	Intertripping Expected

Historic Vector Shift Settings		
Date of Commissioning	Small Power Stations	Medium Power Stations
Settings permitted for Generating Plant commissioned before 01/02/18 and allowable up to [31/12/21]. VS is not allowed from [01/01/22]	K1 x 6 degrees	Intertripping Expected
Settings permitted for Generating Plant commissioned on or after 01/02/18	Vector Shift not allowed as LoM in these Power Stations	Intertripping Expected


Loss-of-Mains – LoM

- Risks of operating in islanded mode
 - ❑ System can become unearthed
 - ❑ Faults in islanded mode may remain undetected (personal safety)
 - ❑ System can be live when utility personnel believe it is not energised
 - ❑ Unsynchronised reclose can occur (damage to generator)
- ⇒ Islanding is not permitted in most countries.




Risk assessment methodology*

- Establishing dominant islanding generation groupings (mixes)
- Simulation based non-detection zone (NDZ) assessment
- Probability tree based risk calculation



* Similar methodology was used in early NVD risk assessment study (2008-09) for G59/2, for the earlier stages of DC0079, and also in the recent revision of the LoM settings in Northern Ireland.

Risk Probability Tree




Risk assessment Summary

- Personal risks related to the proposed change of settings of the RoCoF based LoM protection are all within the broadly acceptable region (i.e. $<10^{-6}$)
- NDZ evaluation of VS protection demonstrated very poor sensitivity for settings above 6° , meaning that most generation fitted with VS in effect has no LoM.
- Based on NDZ values for RoCoF protection, in cases where RoCoF with recommended settings cannot be easily applied, it is acceptable to disable LoM protection except for SG and DFIG.
- Single-phase PV inverters remain stable under VS events up to 50° . Some three-phase inverters may disconnect under imbalanced transmission system faults.

DC0079 retrospective change cost benefit analysis

Past RoCoF Constraint Costs




Forecasting Model

- BID3 Economic Model
 - Pan-European Market Model
 - Used for the Network Options Assessment
- Typically used for assessing network reinforcement options
- New developments are allowing us to start to investigate other operability constraints
 - Real-time voltage 'rules'
 - Area unit constraints on synchronous generators
 - Large loss risk limit
 - Loss risk size constraint given RoCoF limit of 0.125 Hz/s

Calculating RoCoF Constraint Cost

- The BID3 first run with only thermal and voltage constraints activated.
- It was then re-run with additional RoCoF constraints activated.
- The cost of the RoCoF constraint is the difference between the total constraints costs of the two runs.

The model re-optimises all constraints when a new constraint is added.



The difference between these two constraint cost totals is the cost of the 'RoCoF Constraint'

FES scenarios




Steady state

Steady State



In **Steady State** business as usual prevails and the focus is on ensuring security of supply at a low cost for consumers. This is the least affluent of the scenarios and the least green. There is little money or appetite for investing in long-term low carbon technologies, therefore innovation slows.

RoCoF cost forecast under Steady State



Implementation Cost Assumption

Nature Of Work	Cost per site (£)
Site Visit	200
Re-programme / reset /disable existing relay	200
Remove Vector shift (synchronous plant except DFIG)	200
Replace VS relay or single function RoCoF Relay	7700

Note that these costs assume an efficient integrated programme - ie site visits and labour organized to support an efficient programme

Implementation Cost


	Nature Of Work	Low Estimate		WG Estimate		High Estimate	
		Number of Sites	Cost (£)	Number of Sites	Cost (£)	Number of Sites	Cost (£)
1	Synch - reset RoCoF	355	71,074	477	95,379	260	52,070
2	Synch replace RoCoF	19	144,019	477	3,672,080	2,343	18,042,324
3	Synch reset VS to RoCoF	1,049	209,849	977	195,469	878	175,564
4	Synch replace VS with RoCoF	117	897,685	977	7,525,549	7,900	60,832,857
5	Asynch reset RoCoF	2,585	516,930	2,927	585,401	559	111,730
6	Asynch remove RoCoF	136	27,207	2,927	585,401	5,028	1,005,568
7	Asynch reset VS to RoCoF	41,176	8,235,255	20,625	4,124,951	3,304	660,876
8	Asynch remove VS	4,575	915,028	20,625	4,124,951	29,739	5,947,886

Plant Category	No of Sites	Expected Cost £m	Low estimate £m	High estimate £m
$P_g > 5\text{MW}$	677	2.2	0.5	4.2
$1\text{MW} \leq P_g < 5\text{MW}$	1445	4.6	1	8.9
$P_g < 1\text{MW}$	47890	24.1	19.5	83.8
Total	50012	30.9	21	96.9

CBA Assumption

- Implementation will be over three years starting from 2018
- Social discount rate 3.5% from UK Government Green Book.
- Benefits will start accruing at the end of the project.

Result Summary and Conclusion



	Investment Cost (£M)	Discounted benefits (£M)	Discounted Cost (£M)	Net Present Value (£M)
Case 1	30.9	314.28	28.86	285.42
Case 2	96.9	314.28	90.49	223.78

The Voice of the Networks

**Energy
Networks
Association**

How to implement



What are our known challenges?

- Large number of network users need to comply
- Stakeholders with little need or desire to interact with licensees or regulators
- Unprecedented retrospective programme
- More information required to define success criteria (ie when you can stop)
- Large number of network licensees involved in a rapidly changing environment
- Urgency

What do we know that helps us?


- Lessons learnt from >5MW change
- Volume of challenge is under control
- Technical solution agreed
- Clear regulatory ask
- Ireland experience

Key Issues to Address	Proposal
<ul style="list-style-type: none">• Large number of network users need to comply• Stakeholders with little need or desire to interact with licensees or regulators	<ul style="list-style-type: none">• Proactive engagement – go out and find who needs to comply• Provide the support required to do the work for customers that can't or don't want to do it themselves• Give affected stakeholders opportunity to shape programme
<ul style="list-style-type: none">• Unprecedented Programme	<ul style="list-style-type: none">• Set up governance necessary to allow decisions to be made as issues arise• Agree success criteria at start of programme

- Multi-workstream programme with Steering Committee Responsible for delivery
- Stakeholders playing major role on the Steering Group
 - Stakeholders delivering the change
- Core delivery through a Customer Support workstream tasked with facilitating compliance
- Assurance provided by two workstreams to ensure work is done and delivers the desired outcome

Structure: Responsibilities

DRAFT



DRAFT

- Customer Support Workstream responsibilities
 - Identify and prioritise customers that need to comply
 - Make contact and identify those that want help to do so
 - Provide help for those that want it including assessing any network implications
 - Broader customer engagement in line with engagement plan
 - Manage risks and liabilities and statutory compliance

VS change accelerated programme

- National Grid in collaboration with three DNOs initiated an accelerated VS change programme to mitigate the risk for summer 2018
- Programme implemented under Balancing Service framework

	VS change 2018	DC0079
Duration	Within a month before June	Multi-Years
Target EG	800MW, 72 sites in specific area	More than 15GW and 50,000 sites nationally
Total cost	£250k	£31M
Benefit	Realized within year	Realized once the whole programme complete
Governance	Tactical exercise between licensees	Steering committee with stakeholder input

- Do you support the proposal to remove vector shift protection technique?
- Do you support the proposed change in RoCoF settings to 1Hzs^{-1} with a delay of 500ms for all non-type-tested distributed generators below 5MW?
- Do you agree that RoCoF protection should be disabled, in cases where settings cannot be changed, for all non-synchronous plant except for DFIG?
- Do you support the proposal that all DFIG machines should use RoCoF protection technique set at 1Hzs^{-1} with a 500ms time delay as loss of mains?

- Do you agree that all synchronous generation >5MW, should have a RoCoF setting of 1Hzs^{-1} with a delay of 500ms retrospectively applied?
- Do you agree that the same approach for asynchronous generation <5MW should be applied to that >5MW in that if the existing protection cannot be reset to RoCoF of 1Hzs^{-1} with a delay of 500ms, then it should just be disconnected/removed?
- Do you agree with the workgroup's proposal for type-tested plant?
- Do you agree that where practicable on existing relays, the overfrequency setting should be changed to the current requirements (and left as-set if the relay cannot accommodate it)?

- Do you agree with the workgroup's CBA analysis for the retrospective protection change?
- Do you agree with the proposed change implementation approach?
- What do you believe are the most important considerations in implementing the change?
- How can we ensure that all generation owners are aware of the consultation and given a chance to respond?

- Questions:
 - What can we learn from the past programme of protection setting changes?
 - Who should be interested?
 - How do we make sure they have their say?

- Options
 - Contact the workgroup, either individually or through the Technical Secretary
 - Contact a Distribution Code Review Panel member at an appropriate time
 - Respond to consultation
 - Further engagement events

- Contacts from today:

Mike Kay mkay@ieee.org

Graham Stein Graham.Stein@nationalgrid.com

Xiaoyao Zhou Xiaoyao.zhou@nationalgrid.com